



Annual Drinking Water Quality Report 2020-21

Section A - Summary



Declaration

I declare that the information provided in this Annual Drinking Water Quality Report for Tasmanian Water and Sewerage Corporation Pty Ltd ABN 47 162 220 653 in its capacity as a water and sewerage corporation licensed under the *Water and Sewerage Industry Act 2008* is complete and accurate.



Michael Brewster

Chief Executive Officer

Date: 30/09/2021

Document approval and issue notice

This is a managed document. Changes will only be issued as a complete replacement document. Recipients should remove superseded versions from circulation. This document is authorised for release once all signatures have been obtained.

Prepared: (for release)	Jes Temby (Laboratory Coordinator Customer & Data)	Date: 02/09/2021
Endorsed: (for acceptance)	Stephen Westgate (Acting Leader Water System Performance)	Date: 03/09/2021
Endorsed: (for acceptance)	Frances Smith (Department Manager System Performance & Productivity)	Date: 20/09/2021
Endorsed: (for acceptance)	Ailsa Sypkes (General Manager Governance & Assurance)	Date: 21/09/2021
Approved: (for acceptance)	Michael Brewster (Chief Executive Officer)	Date: 30/09/2021

Build status:

Version	Date	Author	Reason	Sections
1.0	30/09/2021	F. Smith	Final submission to DoH	All
1.1	29/10/2021	F. Smith	Amendments post DoH review	All

Amendments in this release:

Section title	Section number	Amendment summary
Section A	2.1, 6.1, 6.4, 6.5	Minor correction of errors

Distribution:

Copy number	Version	Issue date	Issued to
1.0	1.0	30/09/2021	Department of Health
2.0	1.1	29/10/2021	Public

Table of Contents

Declaration	i
Document approval and issue notice	ii
Introduction	2
Executive summary	3
Capital investments	3
Drinking water risk reduction	3
Customer impacts	3
Looking Forward	4
1. Approach to drinking water quality management	4
2. Drinking water supply systems	6
2.1 List of drinking water supply systems	6
2.2 Location of drinking water supply systems	9
2.3 Source water catchments	10
3. Quality of drinking water for FY2020-21	11
3.1 System performance	11
3.2 Microbiological performance	13
3.3 Metals performance	13
3.4 Disinfection-by-product performance	13
3.5 Fluoride performance	13
3.6 Incident-based BWAs	14
3.7 Compliance assessment	14
3.8 Maintaining water quality to customer tap	15
3.9 Aesthetic quality	15
3.10 Customer complaints	16
4. Current and future planning and works	17
4.1 Water supply improvement program	17
4.2 Water system optimisation program	17
4.3 Water quality portal	17
5. Reporting methodology	18
5.1 Understanding this report	18
5.2 Compliance sampling program	18
5.3 Assessing microbiological compliance	19
5.4 Assessing non-microbiological compliance	19
5.5 Assessing fluoride compliance	19
5.6 System issues	20
6. Appendices	21
6.1 Appendix A - Summary of ADWG health, physico-chemical and aesthetic limits	21
6.2 Appendix B - Summary of <i>E.coli</i> detections in drinking water systems	22
6.3 Appendix C - Summary of metals exceedances in compliance sample programs	23
6.4 Appendix D - Summary of disinfection-by-product exceedances in compliance sample programs	24
7. List of acronyms/terms of reference	26

Introduction

We are pleased to provide our FY2020-21 Annual Drinking Water Quality Report (ADWQR) as required under section 129B of the *Public Health Act 1997* and specified under section 13 of the Tasmanian Drinking Water Quality Guidelines 2015 (TDWQG).

This ADWQR consolidates information on each drinking water supply system against performance targets set out in the Australian Drinking Water Guidelines 2011 (ADWG).

The FY2020-21 ADWQR is comprised of two sections:

- Section A – provides a statewide overview of our drinking water supply systems and performance against the ADWG, as well as detailing our strategies to improve drinking water quality performance
- Section B – contains a detailed summary of each of our drinking water supply systems and a detailed assessment of performance against ADWG.

All supporting data used in this report is available on our website through our [Water Quality Portal](#)

Executive summary

Capital investments

During FY2020-21 a total of \$105.2 million in capital expenditure was delivered across a wide range of drinking water projects addressing compliance, growth and renewals of our water assets.

The focus has been the commencement of upgrade works at our largest water treatment plant, Bryn Estyn, which will secure quality drinking water to the greater Hobart area for the next 50 years.

Drinking water risk reduction

Over the past year a reduction in drinking water risks for our customers has been achieved through:

- improvement in operational compliance and staff awareness relating to water safety through an ongoing focus on Critical Control Points and Operational Control Points
- improvement in compliance with industry practice in our water supply networks through an ongoing focus on network residual disinfection
- the realisation of operational improvements arising from ongoing technical and network assessments and
- improved visibility of operational performance data to the organisation.

Customer impacts

During the financial year, three incident-based temporary BWAs were issued at Adventure Bay as a precautionary measure due to disinfection issues. Upgrades of the chlorination system and improved maintenance of the UV system have subsequently been implemented.

All breaches of ADWG or CCP were formally investigated and reviewed for the purposes of determining root causes and to facilitate targeted improvements in processes and infrastructure with a view to minimising the risk of repeat incidents. In each case, the incident review included an assessment of the risk that such an incident could occur in other systems across the state. Where the level of risk warranted action, plans have been put in place to minimise such risks.

Compliance outcomes

The percentage of systems compliant with Tasmanian Drinking Water Quality Guidelines (TDWQG) microbiological guidelines was 100 per cent, which means that 100 per cent of customers received microbiologically compliant water.¹

Metal concentrations above ADWG health limits were detected at Cornwall. Subsequent testing returned results that were within the guidelines.

Coles Bay had three samples with one disinfection-by-product above ADWG health limits. The maintenance of the activated carbon process at the WTP has significantly improved subsequent results.

There were no detections of fluoride in laboratory samples above the ADWG limit of 1.5 mg/L. Six systems (Bicheno, Burnie, Forth, Longford, Scamander and Leven River/Whitehills) failed to maintain an average dose of fluoride between 0.8-1.1 mg/L. Overall fluoride compliance remained at similar levels to the prior year and below the operational target of 97 per cent. This does not pose a risk to public safety and a Fluoride Improvement Plan (including potential capital projects) has been developed to focus efforts on optimisation and infrastructure upgrades of our fluoride system to meet both the health target and Tasmanian Code of Practice for the Fluoridation of Water Supplies.

Assessment of compliance against the drinking water sampling program (correct sample number and frequency) forms part of the compliance assessment prescribed in the ADWG, TDWQG and our DWQRMP. Sampling programs for all systems were complete.

Looking Forward

Looking ahead, we are planning to invest in further improvements to drinking water quality during FY2021-22 through measures such as WTP upgrades, system optimisation initiatives and other risk reduction activities. The work is included in our Price and Service Plan submission and will be funded through revenue and increased borrowings. Projects include:

- Upgrade to the Bryn Estyn WTP
- Installation of UV systems across multiple WTPs
- Upgrades to multiple fluoride dosing stations.

1. Approach to drinking water quality management

Drinking water is an important product, and as a trusted and respected provider of essential services to homes and businesses across Tasmania we are committed to supplying safe and good quality drinking water.

To ensure consistent management of drinking water from catchment to customer, the 12-element risk management framework detailed in our DWQRMP is adopted, which demonstrates compliance with the ADWG framework. The DWQRMP identifies risks to drinking water systems and the management practices adopted to mitigate these risks.

The ADWG provide definitions for two sets of guideline values:

- **Health-related guideline value** — The concentration or measure of a water quality characteristic that, based on present knowledge, does not result in any significant risk to the health of the consumer over a lifetime of consumption
- **Aesthetic-related guideline value** – The concentration or measure of a water quality characteristic that is associated with the acceptability of water to the consumer e.g. taste and odour.

¹ This excludes customers outside TasWater serviced land who receive non-potable water.

Samples are collected and tested in each drinking water supply in accordance with the sampling requirements prescribed in the ADWG, the TDWQG and our DWQRMP. Refer to Section 5 for further information on the compliance assessment framework utilised throughout this report.

2. Drinking water supply systems

Drinking water is sourced from 72 catchments located around Tasmania across a range of geographic and climatic zones.

As at 30 June 2021, TasWater was responsible for 60 drinking water supply systems (refer Table 1).

2.1 List of drinking water supply systems

Table 1: Potable drinking water supply systems with status as of 30th June 2021

System	Status	Catchment/ water source	Connections	Population	Treatment Process	Fluoridated supply
Adventure Bay	Potable	Bore	1	1	Disinfection only	No
Bicheno	Potable	Aspley River	1,037	1,089	Full treatment	Yes
Bothwell	Potable	Clyde River	327	585	Full treatment	No
Bracknell	Potable	Liffey River	187	420	Full treatment	No
Bridport	Potable	Brid River	1,096	1,271	Full treatment	Yes
Bronte Park	Potable	Bronte Canal	65	46	Full treatment	No
Bushy Park	Potable	Lake Fenton	125	248	Full treatment	Yes
Campbell Town	Potable	Elizabeth River	795	1,361	Full treatment	Yes
Coles Bay	Potable	Saltwater Creek	279	153	Full treatment	No
Conara/Epping	Potable	South Esk	68	158	Full treatment	No
Cornwall	Potable	Fanshaft Spring/ unnamed watercourse	48	81	Full treatment	No
Deep Creek	Potable	Deep Creek	2,364	4,725	Full treatment	Yes
Deloraine	Potable	Meander River	1,366	2,799	Full treatment	Yes
Distillery Creek	Potable	Distillery Creek / St Patricks River	14,099	27,974	Full treatment	Yes
Dover	Potable	Esperance River	750	1,234	Full treatment	Yes
Dowlings Creek	Potable	Dowlings Creek	103	216	Full treatment	No
Ellendale	Potable	Jones River	77	140	Full treatment	No
Fentonbury/Westerway	Potable	Lake Fenton	133	259	Full treatment	Yes
Fingal	Potable	South Esk River	401	715	Full treatment	No
Forth River	Potable	Forth River	19,019	37,950	Full treatment	Yes
Gawler River	Potable	Gawler River	6,092	12,382	Full treatment	Yes
Gladstone	Potable	Ringarooma River	84	120	Full treatment	No


System	Status	Catchment/ water source	Connections	Population	Treatment Process	Fluoridated supply
Greater Hobart	Potable	Lake Fenton	95,519	204,352	Full treatment (1)	Yes
		Derwent River Mt Wellington (multiple offtakes)			Disinfection only (9)	
Herrick	Potable	Cascade and Frome dams	27	61	Full treatment	No
Huon Valley	Potable	Huon River	4,339	8,724	Full treatment	Yes
King Island	Potable	Grassy River	603	1,046	Full treatment	Yes
Lady Barron	Potable	Bore	112	157	Full treatment	No
Lake Barrington	Potable	Lake Barrington	1,228	2,482	Full treatment	Yes
Leven River	Potable	Leven River	2,248	4,609	Full treatment	Yes
Longford	Potable	Macquarie River	4,643	9,793	Full treatment	Yes
Manuka River	Potable	Manuka River	593	815	Full treatment	Yes
Mathinna	Potable	South Esk	82	132	Full treatment	No
Maydena	Potable	Unnamed tributary	141	218	Full treatment	No
Mole Creek	Potable	Weir	202	391	Full treatment	No
National Park	Potable	Lake Fenton	23	32	Full treatment	Yes
North Esk	Potable	North Esk	15,094	31,978	Full treatment	Yes
Oatlands	Potable	Blackman River	493	873	Full treatment	Yes
Orford	Potable	Prosser River	1,187	857	Full treatment	Yes
Ouse and Hamilton	Potable	Derwent River	282	444	Full treatment	No
Pet River	Potable	Pet River	13,593	26,787	Full treatment	Yes
Queenstown	Potable	Conglomerate Creek	1,513	2,257	Full treatment	Yes
Ringarooma System	Potable	Dunn's Creek Dam/ Ringarooma River	679	1,138	Full treatment	Yes
Rocky Creek	Potable	Rocky Creek	226	506	Full treatment	Yes
Rosebery	Potable	Mountain Creek / Stitt River	677	804	Full treatment	Yes
Rossarden	Potable	Aberfoyle Creek	32	36	Full treatment	No
Scamander	Potable	Scamander River	530	692	Full treatment	Yes
Scottsdale	Potable	Great Forester River / Brid River	1,340	2,803	Full treatment	Yes

System	Status	Catchment/ water source	Connections	Population	Treatment Process	Fluoridated supply
South Esk	Potable	Lake Trevallyn	5,442	11,766	Full treatment	Yes
St Helens	Potable	Georges River	1,908	2,417	Full treatment	Yes
St Marys	Potable	Bore	367	605	Full treatment	Yes
Swansea	Potable	Swan River / Meredith River	897	1,274	Full treatment	Yes
Triabunna	Potable	Maclaines Creek / Brady's Creek	548	951	Full treatment	Yes
Tullah	Potable	Lake Rosebery	218	236	Full treatment	No
Tunbridge	Potable	Blackman River	118	201	Full treatment	No
Waratah	Potable	Waratah River	134	184	Full treatment	Yes
Wayatinah	Potable	Lake Liapootah	63	39	Full treatment	No
West Tamar	Potable	Lake Trevallyn	9,811	20,974	Full treatment	Yes
Westbury	Potable	Meander River	1,188	2,370	Full treatment	Yes
Whitemark	Potable	Pats River	178	261	Full treatment	No
Zeehan	Potable	Parting Creek	625	905	Full treatment	Yes
Total	60		215,419	438,097		

2.2 Location of drinking water supply systems

The location and system status (as at 30 June 2021) of all drinking water systems is shown in Figure 1.

Figure 1: Locations and status of drinking water systems.



2.3 Source water catchments

The drinking water catchments for each drinking water system are identified in Table 1. Each catchment has a comprehensive water quality monitoring program including specific monitoring for microbes, metals, pesticides and herbicides.

3. Quality of drinking water for FY2020-21

Routine compliance monitoring of water supply systems was conducted throughout FY2020-21. Water sampling was undertaken based on analysis of the ADWG requirements and was also informed by internal risk assessments to ensure sampling represented the water quality received by customers.

The frequency of monitoring is established in the compliance program, which has been designed in accordance with the recommendations in the ADWG and TDWQG. A risk-based approach was used to specify the chemical parameters included in the monitoring program.

The compliance program includes health parameters including microbiological, metals, chlorine residual and disinfection by-products. Furthermore, the program includes aesthetic parameters such as turbidity, pH and colour (see Appendix A).

All laboratory samples were analysed by NATA accredited laboratories.

3.1 System performance

Table 2: High level health performance outcome for drinking water supply systems (against ADWG health-regulated parameters) (☒ = compliant, ✗ = non-compliant)

System	Status	Status changes	Compliance program completeness	Microbiological performance	Fluoride performance	Metals performance	DBP performance
Adventure Bay	Potable	TBWA lifted	☒	☒	n/a	☒	☒
Bicheno	Potable		☒	☒	✗ ³	☒	☒
Bothwell	Potable		☒	☒	n/a	☒	☒
Bracknell	Potable		☒	☒	n/a	☒	☒
Bridport	Potable		☒	☒	☒	☒	☒
Bronte Park	Potable		☒	☒	n/a	☒	☒
Bushy Park	Potable		☒	☒	n/a	☒	☒
Campbell Town	Potable		☒	☒	☒	☒	☒
Coles Bay	Potable		☒	☒	n/a	☒	✗ ¹
Conara	Potable		☒	☒	n/a	☒	☒
Cornwall	Potable		☒	☒	n/a	✗ ²	☒
Deep Creek	Potable		☒	☒	☒	☒	☒
Deloraine	Potable		☒	☒	☒	☒	☒
Distillery Creek	Potable		☒	☒	☒	☒	☒
Dover	Potable		☒	☒	☒	☒	☒
Dowlings Creek	Potable		☒	☒	n/a	☒	☒
Ellendale	Potable		☒	☒	n/a	☒	☒
Fentonbury/Westerway	Potable		☒	☒	n/a	☒	☒
Fingal	Potable		☒	☒	n/a	☒	☒
Forth River	Potable		☒	☒	✗ ³	☒	☒
Gawler River	Potable		☒	☒	☒	☒	☒
Gladstone	Potable		☒	☒	n/a	☒	☒
Greater Hobart	Potable		☒	☒	☒	☒	☒
Herrick	Potable		☒	☒	n/a	☒	☒
Huon Valley	Potable		☒	☒	☒	☒	☒

System	Status	Status changes	Compliance program completeness	Microbiological performance	Fluoride performance	Metals performance	DBP performance
King Island	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Lady Barron	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	n/a	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Lake Barrington	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Leven River	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> ³	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Longford	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> ³	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Manuka River	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Mathinna	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	n/a	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Maydena	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	n/a	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Mole Creek	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	n/a	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
National Park	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	n/a	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
North Esk	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Oatlands	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Orford	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Ouse and Hamilton	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	n/a	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Pet River	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> ³	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Queenstown	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Ringarooma	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Rocky Creek	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Rosebery	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Rossarden	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	n/a	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Scamander	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> ³	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Scottsdale	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
South Esk	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
St Helens	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
St Marys	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Swansea	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Triabunna	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Tullah	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	n/a	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Tunbridge	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	n/a	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Waratah	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Wayatinah	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	n/a	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
West Tamar	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Westbury	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Whitemark	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	n/a	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Zeehan	Potable		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

1. DBP compliance assessment was deemed non-compliant against ADWG: refer to Table 6.4.
2. Metals compliance assessment was deemed non-compliant against ADWG: refer to Table 6.3.
3. Fluoride dosing station was non-compliant against the Fluoride Code of Practice: refer to Table 3.

3.2 Microbiological performance

Each drinking water system is sampled in accordance with the sampling frequency specified in the compliance sampling program.

A drinking water system is to be assessed for microbiological contamination in relation to *E.coli* and a system is deemed to have passed if greater than 98 per cent of samples over 12 months are free of *E.coli* (Section 13, TDWG).

The FY2020-21 microbiological performance is assessed against two indicators with the following results:

- 100.0 per cent (60 of 60) of systems met microbiological compliance (greater than 98 per cent of samples in systems were free of *E.coli*)
- 100 per cent of the serviced population achieved microbiological compliance.

A detailed summary of *E.coli* detections in potable systems is at Appendix B.

3.3 Metals performance

Monitoring for the presence of metals is a requirement under the TDWQG and is undertaken in line with the risk-based approach promoted by the ADWG. Sampling programs are designed specifically for each drinking water system based on the site-specific risks.

During FY2020-21 there was one system (Cornwall) affected by a single ADWG metals exceedance. The details of each ADWG metal exceedance are described in Appendix C.

3.4 Disinfection-by-product performance

During FY2020-21, detections of DBPs above the ADWG health limit were recorded in the Coles Bay system. The details of each DBP exceedance are described in Appendix D.

3.5 Fluoride performance

At the end of FY2020-21 there were 38 fluoride dosing systems across Tasmania. The average fluoride concentration should be maintained between 0.8 milligrams per litre and 1.1 milligrams per litre. Six fluoride dosing stations underperformed against this regulatory metric. (Refer to Table 3).

Table 3: Non-compliances against fluoride metrics in FY2020-21

Fluoridated water supply	Average of all [F] samples within the 0.8-1.1 mg/L range
Bicheno	Non-compliant (0.7 mg/L)
Pet River (Burnie)	Non-compliant (0.7 mg/L)
Forth	Non-compliant (0.7 mg/L)
Longford	Non-compliant (0.7 mg/L)
Scamander	Non-compliant (0.7 mg/L)
Leven River (Whitehills)	Non-compliant (0.5 mg/L)

An assessment of the three performance metrics for fluoride performance is shown in Table 4.

Table 4: Regulatory outcome for fluoridation systems in FY2020-21

Metric	Compliant	Non-compliant
Average of all [F] samples within the 0.8 -1.1 mg/L range	32	6
90% of all [F] samples are equal to or less than 1.1 mg/L	38	0
No sample should exceed 1.5 mg/L (ADWG limit)	38	0

3.6 Incident-based BWAs

In the FY2020-21 reporting period three incident based BWAs were issued to mitigate risks to customers while investigation and remediation actions took place (refer to Table 5).

Table 5: List of temporary BWAs issued in the FY2020-21 reporting period

Town	System	Dates	Nature of event
Adventure Bay - Shop	Adventure Bay	05/03/2021 – 06/03/2021	A BWA was issued on 5 March for the Adventure Bay Shop due to a failure of the UV system. The system was locked to prevent access by water carters. The UV system was repaired and follow up microbiological samples were clear. The BWA was lifted on 6 March 2021.
Adventure Bay - Shop	Adventure Bay	27/03/2021 – 29/03/2021	A BWA was issued on 27 March for the Adventure Bay Shop due to a failure of the chlorine system. The system was locked to prevent access by water carters. The chlorine system was repaired and follow up microbiological samples were clear. The BWA was lifted on 29 March 2021.
Adventure Bay - Shop	Adventure Bay	22/06/2021 – 09/07/2021	A BWA was issued on 22 June for the Adventure Bay Shop due to a failure of the chlorine mixing system. The system was locked to prevent access by water carters. A planned capital upgrade of the chlorine mixing system was brought forward to be completed during this shutdown. The BWA was lifted on 9 July 2021.

3.7 Compliance assessment

As previously noted, samples must be collected and tested in accordance with sampling requirements specified in each drinking water system compliance sample program (refer to section 5.2). The compliance sample program specifies the frequency of sampling as well as the required number of tests. All sample programs were complete for all systems.

3.8 Maintaining water quality to customer tap

Chlorine is widely used in the treatment of drinking water throughout the world to control microbiological contaminants such as bacteria and viruses. Chlorine has an important role to play in maintaining the microbiological quality of water from the WTP to the customer tap. It also provides a final barrier against microbiological recontamination. Residual levels 0.2 mg/L are considered the minimum required to provide an effective defence against minor and uncommon recontamination events (e.g. vermin ingress). Maintaining a healthy residual has also been proven to reduce aesthetic complaints from excessive biological growth.

The operational target for chlorine residual levels is a range between 0.2 mg/L to 0.8 mg/L. A review of historic chlorine performance indicated underperformance against the operational target.

A number of activities were initiated to improve performance and included education, review of sampling points, network cleaning programs in high-risk systems, increased monitoring, review of water age and storage levels in tanks and a focus on residuals through setting dose rates.

A focus in FY2020-21 was the implementation of a network maintenance strategy as part of a holistic risk management approach to water distribution networks including network audits, remote operated vehicle inspections, chlorine dosing targets and hygienic work practises.

In the FY2020-21 reporting period, the maximum chlorine residual across sampling locations was below the ADWG health guideline level (5 mg/L) and the chlorine residual averages were maintained within the operational range for most systems while all systems were above the lower limit of 0.2 mg/L.

3.9 Aesthetic quality

The aesthetic quality of drinking water is not a health concern. Common aesthetic considerations include discolouration and cloudiness, taste and odour. However, these aspects do have the potential to significantly affect community acceptance of drinking water. Aesthetic quality complaints are further described in relevant individual system performance reports (Section B).

Discolouration and turbidity are commonly caused by small particles of sediment suspended in water. The accumulation of sediment within the mains is often attributed to corrosion of distribution assets (particularly where there is ageing infrastructure) and is often attributed to the accumulation of sediment within the mains.

During disturbances (such as flushing of the mains or change in flow rate or flow direction in the pipes) sediment may become mobilised. These issues are not considered harmful to health, but TasWater appreciates that a supply which is discoloured in this manner can be aesthetically unacceptable.

Taste and odour can vary significantly, impacting consumers differently depending on individual sensitivities. Customers are encouraged to contact TasWater so that assistance can be provided with identifying the cause.


Earthy/musty issues impacting entire towns are typically caused by algae or bacteria metabolites in the source water. At certain periods in their seasonal lifecycle typically in warmer months these can release small amounts of the chemicals MIB and geosmin. These compounds may be noticeable by some consumers at levels as low as five parts per billion. These chemicals are not harmful to human health but can taste unpleasant.

3.10 Customer complaints

Throughout the FY2020-21 reporting period we received a total of 90 customer complaints relating to drinking water quality. This figure relates to all complaints which are received via our call centre or in writing, including Ombudsman enquiries.

In this period 53 complaints were received regarding discolouration, 10 regarding taste/odour issues, two related to cloudy water, and 25 were unable to be classified into the previous categories (the majority of which related to health alerts or stained washing). The number of complaints has decreased since the last reporting period. Complaints decreased during the warmer months and increased again as the weather became cooler.

All complaints are investigated and under the provisions of the TasWater customer charter we are required to respond to the customer within 10 working days (or other period as agreed) of receiving a complaint.



During FY2020-21 we improved the complaints recording process, enabling improved reporting and response to deliver a targeted reduction in water quality complaints.

Further details on complaints received are listed in the relevant individual system performance reports (Section B).

4. Current and future planning and works

4.1 Water supply improvement program

Over the next few years, strategic projects at Bryn Estyn, Forth and Leven WTPs will continue providing safe drinking water into the future. The WTPs are high priority due to the age of the assets and the size of the populations serviced by these plants. The upgrades are designed to increase capacity to deliver required demand and meet all water quality targets, as well as reduce the potential for taste and odour issues. Investment in ultra-violet (UV) disinfection units and in upgrades to fluoride dosing systems will improve the robustness of our WTPs.

4.2 Water system optimisation program

During FY2020-21, improvements in the performance and risk management capability of water treatment and distribution assets continued through the delivery of our Water System Optimisation Program.

Key highlights included:

- Improvement in operational compliance and staff awareness relating to water safety through our ongoing focus on CCP and OCP
- Improvement in compliance with industry practice in our water supply networks through an ongoing focus on network residual disinfection
- The realisation of operational improvements arising from ongoing technical and network assessments and
- Improved visibility of operational performance data within the organisation.

4.3 Water quality portal

Our drinking water data is available through an interactive map web-based platform (web application). The web application is updated with compliance results on a monthly basis. The public interface is designed to simplify the way water quality information is shared and provide greater transparency for our customers.

5. Reporting methodology

This section is intended to assist the reader with interpreting drinking water quality results and system performance statistics detailed throughout this document.

5.1 Understanding this report

This report meets the requirements specified under Tasmania's regulatory framework to ensure safe drinking water. The following legislation and other instruments apply to this ADWQR:

- Fluoridation Act 1968
- Public Health Act 1997
- Fluoridation Regulations 2019
- Australian Drinking Water Quality Guidelines 2011
- Tasmanian Drinking Water Quality Guidelines 2015
- Tasmanian Code of Practice for the Fluoridation of Public Water Supplies 2018.

Furthermore, the DWQRMP details risk-based requirements for drinking water supply systems.

For the purpose of this report, all data is assessed in relation to the health and aesthetic guidelines specified in the ADWG. The ADWG provide an authoritative reference to the water industry on what defines safe and good quality water, how it can be achieved and how it can be assured.

Each drinking water system identified in this document is addressed in detail to meet the requirements specified under the relevant legislation. This ensures the management of each drinking water system meets regulatory obligations within the legislation and protects the public's health.

This report focuses on specific requirements outlined within the above legislation:

- Microbiological compliance
- Non-microbiological compliance
- Public Health Alerts (Boil Water Alerts and Do Not Consume notices) and
- Fluoridation.

5.2 Compliance sampling program

Compliance monitoring is conducted in the distribution network and is a verification of the water quality customers receive. Samples are collected and tested for all drinking water systems in accordance with sampling requirements prescribed in the ADWG, TDWQG and the DWQRMP.

Drinking water quality monitoring confirms the final quality of water that is supplied to consumers. Therefore, sampling is required to be undertaken throughout the distribution network. This is performed at compliance sample points reflective of the quality of water supplied to customers' properties (e.g. at or close to water meters). The locations and numbers of compliance sampling points within a distribution system are determined by the complexity of the drinking water system. The compliance program considers populations and uses the ADWG methodology.

It should be noted in addition to the compliance sampling program, which samples the water the customer receives, additional operational and event-based monitoring is undertaken, which is outside the scope of this report. However, where an exceedance against ADWG has occurred in operational or event-based monitoring, it is disclosed in Section B.

5.3 Assessing microbiological compliance

The TDWQG require drinking water supplies to be sampled and tested at an accredited laboratory for *Escherichia coli* (*E. coli*) in accordance with the specified frequency outlined in the compliance sample program.

The compliance sampling program for microbiological compliance relates to the population serviced and dictates the number of samples required to verify the safety of the water to the consumer. Supplies servicing under 1,000 people require one sample per week, whereas populations greater than 1,000 people require more than one sample as specified in the ADWG.

Microbiological compliance is assessed for microbiological contamination in relation to *E.coli* and a system is deemed to have passed if greater than 98 percent of samples over 12 months are free of *E.coli*.

Where an exceedance has occurred at either a compliance or operational monitoring location, it is included in Appendix B of this report.

5.4 Assessing non-microbiological compliance

The TDWQG require our drinking water supplies to be sampled and tested in accordance with the compliance monitoring program set out in our DWQRMP.

In the reporting period monitoring programs are implemented for non-microbiological (physical and chemical) ADWG health-regulated parameters. Sampling programs for non-microbiological parameters including metals and DBPs may differ between systems and is dependent on risk. For historic trends, performance figures, where available, are entered from previous annual reports. It is to be noted that previous programs may differ from those defined in this year's report. To achieve compliance, 100 per cent of the samples tested must comply with the ADWG health targets.

Where an exceedance has occurred at a compliance monitoring location, it will be included in the appendix of Section A. For results above the ADWG limit but when rounded do not exceed the ADWG limit, they will be listed in Appendix 6.4 but not counted as an exceedance. Furthermore, where ADWG non-microbiological exceedances occurred at an operational monitoring point or as part of an investigation they are listed in Section B in the relevant drinking water supply system.

5.5 Assessing fluoride compliance

The ADWG health-based guideline value for fluoride has been set at 1.5 mg/L for fluoridated water supplies.

The *Tasmanian Code of Practice for the Fluoridation of Public Water Supplies 2018* (CoP) set minimum requirements for fluoridation operation and service delivery. These minimum requirements are consistent with the requirements of the *Fluoridation Act 1968* and *Fluoridation Regulations 2019*.

As the regulated entity the operating target is 1.00 mg/L fluoride in treated water. The fluoride target is specified as a concentration rather than a dose rate and assessed against the following metrics:

- Meet a compliance exposure target over a reporting year, that the average concentration of all fluoride samples taken within the reticulation network fall within the fluoride concentration operating range of 0.8 mg/L – 1.1 mg/L
- Meet a compliance performance target over a reporting year, that at least 90 per cent of all fluoride samples taken within a reticulation network are equal to or less than 1.1 mg/L

- Never allow the fluoride concentration to exceed 1.5 mg/L in any of the samples taken from within the reticulation network. A system that records a fluoride concentration greater than 1.5 mg/L will be assessed as non-compliant for that reporting period.

The samples taken from the fluoridated water reticulation supply are analysed and tested by a NATA-accredited laboratory at least twice in each calendar month.

5.6 System issues

A record of incidents and issues reported throughout the year and how they were addressed is maintained in the Incident Reporting Information System (IRIS). System incidents relate to laboratory test exceedances above the health limits specified in the ADWG (see Appendix A).

6. Appendices

6.1 Appendix A - Summary of ADWG health, physico-chemical and aesthetic limits

Parameter	Operational target	ADWG health	ADWG aesthetic	Comment
Microbiological				
Escherichia coli (<i>E. coli</i>) (MPN/100mL)	<1	<1	-	ADWG Health
Metals ADWG health regulated				
Antimony total (mg/L)	-	0.003	-	ADWG Health
Arsenic inorganic (mg/L)	-	0.01	-	ADWG Health
Barium total (mg/L)	-	2	-	ADWG Health
Boron (mg/L)	-	4	-	ADWG Health
Cadmium total (mg/L)	-	0.002	-	ADWG Health
Chromium (mg/L)	-	0.05	-	ADWG Health
Copper total (mg/L)	-	2	1	ADWG Health
Lead total (mg/L)	-	0.01	-	ADWG Health
Manganese total (mg/L)	-	0.5	0.1	ADWG Health
Mercury total (mg/L)	-	0.001	-	ADWG Health
Molybdenum total (mg/L)	-	0.05	-	ADWG Health
Nickel total (mg/L)	-	0.02	-	ADWG Health
Selenium total (mg/L)	-	0.01	-	ADWG Health
Disinfection by-products				
Chloroacetic acid (mg/L)	-	0.15	-	ADWG Health
Dichloroacetic acid (mg/L)	-	0.1	-	ADWG Health
Trichloroacetic acid (mg/L)	-	0.1	-	ADWG Health
Total trihalomethanes (mg/L)	-	0.25	-	ADWG Health
Fluoride				
Fluoride (mg/L)	1.0	1.5	-	DoH regulations & ADWG Health
General physico-chemical parameters				
Chlorine residual (mg/L)	> 0.2 to <0.8	5	0.6	ADWG Health
pH (pH Units)	6.5 to 8.5	N/A	6.5 to 8.5	ADWG Aesthetic
Turbidity (NTU)	<1	N/A	5	ADWG Aesthetic

6.2 Appendix B - Summary of *E.coli* detections in drinking water systems

System	Treatment process	Detection date	Nature of event	Outcomes
Smithton	Full treatment	10/11/2020	Routine sample (10/11/2020) taken from 024SMSPO501 (Supply) detected 3.1 MPN/100mL <i>E. coli</i> . Department of Health (DoH) was immediately notified. The system was flushed, and subsequent samples were clear of <i>E. coli</i> .	Reported to DoH Subsequent sample clear of <i>E. coli</i>

6.3 Appendix C - Summary of metals exceedances in compliance sample programs

System	Treatment process	Detection date	Detection details	Outcomes
Cornwall	Full Treatment	13/11/2020	Routine quarterly sample (13/11/2020) taken from COW51W08 detected lead above the health limit. Department of Health (DoH) was notified. System was flushed and subsequent samples were clear.	Reported to DoH System flushed Subsequent sample clear of lead

6.4 Appendix D - Summary of disinfection-by-product exceedances in compliance sample programs

System	Treatment process	Detection date	Detection details	Outcomes
Coles Bay	Full Treatment	9/03/2021	Total Trihalomethane exceedance in compliance sample at GCSTE86 (Coles Bay/Park Esplanade) of 305 ug/L	Reported to DoH

6.5 Appendix E – Occurrences of non-reportable exceedances (rounding)

Parameter	ADWG Limit (µg/L)	Rounded Limit (µg/L)	Non-reportable exceedance
Trichloroacetic Acid	100	150	ADWG exceedance in compliance sample at WYSTE97 (Wayatinah) on 2/07/2020 of 118 µg/L
			ADWG exceedance in compliance sample at EDSTE62 (Ellendale) on 08/10/2020 of 109 µg/L
			ADWG exceedance in compliance sample at WYSTE97 (Wayatinah) on 19/10/2020 of 110 µg/L
			ADWG exceedance in compliance sample at FBSTE03 (Fentonbury) on 28/10/2020 of 121 µg/L
			ADWG exceedance in compliance sample at WYSTE97 (Wayatinah) on 02/11/2020 of 103 µg/L
Trihalomethane	250	270	ADWG exceedance in compliance sample at GCSTE86 (Coles Bay/Park Esplanade) on 9/02/2021 of 270 µg/L
			ADWG exceedance in compliance sample at DLW51W01 (Deloraine) on 21/01/2021 of 1.16 µg/L
Mercury	1	1.5	

7. List of acronyms/terms of reference

Acronym/term	Definition
ADWG	Australian Drinking Water Guidelines
BWA	Boil Water Alert (used for microbiological non-compliances): water must be boiled before consumption
CCP	Critical control points
CoP	Tasmanian Code of Practise for the Fluoridation of Public Water Supplies 2018
DNC	Do Not Consume
DBPs	Disinfection by-products
DoH	Department of Health
DWQRMP	Drinking Water Quality Risk Management Plan
<i>E.coli</i>	<i>Escherichia coli</i>
FY	Financial year
IRIS	Incident Reporting Information System
mg/L	Milligrams per litre
MIB	2-Methylisoborneol
MPN/100mL	Most probable number per 100 millilitres
NATA	National Association of Testing Authorities
NTU	Nephelometric turbidity unit (measure of turbidity)
OCP	Operational control point
PHA	Public Health Alert (the water cannot be safely consumed) when non-microbiological samples are non-compliant (i.e. any parameter that has a corresponding ADWG health-related guideline value exceeded)
Physico-chemical	Physical and chemical properties
Portable	Water classified fit for consumption by DoH
TBWA	A temporary Boil Water Alert can be issued by TasWater at the direction of the Director of Public Health in order to protect the public
TDWQG	Tasmanian Drinking Water Quality Guidelines (the Guidelines issued by the Director of Public Health under the <i>Public Health Act 1997</i>)
$\mu\text{g}/\text{L}$	Micrograms per litre
UV	Ultraviolet
Water Supply	A water supply controlled by the regulated entity that is used for supplying water to the public and intended for human consumption
WTP	Water treatment plant



Annual Drinking Water Quality Report 2020-21

Section B - Summary



Table of Contents

1. Adventure Bay drinking water system	4
2. Bicheno drinking water system.....	9
3. Bothwell drinking water system	14
4. Bracknell drinking water system.....	19
5. Bridport drinking water system	24
6. Bronte Park drinking water system.....	29
7. Bushy Park drinking water system	34
8. Campbell Town drinking water system.....	39
9. Coles Bay drinking water system	44
10. Conara drinking water system	49
11. Cornwall drinking water system	54
12. Deep Creek drinking water system	59
13. Deloraine drinking water system	65
14. Distillery Creek drinking water system	70
15. Dover drinking water system	76
16. Dowlings Creek drinking water system.....	81
17. Ellendale drinking water system	86
18. Fentonbury/Westerway drinking water system	91
19. Fingal drinking water system	96
20. Forth River drinking water system.....	101
21. Gawler River drinking water system	107
22. Gladstone drinking water system	112
23. Greater Hobart drinking water system	117
24. Herrick drinking water system	133
25. Huon Valley drinking water system	138
26. King Island drinking water system	144
27. Lady Barron drinking water system	149
28. Lake Barrington drinking water system	154
29. Leven River drinking water system	159
30. Longford drinking water system	164
31. Manuka River drinking water system	170
32. Mathinna drinking water system	175
33. Maydena drinking water system.....	180
34. Mole Creek drinking water system	185
36. North Esk drinking water system	195
37. Oatlands drinking water system	202

38. Orford drinking water system	207
39. Ouse and Hamilton drinking water system.....	212
40. Pet River drinking water system	217
41. Queenstown (Conglomerate Creek) drinking water system	223
42. Ringarooma System drinking water system	228
43. Rocky Creek drinking water system.....	233
44. Rosebery drinking water system.....	238
45. Rossarden drinking water system	243
46. Scamander drinking water system.....	248
47. Scottsdale drinking water system	253
48. South Esk drinking water system	258
49. St Helens drinking water system.....	263
50. St Marys drinking water system.....	268
51. Swansea drinking water system.....	273
52. Triabunna drinking water system	278
53. Tullah drinking water system.....	283
54. Tunbridge drinking water system	288
55. Waratah drinking water system.....	293
56. Wayatinah drinking water system	298
57. West Tamar drinking water system	303
58. Westbury drinking water system	310
59. Whitemark drinking water system.....	315
60. Zeehan drinking water system.....	320

Acronyms and Terms of Reference

ADWG	Australian Drinking Water Guidelines
Mean	Average measurement
DoH	Department of Health
DBPs	Disinfection By-products
<i>E.coli</i>	Escherichia coli
FSA	fluorosilicic acid
HU	Hazen unit (measure of colour (true))
KL	kilolitre
Max	Maximum measurement
ML	Megalitres
µg/L	Micrograms per litre
mg/L	Milligrams per litre
Min	Minimum measurement
M	Monthly
MPN/100mL	Most probably number per 100 millilitres
NTU	Nephelometric turbidity unit (measure of turbidity)
n/a	not applicable
PHA	Public Health Alert
Q	Quarterly
Sat.	Saturated
NaF	Sodium fluoride
TBA	To be advised
2M	Twice a month
UF Membrane	Ultrafiltration membrane
UV	Ultraviolet light
Potable	Water classified fit for consumption by DoH
W	Weekly

1. Adventure Bay drinking water system

1.1. System summary (2020–21)

Adventure Bay drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	1
Population serviced	1
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ■ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	3	Temporary BWAs issued (5/3/2021–6/3/2021, 27/3/2021–29/3/2021, 22/6/2021–9/7/2021)
Notifications made to DoH	3	UV system failure, chlorine system failure, chorine mixing system failure.
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	Chlorination Upgrade	Completed	2020/2021	\$40,000




Figure 1.1-a Adventure Bay system schematic




Figure 1.1-b Map of Adventure Bay monitoring system

1.2. Summary of annual reticulation compliance (2020–21)

Table 1.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Shop Sample Tap	ABSTE288	W	Q	Q	n/a	Q	n/a
Number Planned Samples		52	4	4	n/a	4	n/a
Number Samples Tested		52	4	4	n/a	4	n/a

1.3. Summary of current and historic performance (2016–21)

Table 1.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	98.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	n/a	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

1.4. Analysis of current health performance (2020–21)

Table 1.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 1.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	0.0003	<0.0003	0.0004
Barium	2	mg/L	4	0	100	0.0009	0.0007	0.0011
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0011	0.0010	0.0012
Copper	2	mg/L	4	0	100	0.0399	0.0203	0.0928
Lead	0.01	mg/L	4	0	100	0.0007	0.0003	0.0015
Manganese	0.5	mg/L	4	0	100	0.0121	0.0068	0.0185
Mercury	0.001	mg/L	4	0	100	0.00005	<0.00003	0.00007
Molybdenum	0.05	mg/L	4	0	100	0.0010	0.0008	0.0011
Nickel	0.02	mg/L	4	0	100	0.0012	0.0006	0.0020
Selenium	0.01	mg/L	4	0	100	0.0001	0.0001	0.0001

Table 1.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	33	20	42
Monochloroacetic acid	150	µg/L	4	0	100	4	<3	5
Trichloroacetic acid	100	µg/L	4	0	100	55	32	79
Total trihalomethanes	250	µg/L	4	0	100	66	49	80

Table 1.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.34	0.06	0.67
Colour True	HU	15	4	3	5
pH	Units	6.5 – 8.5	7.22	6.57	7.91
Turbidity	NTU	1	0.43	0.22	0.81

1.5. Analysis of overall system performance (2020–21)

Table 1.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
5/3/2021–6/3/2021	<p>A BWA was issued on 5 March for the Adventure Bay Shop due to a failure of the UV system.</p> <p>The system was locked to prevent access by water carters.</p> <p>The UV system was repaired and follow up microbiological samples were clear.</p> <p>The BWA was lifted on 6 March 2021.</p>	✓	✓
27/3/2021–9/3/2021	<p>A BWA was issued on 27 March for the Adventure Bay Shop due to a failure of the chlorine system.</p> <p>The system was locked to prevent access by water carters.</p> <p>The chlorine system was repaired and follow up microbiological samples were clear.</p> <p>The BWA was lifted on 29 March 2021.</p>	✓	✓
22/6/2021–9/7/2021	<p>A BWA was issued on 22 June for the Adventure Bay Shop due to a failure of the chlorine mixing system.</p> <p>The system was locked to prevent access by water carters.</p> <p>A planned capital upgrade of the chlorine mixing system was brought forward to be completed during this shutdown.</p> <p>The BWA was lifted on 6 March 2021</p>	✓	✓

2. Bicheno drinking water system

2.1. System summary (2020–21)

Bicheno drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	1,037
Population serviced	1,089
Fluoride	Sodium Fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ■ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	1	Low fluoride levels detected
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 2.1-a Bicheno system schematic




Figure 2.1-b Map of Bicheno monitoring system

2.2. Summary of annual reticulation compliance (2020–21)

Table 2.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Bicheno Primary School/Garden Tap	GBSTE83	W	Q	Q	2M	Q	n/a
Bicheno/47 Tasman Hwy next to SPS	GBSTE84	n/a	n/a	n/a	2M	n/a	M
Number Planned Samples		52	4	4	48	4	12
Number Samples Tested		52	4	4	48	4	12

2.3. Summary of current and historic performance (2016–21)

Table 2.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

2.4. Analysis of current health performance (2020–21)

Table 2.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 2.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.7
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant	 Non-compliant	

Table 2.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0028	0.0026	0.0030
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0044	0.0020	0.0097
Lead	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Manganese	0.5	mg/L	4	0	100	0.0013	0.0005	0.0022
Mercury	0.001	mg/L	4	0	100	0.00011	<0.00003	0.00019
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Selenium	0.01	mg/L	4	0	100	0.0002	<0.0001	0.0004

Table 2.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	4	3	6
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	13	2	4
Total trihalomethanes	250	µg/L	4	0	100	36	31	44

Table 2.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.69	0.10	1.08
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.26	6.66	7.59
Turbidity	NTU	1	0.20	0.08	1.67

2.5. Analysis of overall system performance (2020–21)

Table 2.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
September 2020 – November 2020 April 2021 – May 2021	Low fluoride levels detected	✓	✓

3. Bothwell drinking water system

3.1. System summary (2020–21)

Bothwell drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	327
Population serviced	585
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	1	Other (stained washing)

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	WTP Upgrade	Planning	2024/2025	TBD




Figure 3.1-a Bothwell system schematic




Figure 3.1-b Map of Bothwell monitoring system

3.2. Summary of annual reticulation compliance (2020–21)

Table 3.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Bothwell/Michael St, Sample Tap	BOSTE98	W	Q	Q	n/a	Q	n/a
Number Planned Samples		52	4	4	n/a	4	n/a
Number Samples Tested		52	4	4	n/a	4	n/a

3.3. Summary of current and historic performance (2016–21)

Table 3.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

3.4. Analysis of current health performance (2020–21)

Table 3.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 3.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0137	0.0110	0.0162
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0002	<0.0001	0.0003
Copper	2	mg/L	4	0	100	0.0029	0.0021	0.0039
Lead	0.01	mg/L	4	0	100	0.0001	0.0001	0.0002
Manganese	0.5	mg/L	4	0	100	0.0048	0.0027	0.0082
Mercury	0.001	mg/L	4	0	100	0.00008	<0.00003	0.00016
Molybdenum	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Nickel	0.02	mg/L	4	0	100	0.0003	0.0003	0.0004
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 3.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	15	7	19
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	14	6	20
Total trihalomethanes	250	µg/L	4	0	100	73	53	118

Table 3.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.60	0.35	1.18
Colour True	HU	15	1	<1	2
pH	Units	6.5 – 8.5	7.27	7.00	7.55
Turbidity	NTU	1	0.32	0.07	1.75

3.5. Analysis of overall system performance (2020–21)

Table 3.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 3.5-b Water quality customer complaints by month and type

4. Bracknell drinking water system

4.1. System summary (2020–21)

Bracknell drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	187
Population serviced	420
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	1	Other (illness from water)

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$600,000




Figure 4.1-a Bracknell system schematic




Figure 4.1-b Map of Bracknell monitoring system

4.2. Summary of annual reticulation compliance (2020–21)

Table 4.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Bracknell/Louisa Street	BNW51W01 ¹	W	Q	Q	n/a	Q	n/a
Bracknell/Emma St - Opposite Field St	BRACKST01	W	Q	Q	n/a	Q	n/a
Number Planned Samples		52	4	4	n/a	4	n/a
Number Samples Tested		52	4	4	n/a	4	n/a

¹ Replaced by BRACKST01 11th February 2021

4.3. Summary of current and historic performance (2016–21)

Table 4.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

4.4. Analysis of current health performance (2020–21)

Table 4.4-a Summary of health guideline exceedances

Summary of health guideline exceedances				
Parameter Exceeding	Date	Details	Resampled	
No ADWG exceedances				

Table 4.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0075	0.0057	0.0090
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Copper	2	mg/L	4	0	100	0.0041	0.0025	0.0053
Lead	0.01	mg/L	4	0	100	0.0006	0.0002	0.0013
Manganese	0.5	mg/L	4	0	100	0.0019	0.0011	0.0039
Mercury	0.001	mg/L	4	0	100	0.00014	<0.00003	0.00038
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0003	0.0002	0.0004
Selenium	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0002

Table 4.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	11	8	14
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	14	9	17
Total trihalomethanes	250	µg/L	4	0	100	27	19	33

Table 4.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.99	0.60	1.25
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.49	6.76	8.14
Turbidity	NTU	1	0.24	0.06	0.98

4.5. Analysis of overall system performance (2020–21)

Table 4.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 4.5-b Water quality customer complaints by month and type

5. Bridport drinking water system

5.1. System summary (2020–21)

Bridport drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	1,096
Population serviced	1,271
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	106	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	2	Discolouration

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$600,000




Figure 5.1-a Bridport system schematic




Figure 5.1-b Map of Bridport monitoring system

5.2. Summary of annual reticulation compliance (2020–21)

Table 5.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Bridport/Emma Street	BRWS1W03	W	Q	Q	2M	Q	n/a
Bridport/Bently St down from Pier	BRWS1W04	W	n/a	n/a	2M	n/a	n/a
Number Planned Samples		106	4	4	48	4	n/a
Number Samples Tested		106	4	4	48	4	n/a

5.3. Summary of current and historic performance (2016–21)

Table 5.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

5.4. Analysis of current health performance (2020–21)

Table 5.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 5.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		1.0
90% of F results are equal to or less than 1.1 mg/L		100%
█ Compliant █ Non-compliant		

Table 5.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0172	0.0138	0.0187
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0089	0.0069	0.0127
Lead	0.01	mg/L	4	0	100	0.0007	0.0003	0.0013
Manganese	0.5	mg/L	4	0	100	0.0111	0.0047	0.0200
Mercury	0.001	mg/L	4	0	100	0.00003	<0.00003	0.00004
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Nickel	0.02	mg/L	4	0	100	0.0004	0.0003	0.0005
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	0.0001

Table 5.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	5	3	7
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	4	2	6
Total trihalomethanes	250	µg/L	4	0	100	44	30	58

Table 5.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.72	0.21	1.16
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.20	6.35	7.63
Turbidity	NTU	1	0.33	0.10	0.67

5.5. Analysis of overall system performance (2020–21)

Table 5.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 5.5-b Water quality customer complaints by month and type

6. Bronte Park drinking water system

6.1. System summary (2020–21)

Bronte Park drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	65
Population serviced	46
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 6.1-a Bronte Park system schematic




Figure 6.1-b Map of Bronte Park monitoring system

6.2. Summary of annual reticulation compliance (2020–21)

Table 6.2-a Sampling program

Planned compliance sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Bronte Park/50 Bronte Estate Rd	BPSTE03	W	Q	Q	n/a	Q	n/a	
Number Planned Samples	52	4	4	n/a	4	n/a		
Number Samples Tested	52	4	4	n/a	4	n/a		

6.3. Summary of current and historic performance (2016–21)

Table 6.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	80.8%	87.3%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	91.7%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

6.4. Analysis of current health performance (2020–21)

Table 6.4-a Summary of health guideline exceedances

Summary of health guideline exceedances				
Parameter Exceeding	Date	Details	Resampled	
No ADWG exceedances				

Table 6.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0021	0.0017	0.0026
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Copper	2	mg/L	4	0	100	0.0083	0.0073	0.0099
Lead	0.01	mg/L	4	0	100	0.0004	0.0004	0.0005
Manganese	0.5	mg/L	4	0	100	0.0036	0.0033	0.0040
Mercury	0.001	mg/L	4	0	100	0.00014	<0.00003	0.00035
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0002	0.0001	0.0004
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 6.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	21	9	32
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	36	17	59
Total trihalomethanes	250	µg/L	4	0	100	38	30	47

Table 6.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.67	0.45	0.97
Colour True	HU	15	1.5	1	2
pH	Units	6.5 – 8.5	7.61	7.11	8.13
Turbidity	NTU	1	0.22	0.11	0.43

6.5. Analysis of overall system performance (2020–21)

Table 6.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

7. Bushy Park drinking water system

7.1. System summary (2020–21)

Bushy Park drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	125
Population serviced	248
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	8	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 7.1-a Bushy Park system schematic




Figure 7.1-b Map of Bushy Park monitoring system

7.2. Summary of annual reticulation compliance (2020–21)

Table 7.2-a Sampling program

Planned compliance sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Glenora/Glenora Fire Station	BPSTE212	W	Q	Q	n/a	Q	n/a	
Gretna/Opp. 3449 Lyell Hwy	GRSTE108	W	Q	Q	n/a	Q	n/a	
Number Planned Samples		104	8	8	n/a	8	n/a	
Number Samples Tested		104	8	8	n/a	8	n/a	

7.3. Summary of current and historic performance (2016–21)

Table 7.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	n/a	n/a	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	n/a	n/a	100.0%	100.0%	100.0%
Disinfection by products	n/a	n/a	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

7.4. Analysis of current health performance (2020–21)

Table 7.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 7.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	8	0	100	0.0025	0.0017	0.0031
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	8	0	100	0.0035	0.0027	0.0046
Lead	0.01	mg/L	8	0	100	0.0003	0.0002	0.0004
Manganese	0.5	mg/L	8	0	100	0.0002	<0.0001	0.0005
Mercury	0.001	mg/L	8	0	100	0.00010	<0.00003	0.00022
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	8	0	100	0.0002	<0.0001	0.0007
Selenium	0.01	mg/L	8	0	100	<0.0001	<0.0001	<0.0001

Table 7.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100	11	4	18
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	8	0	100	26	17	37
Total trihalomethanes	250	µg/L	8	0	100	55	43	64

Table 7.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.68	0.35	1.23
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.33	6.92	7.69
Turbidity	NTU	1	0.22	0.06	0.76

7.5. Analysis of overall system performance (2020–21)

Table 7.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

8. Campbell Town drinking water system

8.1. System summary (2020–21)

Campbell Town drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	795
Population serviced	1,361
Fluoride	Sodium Fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

 Compliant Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	1	Discolouration

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$1,000,000




Figure 8.1-a Campbell Town system schematic




Figure 8.1-b Map of Campbell Town monitoring system

8.2. Summary of annual reticulation compliance (2020–21)

Table 8.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Campbell Town/Cnr Bridge St & Hamilton St (#2)	CTW51W12	W	n/a	n/a	2M	n/a	n/a
Ross/ Bridge St SPS	ROW51W01	W	Q	Q	2M	Q	n/a
Number Planned Samples		104	4	4	48	4	n/a
Number Samples Tested		104	4	4	48	4	n/a

8.3. Summary of current and historic performance (2016–21)

Table 8.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

8.4. Analysis of current health performance (2020–21)

Table 8.4-a Summary of health guideline exceedances

Summary of health guideline exceedances				
Parameter Exceeding	Date	Details		Resampled
No ADWG exceedances				

Table 8.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.8
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant	 Non-compliant	

Table 8.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0101	0.0073	0.0157
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0144	0.0107	0.0181
Lead	0.01	mg/L	4	0	100	0.0015	0.0010	0.0020
Manganese	0.5	mg/L	4	0	100	0.0020	0.0011	0.0038
Mercury	0.001	mg/L	4	0	100	0.00005	<0.00003	0.00009
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0002	0.0002	0.0003
Selenium	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0003

Table 8.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	16	13	19
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	27	23	31
Total trihalomethanes	250	µg/L	4	0	100	80	70	93

Table 8.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.49	0.02	0.94
Colour True	HU	15	1	1	1
pH	Units	6.5 – 8.5	7.22	6.55	7.60
Turbidity	NTU	1	0.36	0.07	3.48

8.5. Analysis of overall system performance (2020–21)

Table 8.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 8.5-b Water quality customer complaints by month and type

9. Coles Bay drinking water system

9.1. System summary (2020–21)

Coles Bay drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	279
Population serviced	153
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	83.3%	☒	100.0%	12	2

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	1	Elevated DBPs
Public health warnings issued	0	
Notifications made to DoH	2	DBP exceedance in sampling program
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	Reservoir Upgrade	In Progress	2021/2022	\$3,000,000




Figure 9.1-a Coles Bay system schematic




Figure 9.1-b Map of Coles Bay monitoring system

9.2. Summary of annual reticulation compliance (2020–21)

Table 9.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Coles Bay/Park Esp. NEW Sample Tap	GCSTE86	W	Q	M	n/a	Q	n/a
Number Planned Samples		52	4	12	n/a	4	n/a
Number Samples Tested		52	4	12	n/a	4	n/a

9.3. Summary of current and historic performance (2016–21)

Table 9.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	90.0%	87.5% ²	91.7%	97.9%	83.3%

█ Compliant █ Non-compliant

9.4. Analysis of current health performance (2020–21)

Table 9.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
Total Trihalomethanes	9/2/2021	270 µg/L in regular compliance sampling (<i>not relevant to compliance assessment due to rounding</i>)	✓
Total Trihalomethanes	9/3/2021	305 µg/L in regular compliance sampling (<i>relevant to compliance assessment</i>)	✓

² Capital improvements identified to improve ongoing disinfection-by-product compliance

Table 9.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0261	0.0033	0.0904
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0019	0.0009	0.0037
Lead	0.01	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Manganese	0.5	mg/L	4	0	100	0.0010	0.0003	0.0141
Mercury	0.001	mg/L	4	0	100	0.00007	<0.00003	0.00012
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0002	0.0001	0.0003
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 9.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	12	0	100	9	1	27
Monochloroacetic acid	150	µg/L	12	0	100	<3	<3	6
Trichloroacetic acid	100	µg/L	12	0	100	10	<1	38
Total trihalomethanes	250	µg/L	12	0	67	144	29	305

Table 9.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.38	0.03	1.14
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.27	6.95	7.80
Turbidity	NTU	1	0.51	0.18	2.72

9.5. Analysis of overall system performance (2020–21)

Table 9.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
9/2/2021	Total trihalomethane exceedance of 270 µg/L in compliance sample.	✓	✓
2/3/2021	Total trihalomethane exceedance of 289 µg/L in investigation sample.	✓	✓
9/3/2021	Total trihalomethane exceedance of 305 µg/L in compliance sample.	✓	✓
16/3/2021	Total trihalomethane exceedance of 324 µg/L in investigation sample.	✓	✓
24/3/2021	Total trihalomethane exceedance of 318 µg/L in investigation sample.	✓	✓

10. Conara drinking water system

10.1. System summary (2020–21)

Conara drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	68
Population serviced	158
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	8	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend (\$'000)
No projected capital investment				




Figure 10.1-a Conara system schematic




Figure 10.1-b Map of Conara monitoring system

10.2. Summary of annual reticulation compliance (2020–21)

Table 10.2-a Sampling program

Planned compliance sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Conara/Cnr Conara Rd and Panec St	CNW51W06	W	Q	Q	n/a	Q	n/a	
Epping/4 Barton Rd	EP51W03	W	Q	Q	n/a	Q	n/a	
Number Planned Samples		104	8	8	n/a	8	n/a	
Number Samples Tested		104	8	8	n/a	8	n/a	

10.3. Summary of current and historic performance (2016–21)

Table 10.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100%	98.1%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	97.9%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	75.0%	87.5% ³	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

10.4. Analysis of current health performance (2020–21)

Table 10.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

³ Planned improvements to WTP to improve disinfection of raw water when turbidity increases during flood events and improve disinfection-by-product compliance

Table 10.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	0.0003	<0.0003	0.0004
Barium	2	mg/L	8	0	100	0.0089	0.0041	0.0200
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	8	0	100	0.0089	0.0025	0.0418
Lead	0.01	mg/L	8	0	100	0.0045	0.0001	0.0010
Manganese	0.5	mg/L	8	0	100	0.0012	0.0001	0.0026
Mercury	0.001	mg/L	8	0	100	0.00006	<0.00003	0.00014
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	0.0001
Nickel	0.02	mg/L	8	0	100	0.0006	0.0004	0.0008
Selenium	0.01	mg/L	8	0	100	<0.0001	<0.0001	0.0002

Table 10.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100	7	1	21
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	8	0	100	8	<1	30
Total trihalomethanes	250	µg/L	8	0	100	22	11	42

Table 10.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.60	0.22	0.88
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.58	6.55	8.30
Turbidity	NTU	1	0.27	0.07	0.99

10.5. Analysis of overall system performance (2020–21)

Table 10.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

11. Cornwall drinking water system

11.1. System summary (2020–21)

Cornwall drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	48
Population serviced	81
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	98.0%	☒	100.0%	4	1
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ☒ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	1	Lead exceedance
Public health warnings issued	0	
Notifications made to DoH	1	Lead exceedance
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend (\$'000)
No projected capital investment				




Figure 11.1-a Cornwall system schematic




Figure 11.1-b Map of Cornwall monitoring system

11.2. Summary of annual reticulation compliance (2020–21)

Table 11.2-a Sampling program

Planned compliance sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Cornwall/37-41 Alexander St	COW51W08	W	Q	Q	n/a	Q	n/a	
Number Planned Samples		52	4	4	n/a	4	n/a	
Number Samples Tested		52	4	4	n/a	4	n/a	

11.3. Summary of current and historic performance (2016–21)

Table 11.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	91.7%	91.7% ⁴	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	98.0%
Disinfection by products	n/a	n/a	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

11.4. Analysis of current health performance (2020–21)

Table 11.4-a Summary of health guideline exceedances

Summary of health guideline exceedances				
Parameter Exceeding	Date	Details		Resampled
Lead	13/11/2020	Lead of 0.0737 mg/L in monthly compliance sample		✓

⁴ System was subject to PHA when *E. coli* exceeded ADWG

Table 11.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	14	0	100	<0.0005	<0.0005	0.0005
Arsenic	0.01	mg/L	14	0	100	0.0004	<0.0003	0.0007
Barium	2	mg/L	14	0	100	0.1290	0.1210	0.1363
Cadmium	0.002	mg/L	14	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	14	0	100	<0.0001	<0.0001	<0.0001
Copper	2	mg/L	14	0	100	0.1673	0.0091	0.6287
Lead	0.01	mg/L	14	1	100	0.0187	0.0002	0.0737
Manganese	0.5	mg/L	14	0	100	<0.0001	<0.0001	<0.0001
Mercury	0.001	mg/L	14	0	100	0.00005	<0.00003	0.00007
Molybdenum	0.05	mg/L	14	0	100	0.0005	0.0003	0.0007
Nickel	0.02	mg/L	14	0	100	0.0007	0.0001	0.0025
Selenium	0.01	mg/L	14	0	100	<0.0001	<0.0001	0.0001

Table 11.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	4	2	6
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	2	<1	3
Total trihalomethanes	250	µg/L	4	0	100	22	16	31

Table 11.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.68	0.46	0.91
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.62	6.71	8.22
Turbidity	NTU	1	0.23	0.06	0.56

11.5. Analysis of overall system performance (2020–21)

Table 11.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
13/11/2020	Routine quarterly sample taken from COW51W08 detected lead above the health limit. System was flushed and subsequent sample was clear.	✓	✓

12. Deep Creek drinking water system

12.1. System summary (2020–21)

Deep Creek drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	2,364
Population serviced	4,725
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	99.5%	☒	98.0%	208	1
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	12	0
DBPs	100.0%	☒	100.0%	12	0

Legend: Compliant Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	1	<i>E. coli</i> exceedance
Public health warnings issued	0	
Notifications made to DoH	1	<i>E. coli</i> exceedance
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$1,000,000
Fluoride Upgrade	Fluoride System Renewal	In Progress	2021/2022	TBD




Figure 12.1-a Deep Creek system schematic




Figure 12.1-b Map of Deep Creek monitoring system

12.2. Summary of annual reticulation compliance (2020–21)

Table 12.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Smithton/Irishtown Fire Station#	023SMS0106	W	Q	Q	2M	n/a	n/a
Smithton/Marine Park Sample Point (Stanley)	024SMS0401	W	Q	Q	2M	Q	n/a
Smithton/Nelson St Sample Point	024SMS0501	W	n/a	n/a	n/a	n/a	n/a
Smithton/Scotchtown Rd Sample Point	024SMS0601	W	Q	Q	n/a	Q	n/a
Number Planned Samples	208	12	12	48	8	n/a	
Number Samples Tested	208	12	12	48	8	n/a	

12.3. Summary of current and historic performance (2016–21)

Table 12.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	99.5%	99.5%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	99.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

12.4. Analysis of current health performance (2020–21)

Table 12.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
<i>E. coli</i>	10/11/2020	<i>E. coli</i> of 3.1 MPN/100mL in monthly compliance sample	✓




Figure 12.4-b Microbiological non-compliances by month

Table 12.4-c Fluoride distribution performance

Distribution fluoride performance	
Indicator	2020–21
F exceeding 1.5 mg/L	0
Average F concentration range (0.8 mg/L – 1.1 mg/L)	0.9
90% of F results are equal to or less than 1.1 mg/L	100%

█ Compliant █ Non-compliant

Table 12.4-d Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	12	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	12	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	12	0	100	0.0086	0.0053	0.0109
Cadmium	0.002	mg/L	12	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	12	0	100	0.0003	0.0001	0.0005
Copper	2	mg/L	12	0	100	0.0012	0.0006	0.0018
Lead	0.01	mg/L	12	0	100	0.0002	0.0001	0.0005
Manganese	0.5	mg/L	12	0	100	0.0049	0.0016	0.0092
Mercury	0.001	mg/L	12	0	100	0.00005	<0.00003	0.00011
Molybdenum	0.05	mg/L	12	0	100	<0.0001	<0.0001	0.0001
Nickel	0.02	mg/L	12	0	100	0.0005	0.0003	0.0010
Selenium	0.01	mg/L	12	0	100	<0.0001	<0.0001	<0.0001

Table 12.4-e Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	12	0	100	9	3	16
Monochloroacetic acid	150	µg/L	12	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	12	0	100	7	3	14
Total trihalomethanes	250	µg/L	12	0	100	81	56	102

Table 12.4-f General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.61	0.15	3.30
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.51	6.78	8.18
Turbidity	NTU	1	0.25	0.07	1.51

12.5. Analysis of overall system performance (2020–21)

Table 12.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
10/11/2020	<i>E. coli</i> exceedance	✓	✓

13. Deloraine drinking water system

13.1. System summary (2020–21)

Deloraine drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	1,366
Population serviced	2,799
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	106	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	8	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	1	Mercury exceedance in sampling program (under rounding limit)
Customer complaints	2	Discolouration

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$600,000




Figure 13.1-a Deloraine system schematic




Figure 13.1-b Map of Deloraine monitoring system

13.2. Summary of annual reticulation compliance (2020–21)

Table 13.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Deloraine/Deloraine, Barrack St	DLW51W01	W	Q	Q	2M	Q	n/a	
Deloraine/Deloraine, Train Park	DLW51W02 ⁵	W	Q	Q	2M	Q	n/a	
Deloraine/51 West Parade	DELST02	W	Q	Q	2M	Q	n/a	
Number Planned Samples		106	8	8	48	8	n/a	
Number Samples Tested		106	8	8	48	8	n/a	

13.3. Summary of current and historic performance (2016–21)

Table 13.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

13.4. Analysis of current health performance (2020–21)

Table 13.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
Mercury	21/01/2021	0.00116 mg/L in regular compliance sampling <i>(relevant to compliance assessment)</i>	Y

⁵ Replaced by DELST02, 1st March 2021

Table 13.4-b Fluoride distribution performance

Distribution fluoride performance	
Indicator	2020–21
F exceeding 1.5 mg/L	0
Average F concentration range (0.8 mg/L – 1.1 mg/L)	0.8
90% of F results are equal to or less than 1.1 mg/L	100%

 Compliant  Non-compliant

Table 13.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	0.0006
Arsenic	0.01	mg/L	8	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	8	0	100	0.0062	0.0053	0.0067
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	0.0001	<0.0001	0.0003
Copper	2	mg/L	8	0	100	0.0031	0.0019	0.0051
Lead	0.01	mg/L	8	0	100	0.0002	<0.0001	0.0004
Manganese	0.5	mg/L	8	0	100	0.0015	0.0003	0.0034
Mercury	0.001	mg/L	8	0	100	0.00021	<0.00003	0.0011 ⁶
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	8	0	100	0.0002	<0.0001	0.0003
Selenium	0.01	mg/L	8	0	100	0.0001	<0.0001	0.0003

Table 13.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100	6	2	12
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	8	0	100	7	3	17
Total trihalomethanes	250	µg/L	8	0	100	19	11	31

⁶ Maximum result, when rounded, does not exceed limit.

Table 13.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.66	0.32	0.98
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.51	6.95	7.81
Turbidity	NTU	1	0.17	0.06	1.07

13.5. Analysis of overall system performance (2020–21)

Table 13.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
21/1/2021	Mercury exceedance of 0.00116 mg/L. Does not exceed rounding limit.	✓	✓




Figure 13.5-b Water quality customer complaints by month and type

14. Distillery Creek drinking water system

14.1. System summary (2020–21)

Distillery Creek drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	14,099
Population serviced	27,974
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	517	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	10	Discolouration, taste and odour, cloudy, other (stained washing)

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	In Progress	2022/2023	TBD




Figure 14.1-a Distillery Creek system schematic




Figure 14.1-b Map of Distillery Creek monitoring system

14.2. Summary of annual reticulation compliance (2020–21)

Table 14.2.a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Denman Rd PS	LRP54W01	W	n/a	n/a	n/a	n/a	n/a
Kings Meadows, 9/1.11 Blaydon St	LRW51W10 ⁷	W	n/a	n/a	n/a	n/a	n/a
6 Norwich Street - Sth Launceston	DCST05	W	n/a	n/a	n/a	n/a	n/a
East Launceston, Crn High & Adelaide St	LRW51W11 ⁸	W	n/a	n/a	n/a	n/a	n/a
69 High Street - East Launceston	DCST02	W	n/a	n/a	n/a	n/a	n/a
Invermay, Mayne St	LRW51W14	W	n/a	n/a	n/a	n/a	n/a
Launceston, York Street Public Toilets	LRW51W09	W	n/a	n/a	n/a	n/a	n/a
Mowbray, 7 Derby St	LRW51W13	W	n/a	n/a	2M	n/a	n/a
South Launceston, Mulgrave St Park	LRW51W16	W	Q	Q	2M	Q	n/a
Summerhill, 194 Peel St	LRW51W12	W	n/a	n/a	n/a	n/a	n/a
West Launceston, Granville St	LRP57W01 ⁹	W	n/a	n/a	n/a	n/a	n/a
Drivers Run Booster	DCR51W07	W	n/a	n/a	n/a	n/a	n/a
6 Floreat Crescent	DCST06 ¹⁰	W	n/a	n/a	n/a	n/a	n/a
Number Planned Samples		517	4	4	48	4	n/a
Number Samples Tested		517	4	4	48	4	n/a

⁷ Replaced by DCST05 31st May 2021

⁸ Replaced by DCST02 31st May 2021

⁹ Replaced by DCST01 4th March 2021

¹⁰ New installation 31st May 2021

14.3. Summary of current and historic performance (2016–21)

Table 14.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

14.4. Analysis of current health performance (2020–21)

Table 14.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 14.4-b Fluoride distribution performance

Distribution fluoride performance	
Indicator	2020–21
F exceeding 1.5 mg/L	0
Average F concentration range (0.8 mg/L – 1.1 mg/L)	0.9
90% of F results are equal to or less than 1.1 mg/L	100%

█ Compliant █ Non-compliant

Table 14.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0091	0.0078	0.0100
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0002	0.0001	0.0003
Copper	2	mg/L	4	0	100	0.0140	0.0089	0.0213
Lead	0.01	mg/L	4	0	100	0.0003	0.0001	0.0004
Manganese	0.5	mg/L	4	0	100	0.0064	0.0020	0.0140
Mercury	0.001	mg/L	4	0	100	<0.00003	<0.00003	<0.00003
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0004	0.0002	0.0005
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 14.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	7	4	12
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	7	3	12
Total trihalomethanes	250	µg/L	4	0	100	29	21	36

Table 14.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.59	0.02	1.21
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.22	6.35	8.56
Turbidity	NTU	1	0.41	0.00	6.48

14.5. Analysis of overall system performance (2020–21)

Table 14.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 14.5-b Water quality customer complaints by month and type

15. Dover drinking water system

15.1. System summary (2020–21)

Dover drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	750
Population serviced	1,234
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	53	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	WTP Upgrade	Planning	2024/2025	TBD




Figure 15.1-a Dover system schematic




Figure 15.1-b Map of Dover monitoring system

15.2. Summary of annual reticulation compliance (2020–21)

Table 15.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Dover/Sample Tap	DOSTE37	W	Q	Q	2M	Q	n/a
Dover/No.4 P/S Kent Beach Rd	DOSTE38	n/a	n/a	n/a	2M	n/a	n/a
Number Planned Samples		53	4	4	48	4	n/a
Number Samples Tested		53	4	4	48	4	n/a

15.3. Summary of current and historic performance (2016–21)

Table 15.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

15.4. Analysis of current health performance (2020–21)

Table 15.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 15.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.9
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant	 Non-compliant	

Table 15.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0060	0.0054	0.0067
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0168	0.0123	0.0223
Lead	0.01	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Manganese	0.5	mg/L	4	0	100	0.0006	0.0004	0.0010
Mercury	0.001	mg/L	4	0	100	<0.00006	<0.00003	0.00010
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0003	0.0002	0.0005
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	0.0001

Table 15.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	19	13	26
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	24	11	38
Total trihalomethanes	250	µg/L	4	0	100	51	33	65

Table 15.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.78	0.23	1.08
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	6.98	6.13	7.63
Turbidity	NTU	1	0.20	0.05	0.60

15.5. Analysis of overall system performance (2020–21)

Table 15.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

16. Dowlings Creek drinking water system

16.1. System summary (2020–21)

Dowlings Creek drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	103
Population serviced	216
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	51	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	6	Discolouration

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	WTP Upgrade	Planning	2024/2025	TBD




Figure 16.1-a Dowlings Creek system schematic




Figure 16.1-b Map of Dowlings Creek monitoring system

16.2. Summary of annual reticulation compliance (2020–21)

Table 16.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Yolla/Church	034YLSP0001	W	Q	Q	n/a	Q	n/a	
Number Planned Samples		51	4	4	n/a	4	n/a	
Number Samples Tested		51	4	4	n/a	4	n/a	

16.3. Summary of current and historic performance (2016–21)

Table 16.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	98.2%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

16.4. Analysis of current health performance (2020–21)

Table 16.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 16.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0036	0.0031	0.0040
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0087	0.0077	0.0105
Lead	0.01	mg/L	4	0	100	0.0007	0.0005	0.0009
Manganese	0.5	mg/L	4	0	100	0.0141	0.0090	0.0192
Mercury	0.001	mg/L	4	0	100	0.00010	<0.00003	0.00029
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0003	0.0003	0.0004
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 16.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	51	33	86
Monochloroacetic acid	150	µg/L	4	0	100	5	<3	10
Trichloroacetic acid	100	µg/L	4	0	100	44	37	49
Total trihalomethanes	250	µg/L	4	0	100	87	62	125

Table 16.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.55	0.11	1.07
Colour True	HU	15	4	2	6
pH	Units	6.5 – 8.5	7.51	7.19	8.00
Turbidity	NTU	1	0.22	0.07	2.71

16.5. Analysis of overall system performance (2020–21)

Table 16.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 16.5-b Water quality customer complaints by month and type

17. Ellendale drinking water system

17.1. System summary (2020–21)

Ellendale drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	77
Population serviced	140
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	12	0

Legend: ☒ Compliant 🟥 Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	1	DBP exceedances in sampling program (under rounding limit)
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	WTP Upgrade	Planning	2024/2025	TBD




Figure 17.1-a Ellendale system schematic




Figure 17.1-b Map of Ellendale monitoring system

17.2. Summary of annual reticulation compliance (2020–21)

Table 17.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Ellendale/Sample Tap	EDSTE62	W	Q	M	n/a	Q	n/a	
Number Planned Samples		52	4	12	n/a	4	n/a	
Number Samples Tested		52	4	12	n/a	4	n/a	

17.3. Summary of current and historic performance (2016–21)

Table 17.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	95.8%	97.9%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

17.4. Analysis of current health performance (2020–21)

Table 17.4-a Summary of health guideline exceedances

Summary of health guideline exceedances				
Parameter Exceeding	Date	Details		Resampled
Trichloroacetic acid	8/10/2020	109 µg/L in regular compliance sampling <i>(relevant to compliance assessment)</i>		Y

Table 17.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0040	0.0033	0.0046
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0004	0.0004	0.0004
Copper	2	mg/L	4	0	100	0.0029	0.0014	0.0065
Lead	0.01	mg/L	4	0	100	0.0002	<0.0001	0.0004
Manganese	0.5	mg/L	4	0	100	0.0005	<0.0001	0.0008
Mercury	0.001	mg/L	4	0	100	0.00009	0.00006	0.00012
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0001	<0.0001	0.0002
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 17.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	12	0	100	32	12	71
Monochloroacetic acid	150	µg/L	12	0	100	3	<3	4
Trichloroacetic acid	100	µg/L	12	0	100	75	50	109 ¹¹
Total trihalomethanes	250	µg/L	12	0	100	88	70	112

Table 17.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.55	0.30	1.05
Colour True	HU	15	2.5	2	4
pH	Units	6.5 – 8.5	7.56	7.07	7.97
Turbidity	NTU	1	0.21	0.06	0.70

¹¹ Maximum result, when rounded, does not exceed limit.

17.5. Analysis of overall system performance (2020–21)

Table 17.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
8/10/2020	Trichloroacetic acid exceedance of 109 µg/L. Does not exceed rounding limit.	✓	✓

18. Fentonbury/Westerway drinking water system

18.1. System summary (2020–21)

Fentonbury/Westerway drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	133
Population serviced	259
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	8	0

☒ Compliant ■ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	1	DBP exceedance in sampling program (under rounding limit)
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend (\$'000)
No projected capital investment				




Figure 18.1-a Fentonbury/Westerway system schematic




Figure 18.1-b Map of Fentonbury/Westerway monitoring system

18.2. Summary of annual reticulation compliance (2020–21)

Table 18.2-a Sampling program

Planned compliance sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Fentonbury/1654 Gordon River Road	FBSTE02	W	Q	Q	n/a	Q	n/a	
Fentonbury/304 Ellendale Rd	FBSTE03	W	Q	Q	n/a	Q	n/a	
Number Planned Samples		104	8	8	n/a	8	n/a	
Number Samples Tested		104	8	8	n/a	8	n/a	

18.3. Summary of current and historic performance (2016–21)

Table 18.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	n/a	n/a	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	n/a	n/a	100.0%	100.0%	100.0%
Disinfection by products	n/a	n/a	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

18.4. Analysis of current health performance (2020–21)

Table 18.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
Trichloroacetic acid	28/10/2020	121 µg/L in regular compliance sampling <i>(relevant to compliance assessment)</i>	Y

Table 18.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	8	0	100	0.0022	0.0015	0.0029
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	<0.0001	<0.0001	0.0001
Copper	2	mg/L	8	0	100	0.0080	0.0067	0.0096
Lead	0.01	mg/L	8	0	100	0.0005	0.0003	0.0006
Manganese	0.5	mg/L	8	0	100	0.0016	0.0007	0.0040
Mercury	0.001	mg/L	8	0	100	0.00005	<0.00003	0.00009
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Selenium	0.01	mg/L	8	0	100	<0.0001	<0.0001	<0.0001

Table 18.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100.0%	30	20	51
Monochloroacetic acid	150	µg/L	8	0	100.0%	<3	<3	4
Trichloroacetic acid	100	µg/L	8	0	100.0%	62	41	121 ¹²
Total trihalomethanes	250	µg/L	8	0	100.0%	85	69	115

Table 18.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.66	0.04	1.19
Colour True	HU	15	1.5	<1	2
pH	Units	6.5 – 8.5	7.16	6.67	7.46
Turbidity	NTU	1	0.56	0.11	1.34

¹² Maximum result, when rounded, does not exceed limit.

18.5. Analysis of overall system performance (2020–21)

Table 18.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
28/10/2020	Trichloroacetic acid exceedance of 121 µg/L. Does not exceed rounding limit.	✓	✓

19. Fingal drinking water system

19.1. System summary (2020–21)

Fingal drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	401
Population serviced	715
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
Fluoride Upgrade	New Fluoride Installation	Planning	2021/2022	TBD




Figure 19.1-a Fingal system schematic




Figure 19.1-b Map of Fingal monitoring system

19.2. Summary of annual reticulation compliance (2020–21)

Table 19.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Avoca/crn Falmouth & Arthur St	AVW51W01	W	Q	Q	n/a	Q	n/a	
Fingal/5-7 Gleadow St	FIW51W09	W	n/a	n/a	n/a	n/a	n/a	
Number Planned Samples	104	4	4	n/a	4	n/a	n/a	
Number Samples Tested	104	4	4	n/a	4	n/a	n/a	

19.3. Summary of current and historic performance (2016–21)

Table 19.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

19.4. Analysis of current health performance (2020–21)

Table 19.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 19.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	28	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	28	0	100	<0.0003	<0.0003	0.0004
Barium	2	mg/L	28	0	100	0.0106	0.0093	0.0128
Cadmium	0.002	mg/L	28	0	100	<0.0001	<0.0001	0.0001
Chromium	0.05	mg/L	28	0	100	<0.0001	<0.0001	<0.0001
Copper	2	mg/L	28	0	100	0.0067	0.0014	0.0123
Lead	0.01	mg/L	28	0	100	0.0006	0.0001	0.0012
Manganese	0.5	mg/L	28	0	100	0.0064	0.0008	0.0197
Mercury	0.001	mg/L	28	0	100	0.00005	<0.00003	0.00008
Molybdenum	0.05	mg/L	28	0	100	0.0002	0.0002	0.0002
Nickel	0.02	mg/L	28	0	100	0.0002	<0.0001	0.0005
Selenium	0.01	mg/L	28	0	100	<0.0001	<0.0001	<0.0001

Table 19.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	17	0	100	20	11	35
Monochloroacetic acid	150	µg/L	17	0	100	<3	<3	4
Trichloroacetic acid	100	µg/L	17	0	100	22	9	44
Total trihalomethanes	250	µg/L	17	0	100	59	39	83

Table 19.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.74	0.23	1.27
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.36	6.58	7.94
Turbidity	NTU	1	0.30	0.12	0.84

19.5. Analysis of overall system performance (2020–21)

Table 19.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

20. Forth River drinking water system

20.1. System summary (2020–21)

Forth River drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	19,019
Population serviced	37,950
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	779	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	16	0
DBPs	100.0%	☒	100.0%	12	0

☒ Compliant ■ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	1	Low fluoride levels detected
Customer complaints	5	Discolouration, taste and odour, other (fluoride general)

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	Forth WTP Upgrade	Planning	2025/2026	\$140,000,000




Figure 20.1-a Forth River system schematic




Figure 20.1-b Map of Forth River monitoring system

20.2. Summary of annual reticulation compliance (2020–21)

Table 20.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Woodrising Avenue – SPS Spreyton	FORST01	W	n/a	n/a	n/a	n/a	n/a
24 Allport St – West Leith	FORST02	W	n/a	n/a	n/a	Q	n/a
Gilbert Street SPS Latrobe	FORST03	W	n/a	n/a	2M	n/a	n/a
Opposite 151 Gunn Street	FORST04	W	Q	Q	n/a	Q	n/a
Opposite 12 Brook Street	FORST05	W	Q	n/a	n/a	n/a	n/a
Hawley Esplanade SPS Hawley Beach	FORST06	W	Q	Q	2M	Q	n/a
Gawler/Turners Beach Esplanade	074TBSP0101	W	n/a	n/a	n/a	n/a	n/a
180 Wrenswood Drive	FORST07	W	Q	Q	n/a	Q	n/a
Paloona Road (Near PRV)	FORST08	W	n/a	n/a	n/a	n/a	n/a
5 Browns Road – Port Sorell	FORST09	W	n/a	n/a	n/a	n/a	n/a
16 Rubicon Rise	FORST10	W	n/a	n/a	n/a	n/a	n/a
24 McCall Terrace – Stony Rise	FORST11	W	n/a	n/a	n/a	n/a	n/a
22 Tatiana Close	FORST12	W	n/a	n/a	n/a	n/a	n/a
Kelcey Tier Road WPS Inlet	FORST13	W	n/a	n/a	n/a	n/a	n/a
26 North Caroline Street	FORST14	W	n/a	n/a	n/a	n/a	n/a
Number Planned Samples		779	16	12	48	12	n/a
Number Samples Tested		779	16	12	48	12	n/a

20.3. Summary of current and historic performance (2016–21)

Table 20.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	99.7%	100.0%	99.8%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

 Compliant  Non-compliant

20.4. Analysis of current health performance (2020–21)

Table 20.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 20.4-b Fluoride distribution performance

Distribution fluoride performance	
Indicator	2020–21
F exceeding 1.5 mg/L	0
Average F concentration range (0.8 mg/L – 1.1 mg/L)	0.6
90% of F results are equal to or less than 1.1 mg/L	100%

Compliant Non-compliant

Table 20.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	16	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	16	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	16	0	100	0.0072	0.0050	0.0101
Cadmium	0.002	mg/L	16	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	16	0	100	0.0003	<0.0001	0.0006
Copper	2	mg/L	16	0	100	0.0043	0.0004	0.0140
Lead	0.01	mg/L	16	0	100	0.0005	<0.0001	0.0018
Manganese	0.5	mg/L	16	0	100	0.0018	0.0004	0.0068
Mercury	0.001	mg/L	16	0	100	0.00006	<0.00003	0.00016
Molybdenum	0.05	mg/L	16	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	16	0	100	0.0001	<0.0001	0.0003
Selenium	0.01	mg/L	16	0	100	<0.0001	<0.0001	<0.0001

Table 20.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	12	0	100	14	4	20
Monochloroacetic acid	150	µg/L	12	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	12	0	100	26	17	36
Total trihalomethanes	250	µg/L	12	0	100	53	32	74

Table 20.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.73	0.00	1.87
Colour True	HU	15	<1	<1	3
pH	Units	6.5 – 8.5	7.53	6.53	9.60
Turbidity	NTU	1	0.27	0.08	12.10

20.5. Analysis of overall system performance (2020–21)

Table 20.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
July 2020 – December 2020	Low fluoride levels detected	✓	
February 2021 – June 2021			✓




Figure 20.5-b Water quality customer complaints by month and type

21. Gawler River drinking water system

21.1. System summary (2020–21)

Gawler River drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	6,092
Population serviced	12,382
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	153	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	6	Discolouration, other (stained washing)

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 21.1-a Gawler River system schematic




Figure 21.1-b Map of Gawler River monitoring system

21.2. Summary of annual reticulation compliance (2020–21)

Table 21.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Gawler/Ulverstone Swimming Pool	064EUSP0201	W	Q	Q	2M	Q	n/a
Gawler/Ulverstone Council Chambers	064UVSP0101	W	n/a	n/a	n/a	n/a	n/a
Gawler/Flora St Wst Ulverstone	064WUSP0101	W	Q	n/a	2M	Q	n/a
Number Planned Samples		153	8	4	48	8	n/a
Number Samples Tested		153	8	4	48	8	n/a

21.3. Summary of current and historic performance (2016–21)

Table 21.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	99.8%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

21.4. Analysis of current health performance (2020–21)

Table 21.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 21.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.8
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant  Non-compliant		

Table 21.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	8	0	100	0.0136	0.0113	0.0198
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	0.0002	<0.0001	0.0003
Copper	2	mg/L	8	0	100	0.0060	0.0026	0.0132
Lead	0.01	mg/L	8	0	100	0.0004	0.0001	0.0008
Manganese	0.5	mg/L	8	0	100	0.0067	0.0016	0.0187
Mercury	0.001	mg/L	8	0	100	0.00010	<0.00003	0.00039
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	8	0	100	0.0017	0.0007	0.0046
Selenium	0.01	mg/L	8	0	100	<0.0001	<0.0001	<0.0001

Table 21.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	6	1	19
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	24	15	30
Total trihalomethanes	250	µg/L	4	0	100	71	46	96

Table 21.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.43	0.00	1.07
Colour True	HU	15	<1	<1	2
pH	Units	6.5 – 8.5	7.59	6.86	8.20
Turbidity	NTU	1	0.38	0.00	7.36

21.5. Analysis of overall system performance (2020–21)

Table 21.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 21.5-b Water quality customer complaints by month and type

22. Gladstone drinking water system

22.1. System summary (2020–21)

Gladstone drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	84
Population serviced	120
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend (\$'000)
No projected capital investment				




Figure 22.1-a Gladstone system schematic




Figure 22.1-b Map of Gladstone monitoring system

22.2. Summary of annual reticulation compliance (2020–21)

Table 22.2-a Sampling program

Planned compliance sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Gladstone/Fire Station	GSW51W01	W	Q	Q	n/a	Q	n/a
Number Planned Samples		52	4	4	n/a	4	n/a
Number Samples Tested		52	4	4	n/a	4	n/a

22.3. Summary of current and historic performance (2016–21)

Table 22.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	16.7%	50.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	n/a	n/a	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

22.4. Analysis of current health performance (2020–21)

Table 22.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 22.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0094	0.0040	0.0215
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0066	0.0047	0.0081
Lead	0.01	mg/L	4	0	100	0.0005	0.0004	0.0007
Manganese	0.5	mg/L	4	0	100	0.0006	0.0004	0.0008
Mercury	0.001	mg/L	4	0	100	<0.00003	<0.00003	<0.00003
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0003	0.0003	0.0004
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	0.0002

Table 22.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	21	10	37
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	4
Trichloroacetic acid	100	µg/L	4	0	100	30	14	51
Total trihalomethanes	250	µg/L	4	0	100	70	41	109

Table 22.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.65	0.41	1.06
Colour True	HU	15	1.25	<1	3
pH	Units	6.5 – 8.5	7.35	6.62	7.87
Turbidity	NTU	1	0.26	0.12	0.46

22.5. Analysis of overall system performance (2020–21)

Table 22.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

23. Greater Hobart drinking water system

23.1. System summary (2020–21)

Greater Hobart drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	95,519
Population serviced	204,352
Fluoride	Lake Fenton: Sodium fluoride All others: Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	5682	0
Fluoride	100.0%	☒	100.0%	144	0
Metals	99.88%	☒	100.0%	72	1
DBPs	100.0%	☒	100.0%	72	0

☒ Compliant ☒ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	1	Antimony exceedance
Public health warnings issued	0	
Notifications made to DoH	1	Antimony exceedance
Customer complaints	26	Discolouration, taste and odour, cloudy, other (stained washing, illness)

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	Bryn Estyn Upgrade	In progress	2022/2023	\$239,000,000
Fluoride Upgrade	New Fluoride Tank	Planning	2021/2022	TBD





Figure 23.1-a Greater Hobart system schematic




Figure 23.1-b Map of Greater Hobart – Brighton monitoring system




Figure 23.1-c Map of Greater Hobart – Clarence monitoring system




Figure 23.1-d Map of Greater Hobart – Coal Valley monitoring system




Figure 23.1-e Map of Greater Hobart – Glenorchy monitoring system




Figure 23.1-f Map of Greater Hobart – Hobart monitoring system




Figure 23.1-g Map of Greater Hobart – Kingborough monitoring system




Figure 23.1-h Map of Greater Hobart – National Park monitoring system




Figure 23.1-i Map of Greater Hobart – New Norfolk monitoring system




Figure 23.1-j Map of Greater Hobart – Sorell monitoring system




Figure 23.1-k Map of Greater Hobart – Southern Midlands monitoring system

23.2. Summary of annual reticulation compliance (2020–21)

Table 23.2-a Sampling program – Brighton

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Vineyard Dr Tanks	BRSTE217	W	n/a	n/a	n/a	n/a	n/a	
Campania Res	NLSTE09	W	n/a	n/a	n/a	n/a	n/a	
Richmond Res	NLSTE10	W	n/a	n/a	n/a	n/a	n/a	
Old Beach Res Sample Tap	SRSTE03	W	n/a	n/a	n/a	n/a	n/a	
Bridgewater/Dental Clinic Opp Bus Stop 57	BRSTE118	W	n/a	n/a	n/a	n/a	n/a	
Compton Downs, St Anne's/NEW Street Entrance	BRSTE119	W	Q	Q	n/a	Q	n/a	
Gagebrook/9 Barrob St, Gagebrook	BRSTE361 ¹³	W	n/a	n/a	n/a	n/a	n/a	
2 Mollineux Drive Old Beach	OLDBCH01	W	n/a	n/a	n/a	n/a	n/a	
Brighton/Crn Briggs Rd and Redside Dr	BRSTE122	W	n/a	n/a	n/a	n/a	n/a	
Tea Tree/Merrieworth Rd (NEW)	BRSTE225	W	n/a	n/a	n/a	n/a	n/a	
Pontville Public Building	BRSTE120	W	Q	Q	2M	Q	n/a	
Bridgewater/Herdmans Cove	BRSTE360	W	n/a	n/a	n/a	n/a	n/a	
Number Planned Samples		572	8	8	24	8	n/a	
Number Samples Tested		572	8	8	24	8	n/a	

Table 23.2-b Sampling program – Clarence

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Lindisfarne, Regis Aged Care Centre, Acorn Dr	CLSTE120	W	n/a	n/a	n/a	n/a	n/a	
73 Droughty Point Rd	CLSTE124	W	n/a	n/a	n/a	n/a	n/a	
Cambridge, 273 Kennedy Drive	CLSTE126	W	n/a	n/a	n/a	n/a	n/a	
Mt Rumney/68 Centauri Dr	CLSTE131	W	n/a	n/a	n/a	n/a	n/a	
Otago,/77 Otage Bay Rd	CLSTE160	W	n/a	n/a	n/a	n/a	n/a	

¹³ Replaced by OLDBCH01 8th February 2021

Tranmere, Norla St P/S	CLSTE158	W	Q	Q	n/a	Q	n/a
Seven Mile Beach - 76 Surf Road	CLSTE125	W	n/a	n/a	n/a	n/a	n/a
Rosny Esplanade Park Opp. No 2	CLSTE121	W	n/a	n/a	n/a	n/a	n/a
Mornington, 116 Mornington Rd	CLSTE123	W	n/a	n/a	n/a	n/a	n/a
Mount Rumney (private water supply) /Sample Tap	CLSTE154	M	n/a	n/a	n/a	n/a	n/a
Lauderdale, crn Balook St & Hadlow St/Sample Tap	CLSTE155	W	Q	Q	n/a	Q	n/a
Howrah PRV Pit Cnr Howrah Rd and Clarence St	CLSTE122	W	n/a	n/a	n/a	n/a	n/a
Acton Park, 222 Acton Drive/PRV Shed Sample Tap	CLSTE289	W	n/a	n/a	n/a	n/a	n/a
Risdon, 26 Saundersons Rd/Sample tap	CLSTE291	W	n/a	n/a	n/a	n/a	n/a
9 Geilston Creek Rd	CLSTE304	W	Q	Q	n/a	Q	n/a
Warrane Sports Centre crn Dampier & Blight St	CLSTE303	W	n/a	n/a	n/a	n/a	n/a
984 Oceana Drive	CLSTE320	W	n/a	n/a	n/a	n/a	n/a
718 Oceana Drive	CLSTE321	W	n/a	n/a	n/a	n/a	n/a
11 Ralph Terrace	CLSTE159	W	n/a	n/a	n/a	n/a	n/a
Matipo St Risdon Vale PS	CLSTE315	W	n/a	n/a	n/a	n/a	n/a
Matipo Street/Matipo Rd Pump Station Top Side	CLSTE319	W	n/a	n/a	n/a	n/a	n/a
118 Tara Drive	CLSTE316	W	n/a	n/a	n/a	n/a	n/a
Belbins Rd, just off Cambridge Rd	SOSTE06	W	n/a	n/a	n/a	n/a	n/a
Risdon Vale RES	SRSTE01	W	n/a	n/a	n/a	n/a	n/a
Acton Park, 111 Cahill Pl	CLSTE157	W	n/a	n/a	n/a	n/a	n/a
Number Planned Samples	1260	12	12	0	12	n/a	
Number Samples Tested	1260	12	12	0	12	n/a	

Table 23.2-c Sampling program – Coal Valley

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Richmond/31 Torrens St	RISTE320	W	Q	Q	n/a	Q	n/a
Campania/Tennis Court	CASTE82	W	Q	Q	n/a	Q	n/a
Colebrook/14 Richmond Street (650073)	COSTE81	W	Q	Q	n/a	Q	n/a
Colebrook/509 Yarlington Rd	COSTE82	W	n/a	n/a	n/a	n/a	n/a
Number Planned Samples	208	12	12	0	12	n/a	
Number Samples Tested	208	12	12	0	12	n/a	

Table 23.2-d Sampling program – Glenorchy

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Glenorchy, 22 Jackson Rd	GOSTE301	W	n/a	n/a	n/a	n/a	n/a
Glenorchy High Level Sample Tap	GOSTE03	W	n/a	n/a	2M	n/a	n/a
St Thereses/Sample Tap	GOSTE10	W	n/a	n/a	n/a	n/a	n/a
Claremont/16 Mahoney Drive	GOSTE144	W	n/a	n/a	n/a	n/a	n/a
Claremont, 5 Box Hill Road	GOSTE112	W	n/a	n/a	n/a	n/a	n/a
Rosetta/7 Marys Hope Road	GOSTE133	W	n/a	n/a	n/a	n/a	n/a
Moonah, 125 Springfield Ave	GOSTE137	W	Q	Q	2M	Q	n/a
Moonah, 50m Pas 98 Amy St	GOSTE136	W	n/a	n/a	n/a	n/a	n/a
Cnr Main and Hestercombe Road	GOSTE140	W	n/a	n/a	n/a	n/a	n/a
Derwent Park, 49 Milton Crescent	GOSTE138	W	n/a	n/a	n/a	n/a	n/a
Lutana/Risdon Rd SPS	GOSTE134	W	n/a	n/a	n/a	n/a	n/a
Chigwell, Boondar St Opp 40 Arunta St	GOSTE135	W	n/a	n/a	n/a	n/a	n/a
Claremont/22 Harbord Rd	GOSTE141	W	Q	Q	n/a	Q	n/a
Claremont - 3 Russell Road	GOSTE139	W	n/a	n/a	n/a	n/a	n/a
Montrose/118 Montrose Rd	GOSTE291	W	n/a	n/a	n/a	n/a	n/a
Chigwell, Res	LFSTE02	W	n/a	n/a	n/a	n/a	n/a
Box Hill/Fenton Res/Glebe Street	LFSTE15	W	n/a	n/a	n/a	n/a	n/a
Pump Station - Fenton Line	LFSTE30	W	n/a	n/a	n/a	n/a	n/a
Claremont/Box Hill Road	WDSTE06	W	n/a	n/a	n/a	n/a	n/a
Number Planned Samples	970	8	8	48	8	n/a	
Number Samples Tested	970	8	8	48	8	n/a	

Table 23.2-e Sampling program – Hobart

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
South Hobart/Opp 132 Forest Rd	HDSTE191	W	n/a	n/a	n/a	n/a	n/a

Lenah Valley/9 Susan Parade	HDSTE208	W	n/a	n/a	n/a	n/a	n/a	n/a
South Hobart/90A Cascade Rd	HDSTE192	W	n/a	n/a	2M	n/a	n/a	n/a
Lenah Valley/PRV Pit, Cnr Girrabong/Mowbray Crt	HDSTE54	W	n/a	n/a	n/a	n/a	n/a	n/a
Fern Tree/1 Menuggana Road	HMSTE27	W	n/a	n/a	2M	n/a	n/a	n/a
Sandy Bay, 8 Lindeith Crt/Sample tap	HDSTE163	W	n/a	n/a	n/a	n/a	n/a	n/a
Hobart/10 Evans St	HDSTE193	W	Q	Q	n/a	Q	n/a	n/a
Mt Nelson/22 Lachlan Dr	HDSTE194	W	n/a	n/a	n/a	n/a	n/a	n/a
328 Churchill Ave	HDSTE186	W	n/a	n/a	n/a	n/a	n/a	n/a
Derwent Sailing Club - Marieville Esp	HDSTE187	W	n/a	n/a	n/a	n/a	n/a	n/a
Taroona/26 Channel Hwy	KBSTE336	W	Q	Q	n/a	Q	n/a	n/a
HCC Mountain Park Depo - 518 Huon Rd	HDSTE203	W	n/a	n/a	n/a	n/a	n/a	n/a
84 Woodcutters Rd	HDSTE206	W	n/a	n/a	n/a	n/a	n/a	n/a
2 Lyndhurst Ave	HDSTE189	W	n/a	n/a	n/a	n/a	n/a	n/a
Queens Walk Flats	HDSTE207	W	n/a	n/a	n/a	n/a	n/a	n/a
263 Lenah Valley Road	HDSTE25	W	n/a	n/a	n/a	n/a	n/a	n/a
Number Planned Samples		833	8	8	48	8	n/a	
Number Samples Tested		833	8	8	48	8	n/a	

Table 23.2-f Sampling program – Kingborough

Planned sampling program (2020–21)

Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Blackmans Bay/23 Wells Parade	KBSTE313	W	n/a	n/a	n/a	n/a	n/a
Kingston High Level/181 Redwood Rd	KBSTE311	W	n/a	n/a	n/a	n/a	n/a
Kingston Gateway Shopping Centre, Channel Hwy	KBSTE318	W	n/a	n/a	n/a	n/a	n/a
St Lukes Church 2 Coolamon Rd	KBSTE304	W	n/a	n/a	n/a	n/a	n/a
128 Albion Heights Drive	KBSTE309	W	n/a	n/a	n/a	n/a	n/a
Kingston Beach/Osborne Esplanade	KBSTE310	W	Q	Q	n/a	Q	n/a
Snug/2361 Channel Highway	KBSTE226	W	n/a	n/a	n/a	n/a	n/a
Margate, Sandfly Rd, Margate Cemetery/Sample tap	KBSTE227	W	n/a	n/a	n/a	n/a	n/a
Kingborough, Scotts Rd/Sample tap	KBSTE228 ¹⁴	W	n/a	n/a	n/a	n/a	n/a
Kingston/Corner Summerleas/Old Summerleas Rd	KBSTE400	W	n/a	n/a	n/a	n/a	n/a

¹⁴ Replaced by KBSTE400 29th March 2021

Electrona/Waterfront – 35 Staff Rd	KBSTE240	W	n/a	n/a	n/a	n/a	n/a
Tarooma – 27 Oakleigh Ave	KBSTE241	W	n/a	n/a	n/a	n/a	n/a
Blackmans Bay/23 Powell Rd	KBSTE314	W	n/a	n/a	n/a	n/a	n/a
Tarooma/Bachelor Way	KBSTE235	W	Q	Q	n/a	Q	n/a
Bonnet Hill/4 Tyndall Road	KBSTE312	W	n/a	n/a	n/a	n/a	n/a
Bayton Street - Patriach Drive PRV Pit	KBSTE315	W	n/a	n/a	n/a	n/a	n/a
Ash Drive - 69 Brightwater Road	KBSTE316	W	n/a	n/a	n/a	n/a	n/a
Mt Pleasant - 51 Summerleas Road	KBSTE317	W	n/a	n/a	n/a	n/a	n/a
Margate Offtake/Margate Esp off Beach Rd	KBSTE319	W	Q	Q	n/a	Q	n/a
Blackmans Bay, 41 Estuary Driver	KBSTE307	W	n/a	n/a	n/a	n/a	n/a
Number Planned Samples	901	12	12	0	12	n/a	
Number Samples Tested	901	12	12	0	12	n/a	

Table 23.2-g Sampling program – National Park

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Uxbridge Rd Airstrip	LFSTE12	W	n/a	n/a	n/a	n/a	n/a
Number Planned Samples	52	0	0	0	0	0	n/a
Number Samples Tested	52	0	0	0	0	0	n/a

Table 23.2-h Sampling program – New Norfolk

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
New Norfolk/29 Alfred St	DVSTE90	W	Q	Q	n/a	Q	n/a
New Norfolk/Hobart Rd & Glebe Rd - 50m Past Intersection	DVSTE94	W	n/a	n/a	n/a	n/a	n/a
New Norfolk Rowing Club - 44 Rocks Rd	DVSTE92	W	n/a	n/a	n/a	n/a	n/a
51 Daniels Rd, Magra	DVSTE95	W	n/a	n/a	n/a	n/a	n/a

crn Goldsmith & Bastian St Lawitta	DVSTE85	W	n/a	n/a	n/a	n/a	n/a
Off Take on Glebe Rd	DVSTE89	W	n/a	n/a	n/a	n/a	n/a
New Norfolk/Dead End of Trbolet Rd	DVSTE93	W	n/a	n/a	n/a	n/a	n/a
Number Planned Samples	364	4	4	0	4	n/a	
Number Samples Tested	364	4	4	0	4	n/a	

Table 23.2-i Sampling program – Sorell

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Sorell/10 Sommerville St	SCITE05	W	Q	Q	n/a	Q	n/a
Sorell/Horizon Drive	SCITE09	W	n/a	n/a	n/a	n/a	n/a
Midway Point/24 Penna Road	SCITE07	W	n/a	n/a	n/a	n/a	n/a
Midway Point/24 Honolulu St	SCITE08	W	n/a	n/a	n/a	n/a	n/a
Number Planned Samples	208	4	4	0	4	n/a	
Number Samples Tested	208	4	4	0	4	n/a	

Table 23.2-j Sampling program – Southern Midlands

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Bagdad, Caltex Fuel stop shop/Sample Post	BDSTE76	W	Q	Q	2M	Q	n/a
Kempton, Caravan Parking Bay/Sample Post on Street	KESTE78	W	n/a	n/a	n/a	n/a	n/a
Mangalore/Park Sample Post	SMSTE75	W	n/a	n/a	n/a	n/a	n/a
Dysart/Crn Ely & Church Lane	SMSTE77	W	n/a	n/a	n/a	n/a	n/a
Number Planned Samples	208	4	4	24	4	n/a	
Number Samples Tested	208	4	4	24	4	n/a	

23.3. Summary of current and historic performance (2016–21)

Table 23.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	99.9%	99.9%	99.9%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	99.9%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

23.4. Analysis of current health performance (2020–21)

Table 23.4-a Summary of health guideline exceedances

Summary of health guideline exceedances				
Parameter Exceeding	Date	Details	Resampled	
Antimony	8/7/2020	Antimony of 0.0050 mg/L in monthly compliance sample		✓

Table 23.4-b Fluoride distribution performance

Distribution fluoride performance	
Indicator	2020–21
F exceeding 1.5 mg/L	0
Average F concentration range (0.8 mg/L – 1.1 mg/L)	0.9
90% of F results are equal to or less than 1.1 mg/L	100%

█ Compliant █ Non-compliant

Table 23.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	72	1	99	<0.0005	<0.0005	0.0050
Arsenic	0.01	mg/L	72	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	72	0	100	0.0056	0.0012	0.0115
Cadmium	0.002	mg/L	72	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	72	0	100	0.0002	<0.0001	0.0005
Copper	2	mg/L	72	0	100	0.0068	<0.0001	0.0270
Lead	0.01	mg/L	72	0	100	0.0004	<0.0001	0.0012
Manganese	0.5	mg/L	72	0	100	0.0020	0.0003	0.0129
Mercury	0.001	mg/L	72	0	100	0.00007	<0.00003	0.00036
Molybdenum	0.05	mg/L	72	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	72	0	100	0.0001	<0.0001	0.0004
Selenium	0.01	mg/L	72	0	100	0.0001	<0.0001	0.0013

Table 23.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	72	0	100	10	2	31
Monochloroacetic acid	150	µg/L	72	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	72	0	100	24	9	84
Total trihalomethanes	250	µg/L	72	0	100	44	14	104

Table 23.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.64	0.00	2.50
Colour True	HU	15	<1	<1	5
pH	Units	6.5 – 8.5	7.25	5.35	9.60
Turbidity	NTU	1	0.44	0.01	22.00

23.5. Analysis of overall system performance (2020–21)

Table 23.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
8/7/2020	Routine quarterly sample taken from BDSTE76 (supply) detected antimony above the health limit. System was flushed, and subsequent sample was clear. Further investigations identified possible contamination of the sample bottle. All affected bottles have been recalled and no further action was taken. This was not counted as an exceedance	✓	✓




Figure 23.5-b Water quality customer complaints by month and type

24. Herrick drinking water system

24.1. System summary (2020–21)

Herrick drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	27
Population serviced	61
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend (\$'000)
No projected capital investment				




Figure 24.1-a Herrick system schematic




Figure 24.1-b Map of Herrick monitoring system

24.2. Summary of annual reticulation compliance (2020–21)

Table 24.2-a Sampling program

Planned compliance sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Herrick/11 Gladstone Road	HRW51W07	W	Q	Q	n/a	Q	n/a
Number Planned Samples		52	4	4	n/a	4	n/a
Number Samples Tested		52	4	4	n/a	4	n/a

24.3. Summary of current and historic performance (2016–21)

Table 24.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	58.3%	66.7%	98.1%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	n/a	n/a	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

24.4. Analysis of current health performance (2020–21)

Table 24.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 24.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	0.0003	<0.0003	0.0005
Barium	2	mg/L	4	0	100	0.0674	0.0487	0.0937
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0039	0.0023	0.0048
Lead	0.01	mg/L	4	0	100	0.0004	0.0003	0.0006
Manganese	0.5	mg/L	4	0	100	0.0024	0.0016	0.0035
Mercury	0.001	mg/L	4	0	100	<0.00003	<0.00003	0.00004
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Nickel	0.02	mg/L	4	0	100	0.0004	0.0001	0.0007
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 24.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	18	12	22
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	57	39	92
Total trihalomethanes	250	µg/L	4	0	100	62	35	92

Table 24.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.39	0.21	0.64
Colour True	HU	15	1.25	1	2
pH	Units	6.5 – 8.5	7.43	6.38	8.05
Turbidity	NTU	1	0.41	0.27	0.66

24.5. Analysis of overall system performance (2020–21)

Table 24.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

25. Huon Valley drinking water system

25.1. System summary (2020–21)

Huon Valley drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	4,339
Population serviced	8,724
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	477	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	12	0
DBPs	100.0%	☒	100.0%	28	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$600,000




Figure 25.1-a Huon Valley system schematic




Figure 25.1-b Map of Huon Valley monitoring system

25.2. Summary of annual reticulation compliance (2020–21)

Table 25.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Cygnet/Football Ground, Bridge Sample Tap	ARSTE35	W	n/a	Q	n/a	n/a	n/a	
South Franklin, Jacksons Rd/Sample Tap	FRSTE45	W	n/a	Q	n/a	n/a	n/a	
Franklin Retic/Opposite No. 1 PS, Sample Tap	HVSTE39	W	n/a	Q	n/a	n/a	n/a	
Huonville Retic/Football Club Entrance, Wilmot Rd, Sample Tap	HVSTE40	W	Q	Q	2M	Q	n/a	
Geeveston/Intersection Bridge, School Rd, Main Rd	HVSTE42	W	Q	Q	2M	Q	n/a	
Geeveston/Fourfoot Rd 1st Bridge	GVSTE38	W	n/a	n/a	n/a	n/a	n/a	
4046 Huon Hwy, Castle Forbes Bay	HVSTE60	W	n/a	n/a	n/a	n/a	n/a	
Nicholls Rivulet, Sample Tap	NRSTE43	W	n/a	Q	n/a	n/a	n/a	
Judbury/19 George Street	JDSTE42	W	Q	Q	n/a	Q	n/a	
Number Planned Samples	477	12	28	48	12	n/a		
Number Samples Tested	477	12	28	48	12	n/a		

25.3. Summary of current and historic performance (2016–21)

Table 25.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	99.7%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

25.4. Analysis of current health performance (2020–21)

Table 25.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 25.4-b Fluoride distribution performance

Distribution fluoride performance	
Indicator	2020–21
F exceeding 1.5 mg/L	0
Average F concentration range (0.8 mg/L – 1.1 mg/L)	0.9
90% of F results are equal to or less than 1.1 mg/L	100%

Compliant Non-compliant

Table 25.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	12	0	100	<0.0005	<0.0005	0.0006
Arsenic	0.01	mg/L	12	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	12	0	100	0.0070	0.0046	0.0120
Cadmium	0.002	mg/L	12	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	12	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	12	0	100	0.0045	0.0020	0.0081
Lead	0.01	mg/L	12	0	100	0.0002	<0.0001	0.0004
Manganese	0.5	mg/L	12	0	100	0.0013	0.0002	0.0047
Mercury	0.001	mg/L	12	0	100	0.00009	<0.00003	0.00033
Molybdenum	0.05	mg/L	12	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	12	0	100	0.0002	0.0001	0.0003
Selenium	0.01	mg/L	12	0	100	<0.0001	<0.0001	<0.0001

Table 25.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	24	0	100	14	3	25
Monochloroacetic acid	150	µg/L	24	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	24	0	100	26	11	55
Total trihalomethanes	250	µg/L	24	0	100	49	29	76

Table 25.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.72	0.03	1.52
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.38	6.23	8.36
Turbidity	NTU	1	0.21	0.05	0.69

25.5. Analysis of overall system performance (2020–21)

Table 25.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

26. King Island drinking water system

26.1. System summary (2020–21)

King Island drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	603
Population serviced	1,046
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	103	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	8	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 26.1-a King Island system schematic



Figure 26.1-b Map of King Island monitoring system

26.2. Summary of annual reticulation compliance (2020–21)

Table 26.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Currie Hospital PRV	241GRSP0020 ¹⁵	W	n/a	n/a	n/a	n/a	n/a	
Depot Site 3	254CUSP0004 ¹⁵	W	Q	Q	2M	Q	n/a	
Ti Tree Drive Site 3	241GRSP0004 ¹⁵	W	Q	Q	2M	Q	n/a	
21 Sassafrass St	241GRSP0003 ¹⁶	W	Q	Q	2M	Q	n/a	
Currie - Cnr Shaw & Hickmott St	241GRSP0030 ¹⁶	W	Q	Q	2M	Q	n/a	
Number Planned Samples	103	8	8	48	8	n/a		
Number Samples Tested	103	8	8	48	8	n/a		

26.3. Summary of current and historic performance (2016–21)

Table 26.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

¹⁵ Removed 12th July 2020

¹⁶ Testing from 12th July 2020

26.4. Analysis of current health performance (2020–21)

Table 26.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 26.4-b Fluoride distribution performance

Distribution fluoride performance	
Indicator	2020–21
F exceeding 1.5 mg/L	0
Average F concentration range (0.8 mg/L – 1.1 mg/L)	0.8
90% of F results are equal to or less than 1.1 mg/L	100%

█ Compliant █ Non-compliant

Table 26.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	0.0003	<0.0003	0.0004
Barium	2	mg/L	8	0	100	0.0033	0.0026	0.0043
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	0.0001	<0.0001	0.0003
Copper	2	mg/L	8	0	100	0.0111	0.0023	0.0246
Lead	0.01	mg/L	8	0	100	0.0008	0.0003	0.0017
Manganese	0.5	mg/L	8	0	100	0.0003	<0.0001	0.0007
Mercury	0.001	mg/L	8	0	100	0.00007	<0.00003	0.00018
Molybdenum	0.05	mg/L	8	0	100	0.0038	0.0010	0.0080
Nickel	0.02	mg/L	8	0	100	0.0004	0.0003	0.0006
Selenium	0.01	mg/L	8	0	100	<0.0001	<0.0001	<0.0001

Table 26.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100	11	4	24
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	8	0	100	11	2	28
Total trihalomethanes	250	µg/L	8	0	100	105	76	171

Table 26.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.79	0.51	1.50
Colour True	HU	15	<1	<1	2
pH	Units	6.5 – 8.5	7.22	6.90	7.98
Turbidity	NTU	1	0.21	0.08	1.34

26.5. Analysis of overall system performance (2020–21)

Table 26.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

27. Lady Barron drinking water system

27.1. System summary (2020–21)

Lady Barron drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	112
Population serviced	157
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 27.1-a Lady Barron system schematic




Figure 27.1-b Map of Lady Barron monitoring system

27.2. Summary of annual reticulation compliance (2020–21)

Table 27.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Lady Baron/Police Station	LBW51W01	W	Q	Q	n/a	Q	n/a
Number Planned Samples		52	4	4	n/a	4	n/a
Number Samples Tested		52	4	4	n/a	4	n/a

27.3. Summary of current and historic performance (2016–21)

Table 27.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	n/a	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

27.4. Analysis of current health performance (2020–21)

Table 27.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 27.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	0.0003
Barium	2	mg/L	4	0	100	0.0401	0.0332	0.0540
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0002	<0.0001	0.0004
Copper	2	mg/L	4	0	100	0.0036	0.0022	0.0064
Lead	0.01	mg/L	4	0	100	0.0004	0.0002	0.0006
Manganese	0.5	mg/L	4	0	100	0.0018	0.0006	0.0027
Mercury	0.001	mg/L	4	0	100	0.00005	<0.00003	0.00010
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Nickel	0.02	mg/L	4	0	100	0.0004	0.0003	0.0005
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 27.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	2	<1	3
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	<1	<1	<1
Total trihalomethanes	250	µg/L	4	0	100	126	65	203

Table 27.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.88	0.50	1.42
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.56	7.15	8.30
Turbidity	NTU	1	0.42	0.11	1.59

27.5. Analysis of overall system performance (2020–21)

Table 27.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

28. Lake Barrington drinking water system

28.1. System summary (2020–21)

Lake Barrington drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	1,228
Population serviced	2,482
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	106	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	8	0

☒ Compliant ✗ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 28.1-a Lake Barrington system schematic




Figure 28.1-b Map of Lake Barrington monitoring system

28.2. Summary of annual reticulation compliance (2020–21)

Table 28.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Barrington/ 15 Esplanade Avenue - Railton	BARST01	W	Q	Q	2M	Q	n/a	
Barrington/7 Roland Crt - Sheffield	BARST02	W	Q	Q	2M	Q	n/a	
Number Planned Samples	106	8	8	48	8	n/a		
Number Samples Tested	106	8	8	48	8	n/a		

28.3. Summary of current and historic performance (2016–21)

Table 28.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

28.4. Analysis of current health performance (2020–21)

Table 28.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 28.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.8
90% of F results are equal to or less than 1.1 mg/L		100%

 Compliant  Non-compliant

Table 28.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	8	0	100	0.0070	0.0059	0.0081
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	0.0002	0.0001	0.0004
Copper	2	mg/L	8	0	100	0.0023	0.0009	0.0056
Lead	0.01	mg/L	8	0	100	0.0006	0.0004	0.0011
Manganese	0.5	mg/L	8	0	100	0.0011	0.0004	0.0048
Mercury	0.001	mg/L	8	0	100	0.00011	<0.00003	0.00031
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	8	0	100	0.0001	<0.0001	0.0002
Selenium	0.01	mg/L	8	0	100	0.0001	<0.0001	0.0003

Table 28.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100	9	2	15
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	8	0	100	28	21	41
Total trihalomethanes	250	µg/L	8	0	100	44	32	65

Table 28.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.64	0.00	1.26
Colour True	HU	15	<1	<1	2
pH	Units	6.5 – 8.5	7.90	6.91	9.18
Turbidity	NTU	1	0.21	0.08	1.76

28.5. Analysis of overall system performance (2020–21)

Table 28.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

29. Leven River drinking water system

29.1. System summary (2020–21)

Leven River drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	2,248
Population serviced	4,609
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	102	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	99.0%	☒	100.0%	8	1
DBPs	100.0%	☒	100.0%	8	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	1	Mercury exceedance
Public health warnings issued	0	
Notifications made to DoH	1	Low fluoride levels detected, mercury exceedance
Customer complaints	1	Other

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
Fluoride Upgrade	Replacement of FSA Tank	Complete	2020/2021	\$200,000




Figure 29.1-a Leven River system schematic




Figure 29.1-b Map of Leven River monitoring system

29.2. Summary of annual reticulation compliance (2020–21)

Table 29.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Whitehills/Penguin - 313 Preservation Drive	054PGSP0005	W	Q	Q	2M	Q	n/a	
Whitehills/Patrick St Clinic Sample Point	054PGSP0003	W	Q	Q	2M	Q	n/a	
Number Planned Samples		102	8	8	48	8	n/a	
Number Samples Tested		102	8	8	48	8	n/a	

29.3. Summary of current and historic performance (2016–21)

Table 29.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	99.5%	100.0%	100.0%	100.0%	99.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

29.4. Analysis of current health performance (2020–21)

Table 29.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
Mercury	1/10/2020	Mercury of 0.00212 mg/L in monthly compliance sample	✓

Table 29.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.5
90% of F results are equal to or less than 1.1 mg/L		100%

 Compliant  Non-compliant

Table 29.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	8	0	100	0.0133	0.0114	0.0157
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	0.0003	0.0002	0.0004
Copper	2	mg/L	8	0	100	0.0059	0.0029	0.0113
Lead	0.01	mg/L	8	0	100	0.0002	<0.0001	0.0005
Manganese	0.5	mg/L	8	0	100	0.0022	0.0005	0.0048
Mercury	0.001	mg/L	8	0	100	0.00036	<0.00003	0.00212
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	8	0	100	0.0003	<0.0001	0.0004
Selenium	0.01	mg/L	8	0	100	<0.0001	<0.0001	<0.0001

Table 29.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100	13	2	21
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	8	0	100	24	10	43
Total trihalomethanes	250	µg/L	8	0	100	45	25	74

Table 29.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.97	0.02	1.95
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.49	6.74	9.03
Turbidity	NTU	1	0.39	0.00	1.89

29.5. Analysis of overall system performance (2020–21)

Table 29.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
July 2020 – October 2020 December 2020 – June 2021	Low fluoride levels detected	✓	✓
1/10/2020	Routine quarterly sample taken from 054PGSP0003 detected mercury above the health limit. System was flushed and subsequent sample was clear. Further investigations identified a possible contamination of the sample bottle. All affected bottles have been recalled and no further action was taken. This was not counted as an exceedance	✓	✓




Figure 29.5-b Water quality customer complaints by month and type

30. Longford drinking water system

30.1. System summary (2020–21)

Longford drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	4,643
Population serviced	9,793
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	208	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	8	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	1	Low fluoride levels detected
Customer complaints	7	Discolouration

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend (\$'000)
WTP Upgrade	UV Installation	Planning	2022/2023	\$600,000
Fluoride Upgrade	Replacement of Day and Bulk Tanks	Complete	2020/2021	TBD
Fluoride Upgrade	Compliance Upgrade	In Progress	2021/2022	TBD




Figure 30.1-a Longford system schematic




Figure 30.1-b Map of Longford monitoring system

30.2. Summary of annual reticulation compliance (2020–21)

Table 30.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Longford/Cressy Public Toilets	CSW51W01 ¹⁷	W	Q	Q	2M	Q	n/a	
Longford/Williams Street SPS Cressy	CSW51W02	W	Q	Q	2M	Q	n/a	
Longford/Evandale History Centre, High St	EDW51W01 ¹⁸	W	Q	Q	n/a	Q	n/a	
910 & 876 White Hills Rd - Evandale	LONGST03	W	Q	Q	n/a	Q	n/a	
Longford/Lyttleton St Toilets	LOW51W01 ¹⁹	W	n/a	n/a	n/a	n/a	n/a	
Longford/50-54 Lewis Street	LONGST02	W	n/a	n/a	n/a	n/a	n/a	
Longford/Perth, Little Mulgrave St	LOW52W01 ²⁰	W	n/a	n/a	2M	n/a	n/a	
Longford/119 Fairtlough St	LONGST04	W	n/a	n/a	2M	n/a	n/a	
Number Planned Samples	208	8	8	48	8	n/a	n/a	
Number Samples Tested	208	8	8	48	8	n/a	n/a	

30.3. Summary of current and historic performance (2016–21)

Table 30.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	99.5%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

¹⁷ Replaced by CSW51W02 1st November 2020

¹⁸ Replaced by LONGST03 1st March 2021

¹⁹ Replaced by LONGST02 1st November 2020

²⁰ Replaced by LONGST04 1st November 2020

30.4. Analysis of current health performance (2020–21)

Table 30.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 30.4-b Fluoride distribution performance

Distribution fluoride performance	
Indicator	2020–21
F exceeding 1.5 mg/L	0
Average F concentration range (0.8 mg/L – 1.1 mg/L)	0.5
90% of F results are equal to or less than 1.1 mg/L	100%

Compliant Non-compliant

Table 30.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	8	0	100	0.0095	0.0059	0.0139
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	0.0003
Chromium	0.05	mg/L	8	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	8	0	100	0.0075	0.0037	0.0142
Lead	0.01	mg/L	8	0	100	0.0008	0.0002	0.0015
Manganese	0.5	mg/L	8	0	100	0.0158	0.0011	0.1010
Mercury	0.001	mg/L	8	0	100	0.00004	<0.00003	0.00008
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	0.0001
Nickel	0.02	mg/L	8	0	100	0.0003	<0.0001	0.0010
Selenium	0.01	mg/L	8	0	100	0.0001	<0.0001	0.0004

Table 30.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100	6	<1	16
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	8	0	100	8	<1	20
Total trihalomethanes	250	µg/L	8	0	100	37	12	90

Table 30.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.66	0.00	1.53
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.20	6.35	7.76
Turbidity	NTU	1	0.49	0.07	20.90

30.5. Analysis of overall system performance (2020–21)

Table 30.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
July 2020 – October 2020 December 2020 – March 2021 May 2021 – June 2021	Low fluoride levels detected	✓	✓




Figure 30.5-b Water quality customer complaints by month and type

31. Manuka River drinking water system

31.1. System summary (2020–21)

Manuka River drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	593
Population serviced	815
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	8	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$1,000,000




Figure 31.1-a Manuka River system schematic




Figure 31.1-b Map of Manuka River monitoring system

31.2. Summary of annual reticulation compliance (2020–21)

Table 31.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Strahan/Harvey St Sample Point	204SNSP0003	W	Q	Q	2M	Q	n/a	
Strahan/Lot 1 Lowana Rd (WWTP Entrance)	204SNSP0008	W	Q	Q	2M	n/a	n/a	
Number Planned Samples		104	8	8	48	4	n/a	
Number Samples Tested		104	8	8	48	4	n/a	

31.3. Summary of current and historic performance (2016–21)

Table 31.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	99.6%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

31.4. Analysis of current health performance (2020–21)

Table 31.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 31.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.8
90% of F results are equal to or less than 1.1 mg/L		100%
█ Compliant	█ Non-compliant	

Table 31.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	8	0	100	0.0059	0.0054	0.0063
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	<0.0001	<0.0001	0.0002
Copper	2	mg/L	8	0	100	0.0068	0.0051	0.0091
Lead	0.01	mg/L	8	0	100	0.0004	0.0003	0.0004
Manganese	0.5	mg/L	8	0	100	0.0018	0.0006	0.0025
Mercury	0.001	mg/L	8	0	100	0.00008	<0.00003	0.00015
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	8	0	100	0.0011	0.0010	0.0012
Selenium	0.01	mg/L	8	0	100	0.0002	<0.0001	0.0010

Table 31.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100	8	5	13
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	8	0	100	27	15	45
Total trihalomethanes	250	µg/L	8	0	100	71	52	94

Table 31.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.45	0.20	0.76
Colour True	HU	15	1.5	<1	3
pH	Units	6.5 – 8.5	7.58	7.08	7.86
Turbidity	NTU	1	0.13	0.05	0.36

31.5. Analysis of overall system performance (2020–21)

Table 31.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

32. Mathinna drinking water system

32.1. System summary (2020–21)

Mathinna drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	82
Population serviced	132
Fluoride	n/a

Performance overview against health targets (2020–21)						
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances	
Microbiological	100.0%	☒	98.0%	52	0	
Fluoride	n/a	n/a	n/a	n/a	n/a	
Metals	100.0%	☒	100.0%	4	0	
DBPs	100.0%	☒	100.0%	4	0	

Overall system performance (2020–21)

Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment

Project	Overview	Progress	Est. Delivery	Est. Spend (\$'000)
No projected capital investment				




Figure 32.1-a Mathinna system schematic




Figure 32.1-b Map of Mathinna monitoring system

32.2. Summary of annual reticulation compliance (2020–21)

Table 32.2-a Sampling program

Planned compliance sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Mathinna/Rec Ground Recreation Ground	MAW51W01	W	Q	Q	n/a	Q	n/a
Number Planned Samples		52	4	4	n/a	4	n/a
Number Samples Tested		52	4	4	n/a	4	n/a

32.3. Summary of current and historic performance (2016–21)

Table 32.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	16.7%	66.7%	98.1%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	n/a	n/a	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

32.4. Analysis of current health performance (2020–21)

Table 32.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 32.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0129	0.0066	0.0223
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0051	0.0037	0.0078
Lead	0.01	mg/L	4	0	100	0.0002	0.0001	0.0003
Manganese	0.5	mg/L	4	0	100	0.0011	0.0008	0.0013
Mercury	0.001	mg/L	4	0	100	0.00013	<0.00003	0.00044
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0003	<0.0001	0.0007
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	0.0002

Table 32.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	42	26	61
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	4
Trichloroacetic acid	100	µg/L	4	0	100	72	47	100
Total trihalomethanes	250	µg/L	4	0	100	74	46	90

Table 32.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.70	0.28	1.08
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.30	6.35	7.91
Turbidity	NTU	1	0.32	0.14	0.65

32.5. Analysis of overall system performance (2020–21)

Table 32.5-a Summary of system issues/public health warnings

Summary of system issues		Date	Description	DHHS notification required	DHHS notification complete
No system issues or public health warnings issued					

33. Maydena drinking water system

33.1. System summary (2020–21)

Maydena drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	141
Population serviced	218
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 33.1-a Maydena system schematic




Figure 33.1-b Map of Maydena monitoring system

33.2. Summary of annual reticulation compliance (2020–21)

Table 33.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Maydena/12 Mayne St	MASTE59	W	Q	Q	n/a	Q	n/a	
Number Planned Samples		52	4	4	n/a	4	n/a	
Number Samples Tested		52	4	4	n/a	4	n/a	

33.3. Summary of current and historic performance (2016–21)

Table 33.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

33.4. Analysis of current health performance (2020–21)

Table 33.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 33.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0021	0.0018	0.0023
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0010	0.0007	0.0013
Copper	2	mg/L	4	0	100	0.0015	0.0010	0.0021
Lead	0.01	mg/L	4	0	100	0.0002	<0.0001	0.0003
Manganese	0.5	mg/L	4	0	100	0.0002	<0.0001	0.0005
Mercury	0.001	mg/L	4	0	100	0.00007	<0.00003	0.00012
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 33.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	20	9	26
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	34	13	44
Total trihalomethanes	250	µg/L	4	0	100	43	28	52

Table 33.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.76	0.46	1.07
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.46	7.02	7.76
Turbidity	NTU	1	0.24	0.06	0.70

33.5. Analysis of overall system performance (2020–21)

Table 33.5-a Summary of system issues/public health warnings

Summary of system issues		Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued					

34. Mole Creek drinking water system

34.1. System summary (2020–21)

Mole Creek drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	202
Population serviced	391
Fluoride	n/a

Performance overview against health targets (2020–21)						
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances	
Microbiological	100.0%	☒	98.0%	53	0	
Fluoride	n/a	n/a	n/a	n/a	n/a	
Metals	100.0%	☒	100.0%	4	0	
DBPs	100.0%	☒	100.0%	4	0	

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 34.1-a Mole Creek system schematic




Figure 34.1-b Map of Mole Creek monitoring system

34.2. Summary of annual reticulation compliance (2020–21)

Table 34.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Mole Creek/Pioneer Drive (650094)	MCW51W01	W	Q	Q	n/a	Q	n/a	
Number Planned Samples		53	4	4	n/a	8	n/a	
Number Samples Tested		53	4	4	n/a	8	n/a	

34.3. Summary of current and historic performance (2016–21)

Table 34.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	50.0%	99.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	n/a	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

34.4. Analysis of current health performance (2020–21)

Table 34.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 34.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0038	0.0026	0.0047
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0002	<0.0001	0.0003
Copper	2	mg/L	4	0	100	0.0007	0.0006	0.0009
Lead	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Manganese	0.5	mg/L	4	0	100	0.0003	0.0001	0.0006
Mercury	0.001	mg/L	4	0	100	0.00008	<0.00003	0.00016
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Selenium	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0002

Table 34.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	2	<1	6
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	2	<1	5
Total trihalomethanes	250	µg/L	4	0	100	7	4	14

Table 34.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.71	0.22	0.97
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.58	7.00	8.56
Turbidity	NTU	1	0.29	0.09	0.98

34.5. Analysis of overall system performance (2020–21)

Table 34.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

35. National Park drinking water system

35.1. System summary (2020–21)

National Park drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	23
Population serviced	32
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 35.1-a National Park system schematic




Figure 35.1-b Map of National Park monitoring system

35.2. Summary of annual reticulation compliance (2020–21)

Table 35.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
National Park/crn Weir Rd and Gordon River Rd	DVSTE60	W	Q	Q	n/a	Q	n/a
Number Planned Samples		52	4	4	n/a	4	n/a
Number Samples Tested		52	4	4	n/a	4	n/a

35.3. Summary of current and historic performance (2016–21)

Table 35.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	n/a	n/a	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	n/a	n/a	100.0%	100.0%	100.0%
Disinfection by products	n/a	n/a	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

35.4. Analysis of current health performance (2020–21)

Table 35.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 35.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	0.0003	<0.0003	0.0004
Barium	2	mg/L	4	0	100	0.0025	0.0019	0.0033
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0002	0.0001	0.0003
Copper	2	mg/L	4	0	100	0.0066	0.0044	0.0103
Lead	0.01	mg/L	4	0	100	0.0006	0.0004	0.0007
Manganese	0.5	mg/L	4	0	100	0.0009	0.0007	0.0013
Mercury	0.001	mg/L	4	0	100	0.00006	<0.00003	0.00012
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0002	0.0001	0.0004
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 35.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	31	22	40
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	56	39	74
Total trihalomethanes	250	µg/L	4	0	100	50	47	61

Table 35.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.86	0.46	1.42
Colour True	HU	15	1.25	1	2
pH	Units	6.5 – 8.5	7.25	6.90	7.56
Turbidity	NTU	1	0.25	0.10	0.58

35.5. Analysis of overall system performance (2020–21)

Table 35.5-a Summary of system issues/public health warnings

Summary of system issues		DoH notification required	DoH notification complete
Date	Description		
No system issues or public health alerts issued			

36. North Esk drinking water system

36.1. System summary (2020–21)

North Esk drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	15,094
Population serviced	31,978
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	699	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	1	Discolouration

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
Fluoride Upgrade	Tank Replacement	Complete	2020/2021	TBD
WTP Upgrade	UV Installation	In Progress	2022/2023	TBD




Figure 36.1-a North Esk system schematic




Figure 36.1-b Map of North Esk monitoring system

36.2. Summary of annual reticulation compliance (2020–21)

Table 36.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Youngtown, Poplar Parade	LRW51W01 ²¹	W	n/a	n/a	2M	n/a	n/a	
4 Dorset Place - Kings Meadows	NEST07	W	n/a	n/a	2M	n/a	n/a	
Norwood, Charlton Park	LRW51W20	W	n/a	n/a	n/a	n/a	n/a	
Norwood, Leith St	LRW51W04	W	n/a	n/a	n/a	n/a	n/a	
Ravenswood, Primary School	LRW51W21 ²²	W	n/a	n/a	n/a	n/a	n/a	
49 Wildor Cres	NEST05	W	n/a	n/a	n/a	n/a	n/a	
Newnham, Franmareae St	LRW51W02	W	n/a	n/a	n/a	n/a	n/a	
Rocherlea, TasWater Depot	LRW51W05	W	n/a	n/a	n/a	n/a	n/a	
Dilston Hall	NEW53W01 ²³	W	n/a	n/a	n/a	n/a	n/a	
1 Dilston Road	NEST06	W	n/a	n/a	n/a	n/a	n/a	
Windermere, Church	WIW51W01	W	n/a	n/a	n/a	n/a	n/a	
Hillwood, Jetty	HWW51W01	W	n/a	n/a	n/a	n/a	n/a	
Lilydale, 1972 Lilydale Rd (Public Toilets)	LRR57W01 ²⁴	W	n/a	n/a	n/a	n/a	n/a	
2 Doaks Rd	NEST10	W	n/a	n/a	n/a	n/a	n/a	
George Town, Information Centre	GTW51W01 ²⁵	W	Q	Q	2M	Q	n/a	
Opposite 42 Davies Street	NEST01	W	Q	Q	2M	Q	n/a	
Low Head Park Toilet	LHDSTW19 ²⁶	W	n/a	n/a	n/a	n/a	n/a	
372 Low Head Road	NEST02	W	n/a	n/a	n/a	n/a	n/a	
Bell Bay Interconnector	NER51W02	W	n/a	n/a	n/a	n/a	n/a	
Miller Court Res and Booster P/Stn	NEST11 ²⁷	W	n/a	n/a	n/a	n/a	n/a	
Bethune Place side fence of 71 Alanvale Road	NEST12 ²⁷	W	n/a	n/a	n/a	n/a	n/a	
444 Los Angelos Road	NEST13 ²⁷	W	n/a	n/a	n/a	n/a	n/a	
Number Planned Samples		699	4	4	48	4	n/a	
Number Samples Tested		699	4	4	48	4	n/a	

²¹ Replaced by NEST07 31st May 2021

²² Replaced by NEST05 1st November 2020

²³ Replaced by NEST06 1st November 2020

²⁴ Replaced by NEST10 1st November 2020

²⁵ Replaced by NEST01 24th March 2021

²⁶ Replaced by NEST02 1st November 2020

²⁷ New installation from 31st May 2021. Zone was not being sampled.

36.3. Summary of current and historic performance (2016–21)

Table 36.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

36.4. Analysis of current health performance (2020–21)

Table 36.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 36.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.9
90% of F results are equal to or less than 1.1 mg/L		100%

█ Compliant █ Non-compliant

Table 36.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0080	0.0066	0.0087
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0002	0.0001	0.0003
Copper	2	mg/L	4	0	100	0.0063	0.0039	0.0090
Lead	0.01	mg/L	4	0	100	0.0002	0.0001	0.0005
Manganese	0.5	mg/L	4	0	100	0.0016	0.0002	0.0055
Mercury	0.001	mg/L	4	0	100	0.00007	<0.00003	0.00014
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0001	<0.0001	0.0002
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 36.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	4	3	7
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	12	6	18
Total trihalomethanes	250	µg/L	4	0	100	29	17	39

Table 36.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.51	0.01	1.09
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.26	6.14	9.05
Turbidity	NTU	1	0.36	0.00	1.82

36.5. Analysis of overall system performance (2020–21)

Table 36.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 36.5-b Water quality customer complaints by month and type

37. Oatlands drinking water system

37.1. System summary (2020–21)

Oatlands drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	493
Population serviced	873
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	WTP Upgrade	Planning	2024/2025	TBD




Figure 37.1-a Oatlands system schematic




Figure 37.1-b Map of Oatlands monitoring system

37.2. Summary of annual reticulation compliance (2020–21)

Table 37.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Oatlands/Wellington St, Sample Post	OASTE79	W	Q	Q	2M	Q	n/a	
Oatlands/Lake SPS	OASTE85	n/a	n/a	n/a	2M	n/a	n/a	
Number Planned Samples		52	4	4	48	4	n/a	
Number Samples Tested		52	4	4	48	4	n/a	

37.3. Summary of current and historic performance (2016–21)

Table 37.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

37.4. Analysis of current health performance (2020–21)

Table 37.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 37.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.2 mg/L)		1.0
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant	 Non-compliant	

Table 37.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0059	0.0046	0.0072
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Copper	2	mg/L	4	0	100	0.0041	0.0030	0.0049
Lead	0.01	mg/L	4	0	100	0.0003	0.0002	0.0005
Manganese	0.5	mg/L	4	0	100	0.0013	0.0001	0.0039
Mercury	0.001	mg/L	4	0	100	0.00007	<0.00003	0.00022
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0003	0.0002	0.0004
Selenium	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0003

Table 37.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	23	19	30
Monochloroacetic acid	150	µg/L	4	0	100	4	<3	6
Trichloroacetic acid	100	µg/L	4	0	100	35	28	42
Total trihalomethanes	250	µg/L	4	0	100	57	46	73

Table 37.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.58	0.11	1.08
Colour True	HU	15	1	<1	2
pH	Units	6.5 – 8.5	7.12	6.53	7.61
Turbidity	NTU	1	0.38	0.10	0.94

37.5. Analysis of overall system performance (2020–21)

Table 37.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

38. Orford drinking water system

38.1. System summary (2020–21)

Orford drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	1,187
Population serviced	857
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)						
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances	
Microbiological	100.0%	☒	98.0%	104	0	
Fluoride	100.0%	☒	100.0%	48	0	
Metals	100.0%	☒	100.0%	4	0	
DBPs	100.0%	☒	100.0%	4	0	

Overall system performance (2020–21)

Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment

Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$1,000,000




Figure 38.1-a Orford system schematic




Figure 38.1-b Map of Orford monitoring system

38.2. Summary of annual reticulation compliance (2020–21)

Table 38.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Orford/71 Barton Ave	GFSTE95	W	n/a	n/a	2M	n/a	n/a	
Orford/53 East Shelley Rd	GFSTE96	W	Q	Q	2M	Q	n/a	
Number Planned Samples		104	4	4	48	4	n/a	
Number Samples Tested		104	4	4	48	4	n/a	

38.3. Summary of current and historic performance (2016–21)

Table 38.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

38.4. Analysis of current health performance (2020–21)

Table 38.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 38.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.9
90% of F results are equal to or less than 1.1 mg/L		100%
█ Compliant	█ Non-compliant	

Table 38.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0134	0.0109	0.0186
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0237	0.0166	0.0307
Lead	0.01	mg/L	4	0	100	0.0019	0.0014	0.0029
Manganese	0.5	mg/L	4	0	100	0.0010	0.0004	0.0018
Mercury	0.001	mg/L	4	0	100	0.00004	<0.00003	0.00008
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0006	0.0004	0.0009
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	0.0001

Table 38.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	9	6	13
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	28	24	33
Total trihalomethanes	250	µg/L	4	0	100	137	81	214

Table 38.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.17	0.00	1.56
Colour True	HU	15	1.75	1	3
pH	Units	6.5 – 8.5	7.15	6.76	7.44
Turbidity	NTU	1	0.21	0.08	0.59

38.5. Analysis of overall system performance (2020–21)

Table 38.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

39. Ouse and Hamilton drinking water system

39.1. System summary (2020–21)

Ouse and Hamilton drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	282
Population serviced	444
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	8	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 39.1-a Ouse and Hamilton system schematic




Figure 39.1-b Map of Ouse and Hamilton monitoring system

39.2. Summary of annual reticulation compliance (2020–21)

Table 39.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Ouse/Public Toilets, Sample Tap	OUSTE102	W	Q	Q	n/a	Q	n/a	
Hamilton/Park, Sample Tap	HASTE104	W	Q	Q	n/a	Q	n/a	
Number Planned Samples		104	8	8	n/a	8	n/a	
Number Samples Tested		104	8	8	n/a	8	n/a	

39.3. Summary of current and historic performance (2016–21)

Table 39.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

39.4. Analysis of current health performance (2020–21)

Table 39.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 39.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	8	0	100	0.0024	0.0019	0.0027
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	8	0	100	0.0050	0.0036	0.0074
Lead	0.01	mg/L	8	0	100	0.0002	<0.0001	0.0003
Manganese	0.5	mg/L	8	0	100	0.0003	<0.0001	0.0005
Mercury	0.001	mg/L	8	0	100	0.00008	<0.00003	0.00021
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	8	0	100	0.0001	<0.0001	0.0002
Selenium	0.01	mg/L	8	0	100	<0.0001	<0.0001	<0.0001

Table 39.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100	11	5	17
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	8	0	100	13	5	23
Total trihalomethanes	250	µg/L	8	0	100	26	19	32

Table 39.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.68	0.25	1.19
Colour True	HU	15	1.19	<1	2
pH	Units	6.5 – 8.5	6.91	6.36	7.28
Turbidity	NTU	1	0.15	0.06	0.74

39.5. Analysis of overall system performance (2020–21)

Table 39.5-a Summary of system issues/public health warnings

Summary of system issues		Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued					

40. Pet River drinking water system

40.1. System summary (2020–21)

Pet River drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	13,593
Population serviced	26,787
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)						
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances	
Microbiological	100.0%	☒	98.0%	409	0	
Fluoride	100.0%	☒	100.0%	48	0	
Metals	100.0%	☒	100.0%	16	0	
DBPs	100.0%	☒	100.0%	16	0	

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	1	Low fluoride levels detected
Customer complaints	6	Discolouration, taste and odour, other (stained washing)

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	In Progress	2022/2023	TBD
Fluoride Upgrade	Replacement of FSA Tank	Complete	2020/2021	\$400,000




Figure 40.1-a Pet River system schematic




Figure 40.1-b Cam River system schematic




Figure 40.1-c Map of Pet River monitoring system

40.2. Summary of annual reticulation compliance (2020–21)

Table 40.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Burnie/Ridgley Mount Road	043RGSP0003	W	n/a	n/a	2M	n/a	n/a	
Burnie/146 Old Surrey Rd	BURNST06	W	n/a	n/a	n/a	n/a	n/a	
Burnie/Brickport SPS 2 Bridport Rd	BURNST02	W	n/a	n/a	n/a	n/a	n/a	
Burnie/39 Scarfe St	BURNST01	W	Q	Q	2M	Q	n/a	
Burnie/Chasm Cr Sample Point	044BUSP0008	W	Q	Q	n/a	Q	n/a	
Somerset/Murchison Highway Sampling Point	034SSSP0007	W	n/a	n/a	n/a	n/a	n/a	
Somerset/16 Somerset Esplanade	SOMST01	W	Q	Q	n/a	n/a	n/a	
Wynyard/Big Creek Sampling Point	034WYSP0002	W	Q	Q	n/a	Q	n/a	
Number Planned Samples		409	16	16	48	12	n/a	
Number Samples Tested		409	16	16	48	12	n/a	

40.3. Summary of current and historic performance (2016–21)

Table 40.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

 Compliant  Non-compliant

40.4. Analysis of current health performance (2020–21)

Table 40.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 40.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.2 mg/L)		0.7
90% of F results are equal to or less than 1.1 mg/L		100%
█ Compliant █ Non-compliant		

Table 40.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	8	0	100	0.0048	0.0035	0.0061
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	0.0002	<0.0001	0.0003
Copper	2	mg/L	8	0	100	0.0020	0.0005	0.0047
Lead	0.01	mg/L	8	0	100	0.0004	<0.0001	0.0008
Manganese	0.5	mg/L	8	0	100	0.0059	0.0011	0.0231
Mercury	0.001	mg/L	8	0	100	0.00006	<0.00003	0.00015
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	8	0	100	0.0001	<0.0001	0.0004
Selenium	0.01	mg/L	8	0	100	<0.0001	<0.0001	0.0002

Table 40.4-d Disinfection by product performance

Disinfection by products – health regulated parameters									
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.	
Dichloroacetic acid	100	µg/L	8	0	100	7	2	12	
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3	
Trichloroacetic acid	100	µg/L	8	0	100	5	2	9	
Total trihalomethanes	250	µg/L	8	0	100	54	39	79	

Table 40.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.63	0.03	1.80
Colour True	HU	15	<1	<1	2
pH	Units	6.5 – 8.5	7.88	7.15	9.52
Turbidity	NTU	1	0.24	0.09	2.87

40.5. Analysis of overall system performance (2020–21)

Table 40.5-a Summary of system issues/public health warnings

Summary of system issues		Date	Description	DoH notification required	DoH notification complete
March 2021 – May 2021	Low fluoride levels detected			✓	✓




Figure 40.5-b Water quality customer complaints by month and type

41. Queenstown (Conglomerate Creek) drinking water system

41.1. System summary (2020–21)

Queenstown drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	1,513
Population serviced	2,257
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	153	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ■ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	8	Discolouration, other (stained washing, illness)

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$1,000,000




Figure 41.1-a Queenstown system schematic




Figure 41.1-b Map of Queenstown monitoring system

41.2. Summary of annual reticulation compliance (2020–21)

Table 41.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Queenstown/Bachelor St Sample Point	194QTSP0101	W	Q	n/a	2M	n/a	n/a	
Queenstown/Murray St Sample Point	194QTSP0301	W	Q	Q	2M	Q	n/a	
Queenstown/Sticht St Sample Point	194QTSP0401	W	n/a	n/a	n/a	n/a	n/a	
Number Planned Samples	153	8	4	48	4	n/a		
Number Samples Tested	153	8	4	48	4	n/a		

41.3. Summary of current and historic performance (2016–21)

Table 41.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

41.4. Analysis of current health performance (2020–21)

Table 41.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 41.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.9
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant  Non-compliant		

Table 41.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	0.0004	0.0004	0.0005
Barium	2	mg/L	8	0	100	0.0173	0.0151	0.0217
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	<0.0001	<0.0001	0.0001
Copper	2	mg/L	8	0	100	0.0144	0.0099	0.0335
Lead	0.01	mg/L	8	0	100	0.0003	0.0002	0.0004
Manganese	0.5	mg/L	8	0	100	0.0144	0.0021	0.0388
Mercury	0.001	mg/L	8	0	100	0.00007	<0.00003	0.00012
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	8	0	100	0.0003	0.0002	0.0005
Selenium	0.01	mg/L	8	0	100	<0.0001	<0.0001	0.0001

Table 41.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	51	37	70
Monochloroacetic acid	150	µg/L	4	0	100	3	<3	4
Trichloroacetic acid	100	µg/L	4	0	100	61	49	68
Total trihalomethanes	250	µg/L	4	0	100	111	90	139

Table 41.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.53	0.07	1.75
Colour True	HU	15	1.75	1	2
pH	Units	6.5 – 8.5	7.61	7.11	7.95
Turbidity	NTU	1	0.20	0.08	0.88

41.5. Analysis of overall system performance (2020–21)

Table 41.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 41.5-b Water quality customer complaints by month and type

42. Ringarooma System drinking water system

42.1. System summary (2020–21)

Ringarooma System drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	679
Population serviced	1,138
Fluoride	Sodium Fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	260	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	20	0
DBPs	100.0%	☒	100.0%	20	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	1	Lead exceedance in an operational site
Public health warnings issued	0	
Notifications made to DoH	1	Lead exceedance in an operational site
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 42.1-a Ringarooma System schematic




Figure 42.1-b Map of Ringarooma System monitoring system

42.2. Summary of annual reticulation compliance (2020–21)

Table 42.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Ringarooma/Opposite Police Station	RRW51W01	W	Q	Q	n/a	Q	n/a
Legerwood/Carvings	LWW51W02 ²⁸	W	Q	Q	n/a	Q	n/a
Legerwood/PRV - Main Rd	RINGST01	W	Q	Q	n/a	Q	n/a
Branxholm/17 Albert Street	BHW51W08	W	Q	Q	n/a	Q	n/a
Derby/Opp Netball Court	DBW51W03	W	Q	Q	2M	Q	n/a
Winnaleah/School	WNW51W01	W	Q	Q	2M	Q	n/a
Number Planned Samples		260	20	20	48	20	n/a
Number Samples Tested		260	20	20	48	20	n/a

42.3. Summary of current and historic performance (2016–21)

Table 42.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	50.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	n/a	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

²⁸ Replaced by RINGST01 26th April 2021

42.4. Analysis of current health performance (2020–21)

Table 42.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
Lead	6/1/2021	Lead of 0.0021 mg/L in a sample at an operational site	✓

Table 42.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.8
90% of F results are equal to or less than 1.1 mg/L		100%
█ Compliant		
█ Non-compliant		

Table 42.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	20	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	20	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	20	0	100	0.0076	0.0044	0.0255
Cadmium	0.002	mg/L	20	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	20	0	100	<0.0001	<0.0001	0.0003
Copper	2	mg/L	20	0	100	0.0133	0.0048	0.0479
Lead	0.01	mg/L	20	0	100	0.0008	0.0002	0.0028
Manganese	0.5	mg/L	20	0	100	0.0002	<0.0001	0.0005
Mercury	0.001	mg/L	20	0	100	0.00005	<0.00003	0.00016
Molybdenum	0.05	mg/L	20	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	20	0	100	0.0002	<0.0001	0.0008
Selenium	0.01	mg/L	20	0	100	0.0001	<0.0001	0.0004

Table 42.4-d Disinfection by product performance

Disinfection by products – health regulated parameters									
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.	
Dichloroacetic acid	100	µg/L	52	0	100	28	14	46	
Monochloroacetic acid	150	µg/L	52	0	100	<3	<3	<3	
Trichloroacetic acid	100	µg/L	52	0	100	58	22	106 ²⁹	
Total trihalomethanes	250	µg/L	52	0	100	51	25	93	

Table 42.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.83	0.27	1.71
Colour True	HU	15	<1	<1	2
pH	Units	6.5 – 8.5	7.12	6.36	7.74
Turbidity	NTU	1	0.27	0.06	2.93

42.5. Analysis of overall system performance (2020–21)

Table 42.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
6/1/2021	Lead exceedance in operational site.	✓	✓
23/2/2021	Trichloroacetic acid exceedance of 106 µg/L. Does not exceed rounding limit.	✓	✓

²⁹ Maximum result, when rounded, does not exceed limit.

43. Rocky Creek drinking water system

43.1. System summary (2020–21)

Rocky Creek drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	226
Population serviced	506
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)						
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances	
Microbiological	100.0%	☒	98.0%	106	0	
Fluoride	100.0%	☒	100.0%	48	0	
Metals	100.0%	☒	100.0%	4	0	
DBPs	100.0%	☒	100.0%	4	0	

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend (\$'000)
No projected capital investment				




Figure 43.1-a Rocky Creek system schematic




Figure 43.1-b Map of Rocky Creek monitoring system

43.2. Summary of annual reticulation compliance (2020–21)

Table 43.2-a Sampling program

Planned compliance sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Ranelagh Showgrounds/Sample Tap (650023)	RCSTE44	W	Q	Q	2M	Q	n/a	
Ranelagh/Grove Fire Station	RCSTE46	W	n/a	n/a	2M	n/a	n/a	
Number Planned Samples	106	4	4	48	4	n/a	n/a	
Number Samples Tested	106	4	4	48	4	n/a	n/a	

43.3. Summary of current and historic performance (2016–21)

Table 43.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

43.4. Analysis of current health performance (2020–21)

Table 43.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 43.4-b Fluoride distribution performance

Distribution fluoride performance		2020-21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.8
90% of F results are equal to or less than 1.1 mg/L		100%
█ Compliant █ Non-compliant		

Table 43.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0016	0.0013	0.0020
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0003	0.0002	0.0004
Copper	2	mg/L	4	0	100	0.0048	0.0039	0.0069
Lead	0.01	mg/L	4	0	100	0.0002	0.0002	0.0004
Manganese	0.5	mg/L	4	0	100	0.0002	0.0002	0.0003
Mercury	0.001	mg/L	4	0	100	0.00003	<0.00003	0.00004
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 43.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	30	19	39
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	55	29	64
Total trihalomethanes	250	µg/L	4	0	100	64	45	80

Table 43.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.90	0.00	1.36
Colour True	HU	15	1.88	<1	3
pH	Units	6.5 – 8.5	7.21	5.98	7.76
Turbidity	NTU	1	0.20	0.06	0.84

43.5. Analysis of overall system performance (2020–21)

Table 43.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health alerts issued			

44. Rosebery drinking water system

44.1. System summary (2020–21)

Rosebery drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	677
Population serviced	804
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	102	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	8	0

☒ Compliant ☒ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	Reservoir Upgrade	In Progress	2021/2022	\$3,000,000




Figure 44.1-a Rosebery system schematic




Figure 44.1-b Map of Rosebery monitoring system

44.2. Summary of annual reticulation compliance (2020–21)

Table 44.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Rosebery/Murchison Highway Tap Behind Public Toilets	174RBSP0301	W	Q	Q	2M	Q	n/a	
Rosebery/Blackwood St Sample Point	174RBSP0701	W	Q	Q	2M	Q	n/a	
Number Planned Samples	102	8	8	48	8	n/a	n/a	
Number Samples Tested	102	8	8	48	8	n/a	n/a	

44.3. Summary of current and historic performance (2016–21)

Table 44.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	99.9%	99.9% ³⁰	100.0% ³¹	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

44.4. Analysis of current health performance (2020–21)

Table 44.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

³⁰ New WTP to improve ADWG compliance

³¹ Two failed tests

Table 44.4-b Fluoride distribution performance

Distribution fluoride performance		2018-19
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.8
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant	 Non-compliant	

Table 44.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	38	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	38	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	38	0	100	0.0045	0.0038	0.0056
Cadmium	0.002	mg/L	38	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	38	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	38	0	100	0.0090	0.0048	0.0165
Lead	0.01	mg/L	38	0	100	0.0005	0.0002	0.0012
Manganese	0.5	mg/L	38	0	100	0.0003	0.0002	0.0004
Mercury	0.001	mg/L	38	0	99.5	0.00011	<0.00003	0.00047
Molybdenum	0.05	mg/L	38	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	38	0	100	<0.0001	<0.0001	<0.0001
Selenium	0.01	mg/L	38	0	100	<0.0001	<0.0001	<0.0001

Table 44.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100	10	4	14
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	8	0	100	11	2	16
Total trihalomethanes	250	µg/L	8	0	100	31	18	40

Table 44.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.83	0.46	1.18
Colour True	HU	15	1.13	<1	2
pH	Units	6.5 – 8.5	7.38	6.82	7.83
Turbidity	NTU	1	0.14	0.07	0.28

44.5. Analysis of overall system performance (2020–21)

Table 44.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

45. Rossarden drinking water system

45.1. System summary (2020–21)

Rossarden drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	32
Population serviced	36
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	8	0
DBPs	100.0%	☒	100.0%	8	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend (\$'000)
No projected capital investment				




Figure 45.1-a Rossarden system schematic




Figure 45.1-b Map of Rossarden monitoring system

45.2. Summary of annual reticulation compliance (2020–21)

Table 45.2-a Sampling program

Planned compliance sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Rossarden/21-23 Schell Street	RDW51W20	W	Q	Q	n/a	Q	n/a	
Rossarden/14 Walter Street	RDW51W21	W	Q	Q	n/a	Q	n/a	
Number Planned Samples	104	8	8	n/a	8	n/a		
Number Samples Tested	104	8	8	n/a	8	n/a		

45.3. Summary of current and historic performance (2016–21)

Table 45.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	99.4%	100.0% ³²	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	n/a	n/a	100.0%	100.0%	100.0%
Disinfection by products	n/a	n/a	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

45.4. Analysis of current health performance (2020–21)

Table 45.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

³² On boil water removal verification program until 3rd August 2018

Table 45.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	8	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	8	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	8	0	100	0.0014	0.0012	0.0016
Cadmium	0.002	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	8	0	100	0.0002	<0.0001	0.0006
Copper	2	mg/L	8	0	100	0.0054	0.0040	0.0099
Lead	0.01	mg/L	8	0	100	0.0004	0.0002	0.0007
Manganese	0.5	mg/L	8	0	100	0.0011	0.0007	0.0020
Mercury	0.001	mg/L	8	0	100	0.00008	<0.00003	0.00027
Molybdenum	0.05	mg/L	8	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	8	0	100	0.0002	<0.0001	0.0006
Selenium	0.01	mg/L	8	0	100	<0.0001	<0.0001	0.0002

Table 45.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	8	0	100	11	9	13
Monochloroacetic acid	150	µg/L	8	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	8	0	100	15	14	18
Total trihalomethanes	250	µg/L	8	0	100	18	14	26

Table 45.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.68	0.36	1.00
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.47	6.50	7.97
Turbidity	NTU	1	0.26	0.11	0.81

45.5. Analysis of overall system performance (2020–21)

Table 45.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health alerts issued			

46. Scamander drinking water system

46.1. System summary (2020–21)

Scamander drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	530
Population serviced	692
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	53	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	1	Low fluoride levels detected
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 46.1-a Scamander system schematic




Figure 46.1-b Map of Scamander monitoring system

46.2. Summary of annual reticulation compliance (2020–21)

Table 46.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Scamander/River Mouth Carpark – 166 Scamander Ave	SCW51W04	n/a	n/a	n/a	2M	n/a	n/a	
Scamander/56 Scamander Ave	SCW51W02	W	Q	Q	2M	Q	n/a	
Number Planned Samples		53	4	4	48	4	n/a	
Number Samples Tested		53	4	4	48	4	n/a	

46.3. Summary of current and historic performance (2016–21)

Table 46.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

46.4. Analysis of current health performance (2020–21)

Table 46.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 46.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.7
90% of F results are equal to or less than 1.1 mg/L		100%

█ Compliant █ Non-compliant

Table 46.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	0.0004
Barium	2	mg/L	4	0	100	0.0075	0.0066	0.0081
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0030	0.0022	0.0042
Lead	0.01	mg/L	4	0	100	0.0004	0.0003	0.0005
Manganese	0.5	mg/L	4	0	100	0.0012	<0.0001	0.0038
Mercury	0.001	mg/L	4	0	100	0.00006	<0.00003	0.00009
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 46.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	13	10	18
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	6
Trichloroacetic acid	100	µg/L	4	0	100	17	13	21
Total trihalomethanes	250	µg/L	4	0	100	50	40	57

Table 46.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.60	0.01	1.01
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.34	6.63	8.31
Turbidity	NTU	1	0.31	0.06	0.75

46.5. Analysis of overall system performance (2020–21)

Table 46.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
July 2020 – December 2020 May 2021 – June 2021	Low fluoride levels detected	✓	✓

47. Scottsdale drinking water system

47.1. System summary (2020–21)

Scottsdale drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	1,340
Population serviced	2,803
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	2	Other (illness)

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$600,000




Figure 47.1-a Scottsdale system schematic




Figure 47.1-b Map of Scottsdale monitoring system

47.2. Summary of annual reticulation compliance (2020–21)

Table 47.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Scottsdale/Opposite Recreation Ground	SDW51S06	W	Q	Q	2M	Q	n/a	
Scottsdale/King St Opposite Visitor Information Centre	SDW51W07	W	n/a	n/a	2M	n/a	n/a	
Number Planned Samples		104	4	4	48	4	n/a	
Number Samples Tested		104	4	4	48	4	n/a	

47.3. Summary of current and historic performance (2016–21)

Table 47.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

47.4. Analysis of current health performance (2020–21)

Table 47.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 47.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.9
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant	 Non-compliant	

Table 47.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0110	0.0100	0.0122
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Copper	2	mg/L	4	0	100	0.0033	0.0026	0.0040
Lead	0.01	mg/L	4	0	100	0.0002	0.0002	0.0003
Manganese	0.5	mg/L	4	0	100	0.0018	0.0011	0.0025
Mercury	0.001	mg/L	4	0	100	0.00006	<0.00003	0.00010
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Selenium	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0003

Table 47.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	5	3	9
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	4	2	8
Total trihalomethanes	250	µg/L	4	0	100	19	13	26

Table 47.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.92	0.45	1.23
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.16	6.77	7.59
Turbidity	NTU	1	0.36	0.07	5.87

47.5. Analysis of overall system performance (2020–21)

Table 47.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 47.5-b Water quality customer complaints by month and type

48. South Esk drinking water system

48.1. System summary (2020–21)

South Esk drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	5,442
Population serviced	11,766
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	364	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	In Progress	2022/2023	TBD
Fluoride Upgrade	Replacement of Storage Tank	In Progress	2021/2022	TBD




Figure 48.1-a South Esk system schematic




Figure 48.1-b Map of South Esk monitoring system

48.2. Summary of annual reticulation compliance (2020–21)

Table 48.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Blackstone Heights, Longvista Drive	PVW52W01	W	n/a	n/a	n/a	n/a	n/a
Prospect Vale, Country Club	PVW51W02	W	n/a	n/a	n/a	n/a	n/a
Kings Meadows, Connector Park	LRW51W07	W	n/a	n/a	n/a	n/a	n/a
Prospect Vale, Chris St Res	LRR58W01	W	n/a	n/a	n/a	n/a	n/a
Carrick, Public Hall	CAW51W01 ³³	W	n/a	n/a	n/a	n/a	n/a
35 East Street	SEST01	W	n/a	n/a	n/a	n/a	n/a
Prospect Vale, Willow Lane	PVW51W01	W	n/a	n/a	2M	n/a	n/a
Hadspen, South Esk Drive	HSW51W01	W	Q	Q	2M	Q	n/a
Number Planned Samples		364	4	4	48	4	n/a
Number Samples Tested		364	4	4	48	4	n/a

48.3. Summary of current and historic performance (2016–21)

Table 48.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

 Compliant  Non-compliant

³³ Replaced by SEST01 1st November 2020

48.4. Analysis of current health performance (2020–21)

Table 48.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 48.4-b Fluoride distribution performance

Distribution fluoride performance	
Indicator	2020–21
F exceeding 1.5 mg/L	0
Average F concentration range (0.8 mg/L – 1.1 mg/L)	0.9
90% of F results are equal to or less than 1.1 mg/L	100%

Compliant Non-compliant

Table 48.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0098	0.0056	0.0143
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0002	<0.0001	0.0003
Copper	2	mg/L	4	0	100	0.0062	0.0032	0.0130
Lead	0.01	mg/L	4	0	100	0.0012	0.0004	0.0030
Manganese	0.5	mg/L	4	0	100	0.0090	0.0012	0.0306
Mercury	0.001	mg/L	4	0	100	0.00012	<0.00003	0.00031
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Nickel	0.02	mg/L	4	0	100	0.0004	0.0002	0.0008
Selenium	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0003

Table 48.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	10	5	14
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	11	3	18
Total trihalomethanes	250	µg/L	4	0	100	32	15	54

Table 48.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.74	0.10	1.55
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.14	6.17	9.19
Turbidity	NTU	1	0.37	0.10	2.10

48.5. Analysis of overall system performance (2020–21)

Table 48.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

49. St Helens drinking water system

49.1. System summary (2020–21)

St Helens drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	1,908
Population serviced	2,417
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ☒ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$600,000




Figure 49.1-a St Helens system schematic




Figure 49.1-b Map of St Helens monitoring system

49.2. Summary of annual reticulation compliance (2020–21)

Table 49.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
St Helens/Longhill Reservoir	SHR51W01	W	n/a	n/a	2M	n/a	n/a	
St Helens/228 St Helens Point Rd	SHW51W04	W	Q	Q	2M	Q	n/a	
Number Planned Samples		104	4	4	48	4	n/a	
Number Samples Tested		104	4	4	48	4	n/a	

49.3. Summary of current and historic performance (2016–21)

Table 49.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

49.4. Analysis of current health performance (2020–21)

Table 49.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 49.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.8
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant  Non-compliant		

Table 49.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0061	0.0056	0.0065
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Copper	2	mg/L	4	0	100	0.0028	0.0013	0.0039
Lead	0.01	mg/L	4	0	100	0.0007	0.0003	0.0010
Manganese	0.5	mg/L	4	0	100	0.0006	0.0004	0.0009
Mercury	0.001	mg/L	4	0	100	0.00003	<0.00003	0.00004
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Nickel	0.02	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Selenium	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0002

Table 49.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	7	5	9
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	19	11	26
Total trihalomethanes	250	µg/L	4	0	100	50	39	63

Table 49.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.82	0.02	1.51
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.26	6.66	7.78
Turbidity	NTU	1	0.37	0.11	0.97

49.5. Analysis of overall system performance (2020–21)

Table 49.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

50. St Marys drinking water system

50.1. System summary (2020–21)

St Marys drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	367
Population serviced	605
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	WTP Upgrade	Planning	2024/2025	TBD




Figure 50.1-a St Marys system schematic




Figure 50.1-b Map of St Marys monitoring system

50.2. Summary of annual reticulation compliance (2020–21)

Table 50.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
St Marys/Park Near Library	SMW51W02	n/a	n/a	n/a	2M	n/a	n/a
St Marys/St. Marys School	SMW51W01	W	Q	Q	2M	Q	n/a
Number Planned Samples		52	4	4	48	4	n/a
Number Samples Tested		52	4	4	48	4	n/a

50.3. Summary of current and historic performance (2016–21)

Table 50.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

50.4. Analysis of current health performance (2020–21)

Table 50.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 50.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.8
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant	 Non-compliant	

Table 50.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.1481	0.1404	0.1519
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Copper	2	mg/L	4	0	100	0.0138	0.0121	0.0170
Lead	0.01	mg/L	4	0	100	0.0003	0.0002	0.0004
Manganese	0.5	mg/L	4	0	100	0.0056	0.0039	0.0073
Mercury	0.001	mg/L	4	0	100	0.00015	<0.00003	0.00041
Molybdenum	0.05	mg/L	4	0	100	0.0002	0.0002	0.0002
Nickel	0.02	mg/L	4	0	100	0.0002	<0.0001	0.0002
Selenium	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0002

Table 50.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	2	1	2
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	<1	<1	1
Total trihalomethanes	250	µg/L	4	0	100	14	11	16

Table 50.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.67	0.31	1.38
Colour True	HU	15	1.38	<1	4
pH	Units	6.5 – 8.5	7.03	6.55	7.38
Turbidity	NTU	1	0.62	0.34	1.07

50.5. Analysis of overall system performance (2020–21)

Table 50.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

51. Swansea drinking water system

51.1. System summary (2020–21)

Swansea drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	897
Population serviced	1,274
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

 Compliant Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$1,000,000




Figure 51.1-a Swansea system schematic




Figure 51.1-b Map of Swansea monitoring system

51.2. Summary of annual reticulation compliance (2020–21)

Table 51.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Swansea/Bark Mill	GSSTE295	W	n/a	n/a	2M	n/a	n/a	
Swansea/1 Esplanade	GSSTE299	W	Q	Q	2M	Q	n/a	
Number Planned Samples		104	4	4	48	4	n/a	
Number Samples Tested		104	4	4	48	8	n/a	

51.3. Summary of current and historic performance (2016–21)

Table 51.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

51.4. Analysis of current health performance (2020–21)

Table 51.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 51.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.8
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant  Non-compliant		

Table 51.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0037	0.0033	0.0039
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Copper	2	mg/L	4	0	100	0.0179	0.0162	0.2108
Lead	0.01	mg/L	4	0	100	0.0010	0.0009	0.0012
Manganese	0.5	mg/L	4	0	100	0.0002	0.0001	0.0003
Mercury	0.001	mg/L	4	0	100	0.00006	<0.00003	0.00010
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Nickel	0.02	mg/L	4	0	100	0.0002	0.0002	0.0003
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 51.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	7	4	10
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	6	3	8
Total trihalomethanes	250	µg/L	4	0	100	45	40	54

Table 51.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.74	0.20	1.42
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.04	6.84	7.33
Turbidity	NTU	1	0.15	0.07	0.41

51.5. Analysis of overall system performance (2020–21)

Table 51.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

52. Triabunna drinking water system

52.1. System summary (2020–21)

Triabunna drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	548
Population serviced	951
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$1,000,000
WTP Upgrade	Reservoir Upgrade	In Progress	2021/2022	\$3,000,000




Figure 52.1-a Triabunna system schematic




Figure 52.1-b Map of Triabunna monitoring system

52.2. Summary of annual reticulation compliance (2020–21)

Table 52.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Triabunna Ada street	GTSTE201	W	n/a	n/a	2M	n/a	n/a	
Triabunna/Cemetery, Charles St, Sample Tap	GTSTE86	W	Q	Q	2M	Q	n/a	
Number Planned Samples	104	4	4	48	4	n/a	n/a	
Number Samples Tested	104	4	4	48	4	n/a	n/a	

52.3. Summary of current and historic performance (2016–21)

Table 52.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

52.4. Analysis of current health performance (2020–21)

Table 52.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 52.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.9
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant  Non-compliant		

Table 52.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0124	0.0089	0.0186
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0054	0.0035	0.0074
Lead	0.01	mg/L	4	0	100	0.0005	0.0003	0.0008
Manganese	0.5	mg/L	4	0	100	0.0073	0.0020	0.0140
Mercury	0.001	mg/L	4	0	100	0.00023	<0.00003	0.00042
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0004	0.0003	0.0005
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	0.0001

Table 52.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	18	8	27
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	38	16	66
Total trihalomethanes	250	µg/L	4	0	100	120	83	143

Table 52.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.77	0.02	1.91
Colour True	HU	15	1.13	<1	2
pH	Units	6.5 – 8.5	7.17	6.48	7.63
Turbidity	NTU	1	0.22	0.09	0.49

52.5. Analysis of overall system performance (2020–21)

Table 52.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

53. Tullah drinking water system

53.1. System summary (2020–21)

Tullah drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	218
Population serviced	236
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	12	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	WTP Upgrade	Planning	2024/2025	TBD




Figure 53.1-a Tullah system schematic




Figure 53.1-b Map of Tullah monitoring system

53.2. Summary of annual reticulation compliance (2020–21)

Table 53.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Tullah/Bluff St Sample Point 1	184TUSP0101	W	Q	n/a	n/a	Q	n/a	
Tullah/Farrell Sample Point 2	184TUSP0201	W	n/a	M	n/a	n/a	n/a	
Number Planned Samples	104		4	12	n/a	4	n/a	
Number Samples Tested	104		4	12	n/a	4	n/a	

53.3. Summary of current and historic performance (2016–21)

Table 53.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0% ³⁴	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

53.4. Analysis of current health performance (2020–21)

Table 53.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

³⁴ Sampling requirements not met (sample missed in May 2018 for DBPs)

Table 53.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0038	0.0033	0.0045
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Copper	2	mg/L	4	0	100	0.0007	0.0004	0.0013
Lead	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Manganese	0.5	mg/L	4	0	100	0.0068	0.0051	0.0103
Mercury	0.001	mg/L	4	0	100	0.00007	<0.00003	0.00012
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0001	<0.0001	0.0002
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 53.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	12	0	100	10	2	29
Monochloroacetic acid	150	µg/L	12	0	100	<3	<3	3
Trichloroacetic acid	100	µg/L	12	0	100	47	32	68
Total trihalomethanes	250	µg/L	12	0	100	108	81	136

Table 53.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.65	0.00	2.70
Colour True	HU	15	3.25	2	5
pH	Units	6.5 – 8.5	7.79	6.79	8.35
Turbidity	NTU	1	0.34	0.17	0.65

53.5. Analysis of overall system performance (2020–21)

Table 53.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

54. Tunbridge drinking water system

54.1. System summary (2020–21)

Tunbridge drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	118
Population serviced	201
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	1	Lead exceedance in an operational site
Public health warnings issued	0	
Notifications made to DoH	1	Lead exceedance in an operational site
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	Reservoir Upgrade	In Progress	2021/2022	\$3,000,000




Figure 54.1-a Tunbridge system schematic




Figure 54.1-b Map of Tunbridge monitoring system

54.2. Summary of annual reticulation compliance (2020–21)

Table 54.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Tunbridge/Tunbridge St Sample Post	TBSTE80	W	Q	Q	n/a	Q	n/a
Number Planned Samples		52	4	4	n/a	4	n/a
Number Samples Tested		52	4	4	n/a	4	n/a

54.3. Summary of current and historic performance (2016–21)

Table 54.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

54.4. Analysis of current health performance (2020–21)

Table 54.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
Lead	20/08/2020	Lead of 0.0117 mg/L in a sample at an operational site.	✓
Lead	17/03/2021	Lead of 0.0489 mg/L in a sample at an operational site.	✓

Table 54.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0118	0.0066	0.0179
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Copper	2	mg/L	4	0	100	0.0097	0.0057	0.0190
Lead	0.01	mg/L	4	0	100	0.0006	0.0002	0.0014
Manganese	0.5	mg/L	4	0	100	0.0005	0.0001	0.0009
Mercury	0.001	mg/L	4	0	100	0.00011	<0.00003	0.00024
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0002	0.0001	0.0003
Selenium	0.01	mg/L	4	0	100	0.0002	<0.0001	0.0004

Table 54.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	3	<1	4
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	<1	<1	2
Total trihalomethanes	250	µg/L	4	0	100	34	8	55

Table 54.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.64	0.26	1.02
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.39	6.58	7.88
Turbidity	NTU	1	0.27	0.05	0.61

54.5. Analysis of overall system performance (2020–21)

Table 54.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
20/8/2020	Lead exceedance	✓	✓
17/3/2021	Lead exceedance	✓	✓

55. Waratah drinking water system

55.1. System summary (2020–21)

Waratah drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	134
Population serviced	184
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	100.0%	☒	100.0%	24	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	1	Discolouration

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 55.1-a Waratah system schematic




Figure 55.1-b Map of Waratah monitoring system

55.2. Summary of annual reticulation compliance (2020–21)

Table 55.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Waratah/Caravan Park Sample Point	124WTSP0002	W	Q	Q	2M	Q	n/a
Number Planned Samples		52	4	4	24	4	n/a
Number Samples Tested		52	4	4	24	4	n/a

55.3. Summary of current and historic performance (2016–21)

Table 55.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

55.4. Analysis of current health performance (2020–21)

Table 55.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 55.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.9
90% of F results are equal to or less than 1.1 mg/L		100%
█ Compliant █ Non-compliant		

Table 55.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	0.0003
Barium	2	mg/L	4	0	100	0.0020	0.0018	0.0022
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0003	0.0002	0.0004
Copper	2	mg/L	4	0	100	0.0328	0.0230	0.0385
Lead	0.01	mg/L	4	0	100	0.0011	0.0006	0.0015
Manganese	0.5	mg/L	4	0	100	0.0085	0.0005	0.0251
Mercury	0.001	mg/L	4	0	100	0.00005	<0.00003	0.00008
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0002	0.0001	0.0003
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 55.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	29	24	34
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	35	32	40
Total trihalomethanes	250	µg/L	4	0	100	56	44	80

Table 55.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.46	0.05	0.88
Colour True	HU	15	1.75	<1	4
pH	Units	6.5 – 8.5	7.34	6.82	8.11
Turbidity	NTU	1	0.15	0.06	0.57

55.5. Analysis of overall system performance (2020–21)

Table 55.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 55.5-b Water quality customer complaints by month and type

56. Wayatinah drinking water system

56.1. System summary (2020–21)

Wayatinah drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	63
Population serviced	39
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	2	DBP exceedances in sampling program (under rounding limit)
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend (\$'000)
No projected capital investment				




Figure 56.1-a Wayatinah system schematic




Figure 56.1-b Map of Wayatinah monitoring system

56.2. Summary of annual reticulation compliance (2020–21)

Table 56.2-a Sampling program

Planned compliance sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Wayatinah/Crn 3rd Street and Bronte Ave	WYSTE97	W	Q	Q	n/a	Q	n/a	
Number Planned Samples		52	4	4	n/a	4	n/a	
Number Samples Tested		52	4	4	n/a	4	n/a	

56.3. Summary of current and historic performance (2016–21)

Table 56.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	98.1%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	95.8%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

56.4. Analysis of current health performance (2020–21)

Table 56.4-a Summary of health guideline exceedances

Summary of health guideline exceedances				
Parameter Exceeding	Date	Details		Resampled
No ADWG exceedances				

Table 56.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0031	0.0014	0.0056
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0030	0.0020	0.0040
Lead	0.01	mg/L	4	0	100	0.0003	0.0002	0.0005
Manganese	0.5	mg/L	4	0	100	0.0005	0.0004	0.0007
Mercury	0.001	mg/L	4	0	100	0.00005	<0.00003	0.00010
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0001	<0.0001	0.0002
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 56.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	12	0	100	30	3	60
Monochloroacetic acid	150	µg/L	12	0	100	<3	<3	4
Trichloroacetic acid	100	µg/L	12	0	100	75	36	118 ³⁵
Total trihalomethanes	250	µg/L	12	0	100	76	54	98

Table 56.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.40	0.06	0.71
Colour True	HU	15	1.63	<1	2
pH	Units	6.5 – 8.5	7.80	7.40	8.11
Turbidity	NTU	1	0.15	0.07	0.32

³⁵ Maximum result, when rounded, does not exceed limit.

56.5. Analysis of overall system performance (2020–21)

Table 56.5-a Summary of system issues/public health warnings

Summary of system issues/public health warnings			
Date	Description	DoH notification required	DoH notification complete
2/7/2020	Trichloroacetic acid exceedance of 118 µg/L. Does not exceed rounding limit.	✓	✓
19/10/2020	Trichloroacetic acid exceedance of 110 µg/L. Does not exceed rounding limit.	✓	✓

57. West Tamar drinking water system

57.1. System summary (2020–21)

West Tamar drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	9,811
Population serviced	20,974
Fluoride	Fluorosilicic acid

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	573	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
Fluoride Upgrade	Replacement of Storage Tank	In Progress	2021/2022	\$130,000
WTP Upgrade	UV Installation	In Progress	2022/2023	TBD




Figure 57.1-a West Tamar system schematic




Figure 57.1-b Map of West Tamar monitoring system

57.2. Summary of annual reticulation compliance (2020–21)

Table 57.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Exeter, Biloo St	ETW51W01 ³⁶	W	Q	Q	2M	Q	n/a
22 Frankford Road - Exeter	WTST01	W	Q	Q	2M	Q	n/a
Stephensdale, 14 Marlou Crt	WEW55W01	W	n/a	n/a	n/a	n/a	n/a
Riverside, 32 Gray St	WEW55W10 ³⁷	W	n/a	n/a	n/a	n/a	n/a
Cnr Cherry Rd & Glencoe Ave - Trevallyn	WTST06	W	n/a	n/a	n/a	n/a	n/a
29A Cleghorn Ave - Riverside	WEW55W02	W	n/a	n/a	n/a	n/a	n/a
Legana Freshwater Point Rd	WEW54W01 ³⁸	W	n/a	n/a	n/a	n/a	n/a
18 Tanner Drive	WTST04	W	n/a	n/a	n/a	n/a	n/a
3 Alpine Cres - Grindelwald	WER53W02	W	n/a	n/a	n/a	n/a	n/a
205 Paper Beach Road	WEW51W02 ³⁹	W	n/a	n/a	n/a	n/a	n/a
175 Paper Beach Rd	WTST03	W	n/a	n/a	n/a	n/a	n/a
Glengarry Res, Reservoir	WER52W01	W	n/a	n/a	n/a	n/a	n/a
Kayena, Bonnie Beach	WEW56W01 ⁴⁰	W	n/a	n/a	n/a	n/a	n/a
89 Kayena Rd - Bonnie Beach	WTST08	W	n/a	n/a	n/a	n/a	n/a
Beauty Point, Esplanade Toilets	WEW51W01 ⁴¹	W	n/a	n/a	n/a	n/a	n/a
207 Mainwaring St	WTST07	W	n/a	n/a	n/a	n/a	n/a
Beaconsfield, John St Near Fire Station	BFW51W01	W	n/a	n/a	2M	n/a	n/a
1 Doncaster Court	WTST11 ⁴²	W	n/a	n/a	n/a	n/a	n/a
Number Planned Samples	573	4	4	48	4	n/a	n/a
Number Samples Tested	573	4	4	48	4	n/a	n/a

³⁶ Replaced by WTST01 31st May 2021

³⁷ Replaced by WTST06 1st April 2021

³⁸ Replaced by WTST04 23rd February 2021

³⁹ Replaced by WTST03 1st November 2020

⁴⁰ Replaced by WTST08 31st May 2021

⁴¹ Replaced by WTST07 1st November 2020

⁴² New installation from 31st May 2021. Zone was not being sampled.

57.3. Summary of current and historic performance (2016–21)

Table 57.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

57.4. Analysis of current health performance (2020–21)

Table 57.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 57.4-b Fluoride distribution performance

Distribution fluoride performance	
Indicator	2020–21
F exceeding 1.5 mg/L	0
Average F concentration range (0.8 mg/L – 1.1 mg/L)	0.9
90% of F results are equal to or less than 1.1 mg/L	100%

█ Compliant █ Non-compliant

Table 57.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0085	0.0051	0.0129
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Copper	2	mg/L	4	0	100	0.0008	0.0002	0.0012
Lead	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0002
Manganese	0.5	mg/L	4	0	100	0.0025	0.0010	0.0048
Mercury	0.001	mg/L	4	0	100	0.00010	<0.00003	0.00026
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	0.0001
Nickel	0.02	mg/L	4	0	100	0.0002	0.0001	0.0004
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 57.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	11	5	18
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	13	3	22
Total trihalomethanes	250	µg/L	4	0	100	44	21	68

Table 57.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.56	0.00	2.40
Colour True	HU	15	<1	<1	1
pH	Units	6.5 – 8.5	7.30	6.01	9.01
Turbidity	NTU	1	0.41	0.00	13.60

57.5. Analysis of overall system performance (2020–21)

Table 57.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

58. Westbury drinking water system

58.1. System summary (2020–21)

Westbury drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	1,188
Population serviced	2,370
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	104	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

☒ Compliant ☐ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	3	Discolouration

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$600,000




Figure 58.1-a Westbury system schematic




Figure 58.1-b Map of Westbury monitoring system

58.2. Summary of annual reticulation compliance (2020–21)

Table 58.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Westbury/Exton, Main Road	EXW51W01	W	n/a	n/a	2M	n/a	n/a	
Westbury/Hagley - Crn Selbourne & Meander Valley Rd	WHW51W04	W	Q	Q	2M	Q	n/a	
Number Planned Samples		104	4	4	48	4	n/a	
Number Samples Tested		104	4	4	48	4	n/a	

58.3. Summary of current and historic performance (2016–21)

Table 58.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	99.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

58.4. Analysis of current health performance (2020–21)

Table 58.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 58.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.9
90% of F results are equal to or less than 1.1 mg/L		100%
█ Compliant █ Non-compliant		

Table 58.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0078	0.0068	0.0085
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0002
Copper	2	mg/L	4	0	100	0.0029	0.0015	0.0047
Lead	0.01	mg/L	4	0	100	0.0003	0.0002	0.0005
Manganese	0.5	mg/L	4	0	100	0.0013	0.0012	0.0015
Mercury	0.001	mg/L	4	0	100	0.00007	<0.00003	0.00017
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Selenium	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0002

Table 58.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	8	4	10
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	10	8	13
Total trihalomethanes	250	µg/L	4	0	100	30	28	33

Table 58.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.74	0.21	1.09
Colour True	HU	15	<1	<1	<1
pH	Units	6.5 – 8.5	7.32	6.49	8.10
Turbidity	NTU	1	0.39	0.11	5.59

58.5. Analysis of overall system performance (2020–21)

Table 58.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			




Figure 58.5-b Water quality customer complaints by month and type

59. Whitemark drinking water system

59.1. System summary (2020–21)

Whitemark drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	178
Population serviced	261
Fluoride	n/a

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	52	0
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	0	

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
No projected capital investment				




Figure 59.1-a Whitemark system schematic




Figure 59.1-b Map of Whitemark monitoring system

59.2. Summary of annual reticulation compliance (2020–21)

Table 59.2-a Sampling program

Planned sampling program (2020–21)							
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals
Whitemark/Council Depot	WMW51W01	W	Q	Q	n/a	Q	n/a
Number Planned Samples		52	4	4	n/a	4	n/a
Number Samples Tested		52	4	4	n/a	4	n/a

59.3. Summary of current and historic performance (2016–21)

Table 59.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	99.1%	100.0%	100.0%	100.0%	100.0%
Fluoride	n/a	n/a	n/a	n/a	n/a
Metals	100.0%	100.0%	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

59.4. Analysis of current health performance (2020–21)

Table 59.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

Table 59.4-b Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0015	<0.0005	0.0032
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0002	<0.0001	0.0003
Copper	2	mg/L	4	0	100	0.0003	0.0002	0.0003
Lead	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0002
Manganese	0.5	mg/L	4	0	100	0.0004	0.0003	0.0005
Mercury	0.001	mg/L	4	0	100	0.00006	<0.00003	0.00012
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0001	<0.0001	0.0004
Selenium	0.01	mg/L	4	0	100	0.0001	<0.0001	0.0003

Table 59.4-c Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	<1	<1	<1
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	<3
Trichloroacetic acid	100	µg/L	4	0	100	<1	<1	<1
Total trihalomethanes	250	µg/L	4	0	100	10	<4	15

Table 59.4-d General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.85	0.54	1.240
Colour True	HU	15	<1	<1	2
pH	Units	6.5 – 8.5	8.65	7.66	9.45
Turbidity	NTU	1	0.44	0.10	1.05

59.5. Analysis of overall system performance (2020–21)

Table 59.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			

60. Zeehan drinking water system

60.1. System summary (2020–21)

Zeehan drinking water system	
System status (as at 30 June 2021)	Potable
Total number of connections	625
Population serviced	905
Fluoride	Sodium fluoride

Performance overview against health targets (2020–21)					
Indicator	Outcome	Compliance	Target	Sampling Events	Exceedances
Microbiological	100.0%	☒	98.0%	106	0
Fluoride	100.0%	☒	100.0%	48	0
Metals	100.0%	☒	100.0%	4	0
DBPs	100.0%	☒	100.0%	4	0

█ Compliant █ Non-compliant

Overall system performance (2020–21)		
Indicator	Occurrences	Details
System issues	0	
Public health warnings issued	0	
Notifications made to DoH	0	
Customer complaints	1	Other (illness)

Current and future planned capital investment				
Project	Overview	Progress	Est. Delivery	Est. Spend
WTP Upgrade	UV Installation	Planning	2022/2023	\$1,000,000




Figure 60.1-a Zeehan system schematic




Figure 60.1-b Map of Zeehan monitoring system

60.2. Summary of annual reticulation compliance (2020–21)

Table 60.2-a Sampling program

Planned sampling program (2020–21)								
Site name	Site Code	Micros	Metals	DBP	Fluoride (Lab)	Chemical Profile	Process Chemicals	
Zeehan/Main Street Sample Point	164ZESP0101	W	n/a	n/a	2M	n/a	n/a	
Zeehan/CMW Depot Sample Point	164ZESP0201	W	Q	Q	2M	Q	n/a	
Number Planned Samples	106		4	4	48	4	n/a	
Number Samples Tested	106		4	4	48	4	n/a	

60.3. Summary of current and historic performance (2016–21)

Table 60.3-a Historical health performance overview (5 year comparison)

Historical health performance overview (5 year comparison)					
Indicator	2016–17	2017–18	2018–19	2019–20	2020–21
Microbiological	100.0%	100.0%	100.0%	100.0%	100.0%
Fluoride	100.0%	100.0%	100.0%	100.0%	100.0%
Metals	100.0%	97.9% ⁴³	100.0%	100.0%	100.0%
Disinfection by products	100.0%	100.0%	100.0%	100.0%	100.0%

█ Compliant █ Non-compliant

60.4. Analysis of current health performance (2020–21)

Table 60.4-a Summary of health guideline exceedances

Summary of health guideline exceedances			
Parameter Exceeding	Date	Details	Resampled
No ADWG exceedances			

⁴³ Retesting of metals showed no further issues

Table 60.4-b Fluoride distribution performance

Distribution fluoride performance		2020–21
Indicator		
F exceeding 1.5 mg/L		0
Average F concentration range (0.8 mg/L – 1.1 mg/L)		0.8
90% of F results are equal to or less than 1.1 mg/L		100%
 Compliant  Non-compliant		

Table 60.4-c Metals performance

Metals – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Antimony	0.003	mg/L	4	0	100	<0.0005	<0.0005	<0.0005
Arsenic	0.01	mg/L	4	0	100	<0.0003	<0.0003	<0.0003
Barium	2	mg/L	4	0	100	0.0036	0.0030	0.0043
Cadmium	0.002	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Chromium	0.05	mg/L	4	0	100	0.0001	<0.0001	0.0003
Copper	2	mg/L	4	0	100	0.0041	0.0030	0.0058
Lead	0.01	mg/L	4	0	100	0.0002	0.0001	0.0003
Manganese	0.5	mg/L	4	0	100	0.0068	0.0047	0.0118
Mercury	0.001	mg/L	4	0	100	0.00011	<0.00003	0.00021
Molybdenum	0.05	mg/L	4	0	100	<0.0001	<0.0001	<0.0001
Nickel	0.02	mg/L	4	0	100	0.0011	0.0009	0.0014
Selenium	0.01	mg/L	4	0	100	<0.0001	<0.0001	<0.0001

Table 60.4-d Disinfection by product performance

Disinfection by products – health regulated parameters								
Parameter	Limit	Unit	Samples	Exceedances	Performance %	Mean	Min.	Max.
Dichloroacetic acid	100	µg/L	4	0	100	23	10	36
Monochloroacetic acid	150	µg/L	4	0	100	<3	<3	4
Trichloroacetic acid	100	µg/L	4	0	100	39	30	46
Total trihalomethanes	250	µg/L	4	0	100	84	60	100

Table 60.4-e General physical performance

General physical parameters					
Parameter	Unit	Guideline Value	Mean	Min	Max
Chlorine residual	mg/L	0.1 – <0.8	0.75	0.09	1.71
Colour True	HU	15	1.25	<1	2
pH	Units	6.5 – 8.5	7.60	6.98	8.08
Turbidity	NTU	1	0.20	0.09	0.69

60.5. Analysis of overall system performance (2020–21)

Table 60.5-a Summary of system issues/public health warnings

Summary of system issues			
Date	Description	DoH notification required	DoH notification complete
No system issues or public health warnings issued			



Figure 60.5-b Water quality customer complaints by month and type



Annual Drinking Water Quality Report 2020-21

Section B - Summary