



NOTES

- 1. SINK STRAINER UNITS OR SIMILAR APPROVED UNITS ARE RECOMMENDED AND MAY BE REQUIRED TO BE FITTED TO SINKS IN COMMERCIAL OPERATIONS. i.e. FOOD PRODUCTION OR PREPARATION AREAS.
- 2. PRIMARY STRAINER UNITS ARE TO BE FABRICATED FROM STAINLESS STEEL PERFORATED METAL OR MESH, WITH A MAXIMUM OF 3.5mm OPENINGS.
- 3. FIXED SECONDARY STRAINERS ARE TO BE FABRICATED FROM STAINLESS STEEL PLATE WITH 4mm HOLES.
- 4. SINK STRAINER UNITS CAN BE RETROFITTED TO SINKS.
- 5. ALL MEASUREMENTS SHOWN ARE IN MILLIMETRES.

THESE STANDARD DRAWINGS ARE PROVIDED AS A GUIDE.  
THE DESIGNER SHOULD ENSURE THAT THE PRETREATMENT SOLUTION IS  
DESIGNED TO ENSURE COMPLIANCE WITH TASWATER DISCHARGE QUALITY  
REQUIREMENTS AND ALL OTHER REGULATORY REQUIREMENTS

TO BE READ IN CONJUNCTION WITH TASWATER PRETREATMENT GUIDELINES

Revision Notes					
1 - GENERAL UPDATE. SEE HPE RECORD NO. 19/136338					
B - INITIAL ISSUE					
Rev.	1	Date	13/11/19	Approved	Greg Cooper



Scale	NTS
Datum	-
Sheet Size	A3
References	

Drawn	PH	24/9/2015
Designed	GC	24/9/2015
Verified	AD	6/10/2015
Project No.	-	Discipline
Vault Folder	© 2015	
HPRM File Ref.	T15/161-002-0001	

DRAWING ISSUE

NOT FOR  
CONSTRUCTION



This drawing and the information it contains is, and remains the property of TasWater and must not be disclosed to third parties, or copied or reproduced wholly or in part or in any format without the written consent of the owners. The information contained herein is also correct and up-to-date, but all details should be verified on site by the user prior to construction. This drawing is produced on an A3 size sheet. DO NOT SCALE a sheet plotted at any other size.

TASWATER STANDARD DRAWING  
TRADE WASTE TYPICAL DRAWING  
SINK STRAINER/BASKET ARRESTOR UNITS

TASMANIAN WATER & SEWAGE CORPORATION PTY LTD  
ABN: 47 162220 653

Drawing Number	TWS-C-0001		Sheet Number	3	REVISION
					1