

NOTES

1. SINK STRAINER UNITS OR SIMILAR APPROVED UNITS ARE RECOMMENDED AND MAY BE REQUIRED TO BE FITTED TO SINKS IN COMMERCIAL OPERATIONS. i.e. FOOD PRODUCTION OR PREPARATION AREAS.
2. PRIMARY STRAINER UNITS ARE TO BE FABRICATED FROM STAINLESS STEEL PERFORATED METAL OR MESH, WITH A MAXIMUM OF 3.5mm OPENINGS.
3. FIXED SECONDARY STRAINERS ARE TO BE FABRICATED FROM STAINLESS STEEL PLATE WITH 4mm HOLES.
4. SINK STRAINER UNITS CAN BE RETROFITTED TO SINKS.
5. ALL MEASUREMENTS SHOWN ARE IN MILLIMETRES.

THESE STANDARD DRAWINGS ARE PROVIDED AS A GUIDE. THE DESIGNER SHOULD ENSURE THAT THE PRETREATMENT SOLUTION IS DESIGNED TO ENSURE COMPLIANCE WITH TASWATER DISCHARGE QUALITY REQUIREMENTS AND ALL OTHER REGULATORY REQUIREMENTS

TO BE READ IN CONJUNCTION WITH TASWATER PRETREATMENT GUIDELINES


Revision Notes				
1 - GENERAL UPDATE. SEE HPE RECORD NO. 19/136338				
B - INITIAL ISSUE				
Rev.	1	Date	13/11/19	Approved
			Greg Cooper	



Scale	NTS
Datum	-
Sheet Size	A3
References	

Drawn	PH	24/9/2015
Designed	GC	24/9/2015
Verified	AD	6/10/2015
Project No.	-	Discipline
Vault Folder	© 2015	
HPRM File Ref.	T15/161-002-0001	

DRAWING ISSUE
NOT FOR CONSTRUCTION



TASWATER STANDARD DRAWING			
TRADE WASTE TYPICAL DRAWING			
SINK STRAINER/BASKET ARRESTOR UNITS			
TASMANIAN WATER & SEWAGE CORPORATION PTY LTD		ABN: 47 162220 653	
Sheet Number	TWS-C-0001	Revision	3
			1