

Addendum

Addendum O2 to TasWater Supplement to WSAA Gravity Sewerage Code of Australia – MRWA Edition (WSA-02-2014-3.1) Version 2.1

Purpose

This addendum provides clarification in regard to acceptability of products utilised in construction of TasWater gravity sewerage assets. The following products are noted as acceptable (with limitations) for use in TasWater gravity sewerage systems. All products must be installed in accordance with TasWater and the manufacturers specifications.

Hudson Civil Products

Concrete maintenance holes manufactured by Hudson Civil Products that comply with Australian Standards in the following diameters:

- Standard steel reinforced shafts – 1050mm, 1200mm and 1500mm

Limitations: See section 7.6.3 of TasWater Supplement to WSAA Sewerage Code of Australia – MRWA Edition (WSA-03-2011-3.1)

Tas Concrete Products

Concrete maintenance holes manufactured by Tas Concrete Products that comply with Australian Standards in the following diameters:

- Standard steel reinforced shafts – 1050mm, 1200mm and 1500mm
- Fibre reinforced shafts – 1050mm only.

Limitations: See section 7.6.3 of TasWater Supplement to WSAA Sewerage Code of Australia – MRWA Edition (WSA-03-2011-3.1)

Terra Firma (Supplied by Geotas)

Thrubeam ER60 access covers for up to Class D loading.

Limitations: Only to be used in major population centres, and with documented approval by TasWater where TasWater staff have access to the propriety tools

Rehau (Supplied by Reece)

AWASHAFT DN1000 Plastic Maintenance holes

Limitations: As per MRWA scope of approval and South East Water limitations published on the MRWA product portal.

Exclusions: AWASHAFT DN600/800 and AWASHAFT DN400 are not accepted for use without project specific approval.

EziPit (Supplied by Hudson Civil Products)

1000MH Plastic Maintenance holes


Limitations: As per MRWA scope of approval and South East Water limitations published on the MRWA product portal.

Exclusions: Ezipit 600MC and Ezipit 425MS are not accepted for use without project specific approval.

Further Information

This Addendum shall be implemented immediately on all projects.

If you have any further enquiries or suggestions regarding this Addendum, please e-mail standards@taswater.com.au



Approved: Matt Jordan
(for issue) Head of Infrastructure Investment

Date: 4/12/2024