

**NOTES**

1. SINK STRAINER UNITS OR SIMILAR APPROVED UNITS ARE RECOMMENDED AND MAY BE REQUIRED TO BE FITTED TO SINKS IN COMMERCIAL OPERATIONS. i.e. FOOD PRODUCTION OR PREPARATION AREAS.
2. PRIMARY STRAINER UNITS ARE TO BE FABRICATED FROM STAINLESS STEEL PERFORATED METAL OR MESH, WITH A MAXIMUM OF 3.5mm OPENINGS.
3. FIXED SECONDARY STRAINERS ARE TO BE FABRICATED FROM STAINLESS STEEL PLATE WITH 4mm HOLES.
4. SINK STRAINER UNITS CAN BE RETROFITTED TO SINKS.
5. ALL MEASUREMENTS SHOWN ARE IN MILLIMETRES.

**THESE STANDARD DRAWINGS ARE PROVIDED AS A GUIDE.  
 THE DESIGNER SHOULD ENSURE THAT THE PRETREATMENT SOLUTION IS  
 DESIGNED TO ENSURE COMPLIANCE WITH TASWATER DISCHARGE QUALITY  
 REQUIREMENTS AND ALL OTHER REGULATORY REQUIREMENTS**

**TO BE READ IN CONJUNCTION WITH TASWATER PRETREATMENT GUIDELINES**


Revision Notes					
1 - GENERAL UPDATE. SEE HPE RECORD NO. 19/136338					
B - INITIAL ISSUE					
Rev.	1	Date	13/11/19	Approved	Greg Cooper



Scale	NTS
Datum	-
Sheet Size	A3
References	

Drawn	PH	24/9/2015
Designed	GC	24/9/2015
Verified	AD	6/10/2015
Project No.	-	Discipline
Vault Folder	© 2015	
HPRM File Ref.	T15/161-002-0001	

**NOT FOR  
CONSTRUCTION**



TASWATER STANDARD DRAWING TRADE WASTE TYPICAL DRAWING SINK STRAINER/BASKET ARRESTOR UNITS			
TASMANIAN WATER & SEWAGE CORPORATION PTY LTD ABN: 47 162220 653		Sheet Number <b>TWS-C-0001</b>	REVISION 3 1