

## 16. Cressy STP

### 16.1 Activity and report details

|                              |   |               |            |
|------------------------------|---|---------------|------------|
| Activity name                | Cressy STP                                  |               |            |
| Activity address             | Old Stock Route, off Murfett Street, Cressy |               |            |
| Permit number                | Licence to Operate - 3577                   | Date of issue | 22/11/1988 |
| EPN                          | 7264/1                                      | Date of issue | 27/07/2006 |
| Treatment level              | Secondary Treatment                         |               |            |
| Authorised dry weather flows | 240 kL/day                                  |               |            |
| Key influent source          | Residential                                 |               |            |
| Contact person               | Kate Westgate                               |               |            |
| Report author                | Luisa Romero (Environmental Scientist)      |               |            |
| Contact details              | Environment@taswater.com.au                 |               |            |
| Date of submission           | 30 September 2025                           |               |            |

**Figure 16-1: Cressy Sewage Treatment Plant**



## 16.2 Monitoring and compliance summary

### 16.2.1. Flow data

**Table 16–A: Flow monitoring summary**

|   | Influent            | Effluent                   | Reuse                      |
|---|---------------------|----------------------------|----------------------------|
| <b>Location name</b>  | Inlet               | Back Creek                 | Cressy Reuse Scheme        |
| <b>Coordinates</b>  | E505959<br>N5385487 | E506055<br>N5385672        | E504790<br>N5386503        |
| <b>Method of measurement</b>                                | In line meter       | Estimate based on influent | Estimate based on influent |
| <b>Date of last calibration/validation (if applicable).</b> | 15/11/2024          | NA – to be installed       | NA – to be installed       |

**Table 16–B: Annual flow and rainfall data**

| Month                       | Average daily influent volume (kL/day) | Rainfall (mm/month)<br>BOM Station ID<br>91375 | Discharge to waters total effluent volume (ML) | Discharge to reuse total effluent volume (ML) |
|-----------------------------|--|--|--|---|
| July 2024                   | 269                                    | 62.6   | 0.00   | 8.34  |
| August 2024                 | 257                                    | 90.4   | 0.00   | 7.97  |
| September 2024              | 272                                    | 67.4   | 0.00   | 8.15  |
| October 2024                | 263                                    | 24.8   | 0.00   | 8.15  |
| November 2024               | 200                                    | 58.8   | 0.00   | 5.99  |
| December 2024               | 212                                    | 66   | 0.00   | 6.58  |
| January 2025                | 185                                    | 14.4   | 0.00   | 5.72  |
| February 2025               | 189                                    | 16.6   | 0.00   | 5.30  |
| March 2025                  | 215                                    | 19.4   | 0.00   | 6.67  |
| April 2025                  | 192                                    | 23   | 0.00   | 5.77  |
| May 2025                    | 176                                    | 40.8   | 0.00   | 5.45  |
| June 2025                   | 235                                    | 60   | 0.00   | 7.04  |
| Annual 2024–25              | 222                                    | 544.2  | 0.00   | 81.13   |
| <b>% of total discharge</b> | --                                     | --   | 0.0%   | 100.0%  |

2024–25 monthly flow data was submitted directly to the EPA.

### 16.3 Bypass events

There were no bypass events associated with the STP during the reporting period.

## 16.4 Discharge compliance with permit limits

**Table 16–C: Discharge compliance with permit limits**

| Parameter                         | Ammonia | BOD5 | Chlorine | Nitrogen | Oil and grease | pH    | Phosphorous | E coli    | Total suspended solids |
|-----------------------------------|---------|------|----------|----------|----------------|-------|-------------|-----------|------------------------|
| Permit/EPN limit                  | mg/L    | mg/L | mg/L     | mg/L     | mg/L           | Units | mg/L        | MPN/100mL | mg/L                   |
| Maximum                           | 20      | 50   | --       | 25       | 10             | 10    | 10          | --        | 50                     |
| 90th percentile                   | --      | --   | --       | --       | --             | --    | --          | --        | --                     |
| 50th percentile                   | --      | --   | --       | --       | --             | --    | --          | 1000      | --                     |
| Minimum                           | --      | --   | --       | --       | --             | 6.5   | --          | --        | --                     |
| <b>Samples analysed</b>           |         |      |          |          |                |       |             |           |                        |
| Number required                   | 12      | 12   | --       | 12       | 12             | 12    | 12          | 12        | 12                     |
| Number analysed                   | 12      | 12   | --       | 12       | 12             | 12    | 12          | 12        | 12                     |
| <b>Statistical summary</b>        |         |      |          |          |                |       |             |           |                        |
| Maximum                           | 29.5    | 70.0 | 0.0      | 55.0     | 1.7            | 9.1   | 8.1         | 8164.0    | 77.0                   |
| 90th percentile                   | 24.5    | 54.2 | 0.0      | 37.4     | 1.5            | 8.9   | 7.4         | 1422.0    | 74.7                   |
| 50th percentile                   | 13.9    | 22.5 | 0.0      | 25.5     | 1.1            | 8.1   | 6.2         | 600.0     | 35.5                   |
| Minimum                           | 5.0     | 5.0  | 0.0      | 12.2     | 1.0            | 7.3   | 2.9         | 10.0      | 5.5                    |
| <b>EPN limit compliance</b>       |         |      |          |          |                |       |             |           |                        |
| % compliance with maximum         | 75%     | 83%  | --       | 50%      | 100%           | 100%  | 100%        | --        | 75%                    |
| % compliance with 90th percentile | --      | --   | --       | --       | --             | --    | --          | --        | --                     |
| % compliance with 50th percentile | --      | --   | --       | --       | --             | --    | --          | 75%       | --                     |
| % compliance with pH range        | --      | --   | --       | --       | --             | 100%  | --          | --        | --                     |

**Table 16-D: Mass loads to the environment**

| Mass Loads              | EPN limit                        | Frequency | 2024-25 result |
|-------------------------|----------------------------------|-----------|----------------|
| <b>Nitrogen</b>         | --                               | Annual    | 0.0            |
| <b>Phosphorous (kg)</b> | --                               | Annual    | 0.0            |
| <b>Method</b>           | Time weighted/Grab sample method |           |                |

#### 16.4 Discharge compliance with permit limits

No parameters have had exceedances in the FY period as there was no discharge to environment.

## 16.5 Reuse annual reporting

The Cressy STP supplies treated effluent to the Cressy recycled water scheme (RWS) for irrigation purposes at the Fairbank property.

**Table 16–E: Reuse compliance summary**

| Parameter                         | BOD5 | pH    | E coli    |
|-----------------------------------|------|-------|-----------|
| Permit/EPN limit                  | mg/L | Units | MPN/100ml |
| Maximum                           | 50   | 10.0  | 10000     |
| 90th percentile                   | --   | --    | --        |
| 50th percentile                   | --   | --    | 1000      |
| Minimum                           | --   | 5.5   | --        |
| <b>Samples analysed</b>           |      |       |           |
| Number required                   | 12   | 12    | 12        |
| Number analysed                   | 12   | 12    | 12        |
| <b>Statistical summary</b>        |      |       |           |
| Maximum                           | 99.0 | 9.2   | 1956      |
| 90th percentile                   | 88.5 | 9.1   | 1072      |
| 50th percentile                   | 30.5 | 7.9   | 241       |
| Minimum                           | 5.0  | 7.4   | 15        |
| <b>Summary of results</b>         |      |       |           |
| % compliance with maximum         | 67%  | --    | 100%      |
| % compliance with 90th percentile | --   | --    | --        |
| % compliance with 50th percentile | --   | --    | 83%       |
| % compliance with pH range        | --   | 100%  | --        |

**Table 16–F: Performance analysis (discharge to reuse)**

| Reuse compliance parameter | Date(s) of elevated parameter                       | Reasons  | Actions to improve performance |
|----------------------------|---|--|--------------------------------|
| BOD                        | 25/06/2025<br>26/05/2025<br>6/03/2025<br>18/02/2025 | 25/06/2025 decreased lagoon hydraulic retention time and treatment capacity due to wet weather event.<br><br>Algae is believed to be the primary reason for elevated BOD. Algae is a source of oxygen and is fundamental to lagoon treatment. Most of the non-compliant results were in warmer months when algal blooms occur. | No actions taken               |

Note: Non-compliances only identified for the times STP has discharged to reuse

Annual soil sampling continued at sites 1D, 2AB and 2D and reestablished in 1C in June 2024 at the Fairbanks property. Sampling ceased at site ID number 1A and continued to not occur due to cessation of irrigation at these paddocks. The field component of the annual compliance audit was completed in conjunction with the soil sampling. A summary of the findings of the two programs is provided in Table 16–H.

**Table 16-G: Annual recycled water scheme compliance audit and soil monitoring**

| Program  | Compliance audit   | Soil monitoring  |
|----------|--|--|
| Outcomes | Compliant  | Site 1D continues to record elevated salinity levels although lower than previous year. Sodicity remains elevated.   |
| Comments | Previous 2023-24 audit findings regarding signage requirements had been fixed. | Elevated levels of two key analytes were recorded across the property and are likely attributed to fertiliser application and not recycled water irrigation due to low irrigation rates in comparison to fertiliser application. |

RWS Groundwater Status: Amber

Cressy RWS groundwater monitoring network consists of three groundwater monitoring bores (CRGW2, CRGW4 and CRGW5). Bore ID: CRGW5 is associated with the recycled water storage dam.

Bi-annual sampling at the standard analytical suite was completed across the network in November 2024 and May 2025 as scheduled.

The 2024-25 groundwater monitoring event recorded elevated concentrations of key analytes at one bore (ID number CRGW2) above adopted assessment criterion. Given the low application rate of recycled water, it is unlikely elevated levels are attributed to recycled water. Bore ID's CRGW4 and 5 reported no evidence of impact from recycled water activities.

Bi-annual sampling is scheduled to continue at monitoring bore ID CRGW2 for the 2025-26 groundwater monitoring program to further investigate the fluctuating and elevated levels. Sampling at bore ID's CRGW4-5 is scheduled to reduce to an annual frequency. All monitoring will be at the standard analytical site.

## 16.6 Ambient monitoring program

**Table 16-H: Program details**

|          |   |
|----------|---|
| Program  | No ambient monitoring required under EPA permit variation 18/01/2024. |
| Status   | No ambient monitoring required under EPA permit variation.            |
| Update   | No ambient monitoring undertaken during the reporting period.         |
| Comments | No ambient monitoring undertaken during the reporting period.         |

## 16.7 Groundwater monitoring

Site Status: Green

Cressy groundwater monitoring network consists of one bore (ID: CRGW1) located to the north of the STP.

One round of sampling was completed (annual) in May 2025. The scheduled 6-monthly sampling (scheduled November 2025) was unable to be completed due to access restrictions (cropped paddocks and fooding).

The 2024–25 groundwater monitoring event recorded no sign of STP impact to groundwater. A data gap in the monitoring network was identified to the east of the STP.

Bi-annual sampling at the standard analytical suite is scheduled to continue for the 2024–25 groundwater monitoring program.

## 16.8 Inflow and infiltration (I&I)

The latest revision to the TasWater Inflow and Infiltration Management Plan includes details of the actions undertaken statewide to address I&I issues.

A Multi Criteria Assessment was undertaken by TasWater in 2024 to prioritise I&I investigation and works state-wide. This catchment was ranked 42 out of 108 in priority. Actions in the period included:

- Field investigations and defect resolution are ongoing.

## 16.9 Sludge and biosolids

The latest revision to the Sewage Sludge Management Plan (SSMP) includes full details of the actions undertaken during the reporting period, the most recent sludge profiling results, and upcoming annual desludging program. This STP was assessed as compliant with the 2024–25 SSMP.

Sludge at this STP is captured within the two treatment lagoons, which will be periodically desludged as required. No stockpiling occurs at this site.

**Table 16–I: Desludging status and comments**

| Desludging status | Comments  |
|-------------------|---|
| Low priority      | Desludging of Lagoon 1 was completed in 2024. Lagoons 1 and 2 are currently low priority – unlikely to require desludging again for another 10 to 20 years. |

## 16.10 Non-compliance with other permit requirements

**Table 16–J: EPN non-compliances**

| EPN condition              | Description of non-conformance                                | Future actions to be taken                                       |
|----------------------------|---|--|
| 36 Effluent Quality limits | Discharge compliance with the environmental compliance limits | See section 16.4   |
| 38 Wastewater Re-use       | Discharge compliance with reuse permit limit                  | See section 16.5 Reuse Annual Reporting and Performance Analysis |

### 16.11 Complaints and incident reporting

No incidents were received during the 2024–25 reporting period.

**Table 16–K: Complaints reporting**

| Date   | Category | Details                   | Mitigation actions  |
|--|----------|---------------------------|---|
| 08/10/2024<br>28/10/2024<br>29/10/2024<br>31/10/2024<br>06/11/2024 | Odour    | Strong odour from lagoons | A pump and tubing were installed in the outlet reuse pump station wet well. This pump returned the Lagoon 2 effluent to Lagoon 1, increasing circulation/ mixing through the system and increasing the biomass in Lagoon 1. |

### 1.1. Any other relevant information

**Table 16–L: Projects or significant operational events that occurred in FY 2024–25**

| Project or significant operational event    | Progress  |
|---|---|
| Meander Tamar Sewerage Regional Master Plan | The Meander Tamar Sewerage Regional Master Plan has been completed and includes the short term and long-term considerations for the Cressy STP with the ultimate decommissioning of the STP and transfer of sewage to the Longford STP. |

For further information on Cressy STP please contact TasWater on 13 6992

[www.taswater.com.au](http://www.taswater.com.au)